

DAWSON CREEK, BC, Canada

WMO: 714710

Lat: 55.7388N

Lon: 120.1869W

Elev: 2148

StdP: 13.59

Time Zone: -7.00 (W07)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-30.2	-22.9	-38.3	0.7	-30.2	-30.8	1.1	-22.9	28.5	37.2	25.1	36.5	1.6	270	0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	82.2	61.5	78.9	60.0	75.8	58.7	63.8	77.1	62.1	75.0	60.4	72.5	8.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.9	80.5	67.8	57.0	75.1	66.2	55.2	70.3	64.8	30.2	77.3	28.9	75.3	27.7	72.4	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.4	21.2	18.5	-36.1	88.1	6.2	3.5	-40.5	90.6	-44.1	92.6	-47.6	94.6	-52.1	97.1		
(5)			-35.0	68.2	7.5	2.2	-40.3	69.8	-44.7	71.1	-48.9	72.3	-54.3	73.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.3	13.8	13.0	21.9	37.6	50.2	57.3	61.5	58.8	51.0	38.6	20.0	10.7
	DBStd	22.07	17.94	16.67	14.94	9.29	7.47	5.35	4.48	6.08	7.92	8.98	14.97	16.19
	HDD50	6070	1121	1035	871	378	89	7	0	6	82	362	900	1219
	HDD65	10501	1586	1455	1336	823	460	237	125	205	422	818	1350	1684
	CDD50	1082	0	0	0	5	95	225	358	279	111	9	0	0
	CDD65	38	0	0	0	0	0	5	18	14	1	0	0	0
	CDH74	1078	0	0	0	3	55	158	444	324	91	3	0	0
	CDH80	220	0	0	0	0	4	21	109	71	15	0	0	0
Wind	WSAvg	7.1	6.8	5.9	6.5	8.1	8.0	7.9	7.4	7.0	7.4	7.7	6.5	6.0
Precipitation	PrecAvg	19.4	1.1	0.9	0.9	0.7	1.5	3.2	3.1	2.6	2.0	1.2	1.0	1.1
	PrecMax	24.7	3.6	3.0	2.0	1.7	4.7	7.0	7.1	6.4	4.9	3.1	2.2	4.5
	PrecMin	12.2	0.4	0.2	0.1	0.2	0.1	1.1	0.7	0.4	0.2	0.4	0.1	0.0
	PrecStd	3.5	0.8	0.7	0.5	0.5	1.1	1.9	1.9	1.5	1.3	0.7	0.6	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.2	47.4	55.1	68.3	79.6	82.8	88.3	86.4	81.8	68.0	50.1	45.0
		MCWB	38.9	39.1	44.3	50.5	56.3	62.8	63.9	62.7	58.9	51.4	41.8	37.3
	2%	DB	44.6	43.0	47.7	61.2	74.6	78.3	82.6	81.4	76.2	61.2	45.1	41.2
		MCWB	38.2	36.4	39.3	46.8	54.2	59.2	62.0	61.5	58.1	48.6	38.5	35.0
	5%	DB	42.0	40.3	44.1	55.8	70.5	74.9	78.8	77.3	70.9	56.3	42.2	37.7
		MCWB	36.4	34.6	36.9	42.8	52.4	57.6	61.1	60.0	55.9	45.9	36.4	32.4
	10%	DB	39.1	37.2	41.2	52.1	66.2	71.2	75.2	73.7	65.9	52.7	39.3	34.5
		MCWB	34.1	32.2	34.8	40.4	50.2	55.9	59.7	58.3	53.3	43.6	34.2	29.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.8	40.1	44.6	51.7	58.6	64.6	67.4	65.5	62.7	53.8	43.4	38.4
		MCDB	45.8	46.4	53.1	68.0	75.4	78.9	80.5	79.8	77.4	66.0	48.6	44.2
	2%	WB	38.3	36.9	39.7	47.0	55.6	61.5	64.4	63.0	59.1	49.5	39.4	35.3
		MCDB	43.9	42.4	46.6	59.9	70.6	74.6	77.3	77.3	72.9	58.8	44.3	40.6
	5%	WB	36.5	34.8	37.4	43.5	53.4	59.3	62.6	61.2	56.6	46.8	36.8	32.5
		MCDB	41.8	39.7	43.4	54.1	67.8	70.8	75.1	74.1	68.9	55.1	41.5	37.3
	10%	WB	34.3	32.6	35.2	41.3	51.5	57.3	61.0	59.5	54.3	44.1	34.6	29.7
		MCDB	38.9	37.3	40.8	50.6	64.3	68.3	72.6	71.3	64.7	51.5	38.9	34.2
Mean Daily Temperature Range	5% DB	MDBR	17.8	19.1	19.4	19.6	23.9	22.2	22.9	24.0	22.3	17.7	16.9	17.5
		MCDBR	17.2	19.7	20.5	28.5	32.7	30.6	32.7	32.7	32.0	25.9	18.2	20.0
		MCWBR	12.8	14.7	14.1	16.5	16.1	14.5	15.4	15.8	16.3	15.5	13.3	15.9
	5% WB	MCDBR	16.4	19.7	19.9	26.6	29.3	26.1	28.7	28.7	30.1	24.4	18.0	19.8
		MCWBR	12.6	15.1	14.1	16.0	15.0	13.5	14.9	14.8	16.0	15.2	13.7	16.2
Clear-Sky Solar Irradiance	taub	0.237	0.250	0.286	0.325	0.351	0.348	0.349	0.347	0.311	0.286	0.244	0.226	
	taud	2.329	2.382	2.347	2.387	2.382	2.404	2.436	2.437	2.538	2.562	2.426	2.265	
	Ebn at Noon	228	271	283	285	282	284	281	275	273	255	226	201	
	Edh at Noon	16	22	29	33	35	35	33	31	24	18	14	13	
All-Sky Solar Radiation	RadAvg	219	508	956	1467	1734	1904	1853	1511	1027	548	248	158	
	RadStd	22	40	70	77	119	173	119	134	96	60	24	12	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (16 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+104	N/A	

Nomenclature: See separate page