

KINDAKUN ROCKS, BC, Canada

WMO: 714720

Lat: 53.316N

Lon: 132.772W

Elev: 53

StdP: 14.67

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	27.7	31.0	9.0	8.7	28.9	14.7	11.6	32.5	47.4	44.2	43.5	44.5	12.5	90	0.807

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	62.3	57.6	60.7	57.5	59.6	56.8	59.4	61.1	58.5	60.0	57.7	59.2	10.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.7	73.8	60.1	57.8	71.6	59.3	57.0	69.4	58.5	26.1	61.3	25.4	60.2	24.9	59.5	62.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.1	37.6	32.9	DB	24.8	67.7	4.8	5.7	21.4	71.9	18.6	75.2	15.9	78.5	12.4	82.6	(4)
(5)			WB	21.0	61.1	4.9	1.1	17.5	61.9	14.6	62.6	11.9	63.2	8.3	64.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.9	42.5	41.5	41.8	44.3	47.6	51.3	54.7	56.6	55.5	50.7	45.4	42.3	(6)	
	DBStd	6.54	4.78	4.33	4.07	3.50	3.32	2.66	2.39	2.20	2.52	3.08	4.46	4.70	(7)	
	HDD50	1418	232	239	256	176	89	13	0	0	0	28	145	240	(8)	
	HDD65	6245	696	658	720	620	539	411	320	260	286	443	588	704	(9)	
	CDD50	650	1	0	1	6	15	53	146	206	164	50	7	1	(10)	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH74	5	0	0	0	0	5	0	0	0	0	0	0	0	(12)	
	CDH80	2	0	0	0	0	2	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	14.8	16.4	15.6	15.9	15.0	13.8	13.1	12.7	12.1	13.6	16.1	16.8	17.2	(14)	
(15) Precipitation	PrecAvg	66.2	7.2	5.4	4.9	4.5	3.1	2.6	2.6	3.4	5.1	8.9	8.7	9.0	(15)	
	PrecMax	82.8	11.0	9.3	7.6	7.9	7.3	4.8	7.6	7.6	10.5	16.1	16.8	19.7	(16)	
	PrecMin	53.4	3.4	2.4	2.3	2.6	0.8	1.2	0.4	1.5	1.0	4.1	5.7	3.6	(17)	
	PrecStd	7.9	1.8	2.2	1.4	1.3	1.6	1.0	1.6	1.5	2.0	3.1	2.3	3.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.2	51.9	54.0	60.3	63.7	63.0	62.1	64.6	64.5	59.2	55.8	53.1	(19)	
		MCWB	48.6	46.7	47.4	47.6	50.7	55.7	57.7	60.2	58.1	56.2	50.9	48.9	(20)	
	2%	DB	50.8	49.8	49.9	53.0	54.6	58.0	60.0	62.4	61.2	57.3	53.8	50.8	(21)	
		MCWB	48.1	46.5	46.5	46.9	49.7	54.7	57.1	58.9	57.5	54.4	50.9	47.8	(22)	
	5%	DB	49.2	48.2	48.3	49.7	52.2	56.0	58.9	61.0	60.0	56.0	52.4	49.2	(23)	
		MCWB	47.0	45.5	45.3	46.4	48.6	53.5	56.5	58.0	57.1	53.0	50.0	46.7	(24)	
	10%	DB	47.9	46.7	46.8	48.1	50.9	54.6	58.0	59.9	59.0	54.9	51.1	47.9	(25)	
		MCWB	45.9	44.1	44.0	45.3	47.7	52.4	56.0	57.4	56.3	51.9	48.8	45.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	49.6	49.6	50.5	52.8	57.8	59.4	61.6	60.2	58.0	53.1	50.9	(27)	
		MCDB	52.9	50.5	51.9	53.6	56.2	61.6	60.5	63.5	62.5	58.6	53.6	52.2	(28)	
	2%	WB	49.4	47.9	47.8	48.4	51.1	56.1	58.4	60.0	58.9	55.8	51.8	48.7	(29)	
		MCDB	50.6	49.3	49.8	50.6	53.2	58.6	59.5	62.0	60.3	57.0	52.9	50.2	(30)	
	5%	WB	48.2	46.3	46.3	46.9	50.2	54.5	57.6	59.0	58.0	54.3	50.7	47.5	(31)	
		MCDB	49.4	48.0	48.4	48.9	51.9	56.2	58.8	60.6	59.4	55.7	52.2	49.2	(32)	
	10%	WB	46.9	44.8	45.1	45.9	49.4	53.5	56.9	58.1	57.2	53.2	49.5	46.4	(33)	
		MCDB	48.2	46.6	47.1	48.0	51.1	54.8	58.2	59.6	58.6	54.6	51.2	48.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	5.3	5.6	5.7	4.9	4.1	3.7	4.1	4.6	4.9	5.4	5.3	(35)	
		MCDBR	5.9	6.0	7.2	8.9	8.1	6.4	5.2	5.7	5.7	5.5	5.8	5.9	(36)	
	5% WB	MCWBR	4.9	5.1	5.3	4.8	4.6	4.2	3.7	4.2	4.4	5.0	5.1	5.3	(37)	
		MCWBR	5.5	5.3	6.7	6.1	5.5	6.0	4.8	5.3	4.6	4.5	5.1	5.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.322	0.325	0.353	0.390	0.390	0.378	0.381	0.380	0.371	0.355	0.325	0.310	(40)	
		taud	2.344	2.457	2.383	2.270	2.335	2.422	2.463	2.474	2.454	2.387	2.335	2.309	(41)	
	Ebn at Noon	Ebn at Noon	205	249	264	266	272	277	274	268	255	231	200	183	(42)	
		Edh at Noon	19	23	30	38	37	35	33	31	28	24	19	16	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	180	439	783	1221	1471	1538	1428	1210	881	493	240	145	(44)	
	RadStd	RadStd	19	68	87	54	97	116	119	98	79	53	24	19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) +0.83	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page