

CLINTON, BC, Canada

WMO: 714740

Lat: 51.1447N

Lon: 121.5049W

Elev: 1057

StdP: 89.26

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-25.3	-21.4	-30.2	0.3	-24.0	-26.2	0.4	-19.2	6.9	-4.2	6.1	-3.5	1.1	350	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	29.3	14.6	27.1	13.9	25.1	13.3	15.5	26.4	14.6	25.0	13.8	23.3	2.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.9	9.8	16.2	10.7	9.1	15.5	9.7	8.5	15.0	46.9	26.4	44.3	25.1	41.9	23.4	18.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.5	4.9	DB	-30.1	32.3	4.0	1.6	-33.0	33.5	-35.3	34.4	-37.6	35.3	-40.5	36.4	(4)
(5)			WB	-30.1	17.0	4.1	1.0	-33.0	17.8	-35.4	18.4	-37.6	19.0	-40.6	19.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.3	-6.6	-5.0	-0.2	4.2	9.1	12.4	16.0	15.4	10.6	3.9	-2.3	-6.8	(6)	
	DBStd	9.32	6.89	5.61	4.78	3.48	3.86	3.32	3.49	3.44	3.98	3.81	5.40	6.03	(7)	
	HDD10.0	2631	516	419	317	177	65	12	2	2	39	191	371	521	(8)	
	HDD18.3	5163	774	652	576	424	288	181	91	102	232	446	620	779	(9)	
	CDD10.0	541	0	0	0	3	36	84	187	170	59	3	0	0	(10)	
	CDD18.3	32	0	0	0	0	0	3	17	11	1	0	0	0	(11)	
	CDH23.3	829	0	0	0	1	25	88	362	302	52	0	0	0	(12)	
	CDH26.7	221	0	0	0	0	2	19	108	83	8	0	0	0	(13)	
(14) Wind	WSAvg	2.1	1.9	2.0	2.4	2.4	2.2	2.1	2.1	2.0	2.0	2.2	2.1	1.9	(14)	
(15) Precipitation	PrecAvg	404	30	18	22	22	46	54	49	41	38	28	32	32	(15)	
	PrecMax	533	47	37	39	41	86	118	101	118	77	82	60	55	(16)	
	PrecMin	250	12	7	7	8	12	18	15	12	8	10	11	15	(17)	
	PrecStd	75	10	7	8	9	22	24	29	26	20	14	12	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.7	7.3	13.5	20.3	26.1	29.2	32.2	31.4	27.8	17.9	10.2	4.9	(19)	
		MCWB	2.5	2.8	5.6	9.5	12.0	14.1	15.8	15.1	13.8	10.1	6.1	2.3	(20)	
	2%	DB	3.5	4.8	10.0	16.6	23.0	26.0	29.7	29.0	24.6	14.1	7.4	2.7	(21)	
		MCWB	1.4	1.1	4.1	7.7	11.1	13.3	15.0	14.4	12.8	8.0	4.5	0.8	(22)	
	5%	DB	1.7	3.2	7.9	13.7	20.2	22.9	27.3	26.9	21.7	11.9	5.4	1.2	(23)	
		MCWB	0.2	0.4	3.0	6.1	10.0	12.0	14.2	14.0	11.9	6.9	3.2	-0.3	(24)	
	10%	DB	0.2	1.7	6.1	11.3	17.6	20.4	25.0	24.4	18.7	9.8	3.8	-0.2	(25)	
		MCWB	-0.7	-0.5	1.7	4.9	9.2	11.2	13.6	13.3	10.8	5.8	2.1	-1.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	3.4	6.2	10.0	13.3	15.2	16.9	16.5	14.7	10.7	6.7	2.7	(27)	
		MCDB	4.7	6.8	12.3	18.7	23.2	25.8	28.8	27.4	24.3	16.4	9.0	3.8	(28)	
	2%	WB	1.6	1.7	4.5	8.4	11.8	13.9	15.8	15.3	13.5	9.1	5.1	1.1	(29)	
		MCDB	3.1	4.0	9.1	15.5	20.6	23.4	26.7	26.5	22.7	13.1	6.8	2.4	(30)	
	5%	WB	0.3	0.7	3.4	6.7	10.7	12.8	14.9	14.4	12.4	7.5	3.6	-0.1	(31)	
		MCDB	1.4	2.7	7.3	12.9	18.8	21.2	25.4	25.0	20.5	11.1	5.1	1.1	(32)	
	10%	WB	-0.6	-0.3	2.2	5.3	9.7	11.9	14.1	13.6	11.2	6.1	2.3	-1.3	(33)	
		MCDB	0.2	1.5	5.7	10.5	16.5	19.0	23.4	23.2	18.1	9.4	3.5	-0.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	8.6	10.1	12.1	13.2	13.1	14.4	15.0	13.4	9.7	6.2	5.5	(35)	
		MCDBR	6.8	9.2	11.5	16.0	18.2	18.1	18.8	19.5	18.5	12.9	7.6	6.3	(36)	
	5% WB	MCWBR	5.2	6.3	7.0	8.9	8.7	8.3	7.9	8.5	8.9	7.9	5.5	5.0	(37)	
		MCWBR	6.1	8.2	11.0	14.9	16.0	15.6	16.8	17.6	16.7	11.7	7.0	5.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.264	0.269	0.295	0.322	0.339	0.339	0.323	0.326	0.304	0.298	0.273	0.270	(40)	
		taud	2.411	2.462	2.484	2.433	2.427	2.453	2.531	2.518	2.577	2.571	2.535	2.341	(41)	
	Ebn at Noon		781	883	916	921	916	916	927	908	897	838	774	697	(42)	
		Edh at Noon	58	73	86	102	108	106	97	93	79	66	52	54	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.95	1.92	3.23	4.58	5.38	5.79	6.27	5.36	3.74	2.16	1.02	0.72	(44)	
	RadStd		0.08	0.16	0.20	0.36	0.41	0.52	0.52	0.30	0.33	0.21	0.10	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page