

ROSE SPIT, BC, Canada

WMO: 714770

Lat: 54.159N

Lon: 131.661W

Elev: 22

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.6	27.8	11.2	9.8	27.4	15.6	12.1	30.8	51.0	42.5	47.3	43.7	20.7	50	0.880

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	62.9	59.4	61.3	58.5	60.1	57.8	60.2	61.7	59.2	60.6	58.3	59.6	10.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.4	75.8	60.8	58.4	73.0	59.8	57.5	70.6	59.0	26.5	61.9	25.8	60.8	25.3	59.8	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
46.1	41.1	36.1	21.1	66.3	4.8	3.0	17.6	68.4	14.8	70.2	12.1	71.8	8.6	74.0		
			19.1	62.4	5.0	3.0	15.5	64.6	12.6	66.3	9.7	68.0	6.1	70.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	38.9	39.2	39.9	43.9	48.4	52.5	55.8	57.0	54.3	48.8	42.5	39.0	
	DBStd	7.65	5.39	4.57	4.14	3.10	3.06	2.57	2.35	2.14	2.63	3.30	4.67	4.74	
	HDD50	1848	345	304	314	185	66	5	0	0	3	60	226	340	
	HDD65	6671	810	723	779	634	515	375	284	249	320	502	675	805	
	CDD50	654	0	1	0	1	17	81	181	216	133	23	1	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	17.1	19.9	18.8	18.2	16.9	16.0	15.5	14.5	13.9	14.8	17.6	19.1	20.0	
Precipitation	PrecAvg	100.0	11.6	8.6	8.4	6.7	4.6	3.8	3.7	5.5	8.0	13.0	13.0	13.0	
	PrecMax	130.1	18.6	15.0	13.4	11.0	11.0	6.9	7.4	11.1	16.9	20.0	24.9	29.2	
	PrecMin	72.4	5.8	3.8	3.5	3.6	1.1	2.1	1.4	2.2	3.5	5.7	7.5	6.8	
	PrecStd	14.2	2.8	2.9	2.7	1.8	2.2	1.1	1.4	2.3	2.9	3.5	3.3	4.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	53.3	50.3	54.6	58.8	63.8	64.4	65.2	62.8	57.2	52.6	49.6	
		MCWB	47.6	51.8	47.9	49.6	54.3	58.6	60.4	61.0	59.8	54.5	51.3	46.6	
	2%	DB	47.4	48.1	47.9	51.3	55.8	59.9	62.1	63.1	60.6	55.5	51.1	47.6	
		MCWB	46.0	46.6	45.7	47.5	52.2	56.3	58.8	59.8	58.1	53.1	50.0	45.9	
	5%	DB	45.9	46.1	46.5	49.5	54.1	57.8	60.8	61.7	59.2	54.3	49.8	46.3	
		MCWB	44.6	44.4	44.4	46.5	51.0	54.9	58.0	59.0	57.2	52.3	48.5	45.1	
	10%	DB	44.9	44.7	45.2	48.3	52.7	56.4	59.5	60.4	58.1	53.3	48.5	45.1	
		MCWB	43.8	43.3	43.3	45.6	50.1	53.9	57.3	58.2	56.4	51.5	47.0	43.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.2	53.2	48.7	50.3	54.9	58.9	61.2	61.9	60.9	56.0	51.8	48.2
			MCDB	50.3	54.6	49.4	51.4	56.3	62.2	63.5	63.6	62.1	56.7	52.0	48.9
2%		WB	46.7	47.3	46.1	48.0	52.7	56.9	59.7	60.3	59.1	54.0	50.1	46.3	
		MCDB	47.4	48.1	47.2	49.4	54.4	58.9	61.4	61.7	60.1	54.7	50.5	47.1	
5%		WB	45.2	44.8	44.7	46.8	51.4	55.5	58.6	59.4	58.0	52.9	48.2	45.2	
		MCDB	45.9	45.6	45.6	48.1	53.2	57.0	60.1	60.8	58.9	53.8	49.0	46.1	
10%		WB	44.2	43.6	43.5	45.8	50.3	54.4	57.6	58.5	57.0	51.8	46.8	44.0	
		MCDB	45.0	44.5	44.5	47.2	51.9	55.8	59.1	59.9	58.0	52.9	47.8	44.9	
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.9	6.8	7.1	6.7	6.5	5.9	6.3	6.3	6.5	6.2	5.5	
		MCDBR	5.3	6.8	7.4	8.5	8.4	8.7	7.6	7.9	7.2	6.9	6.0	5.5	
		MCWBR	5.2	6.8	6.4	6.7	6.9	6.8	5.7	6.3	6.0	6.2	6.1	5.7	
	5% WB	MCDBR	5.6	6.8	7.0	7.4	7.8	8.1	7.5	7.6	6.6	6.6	6.2	5.9	
		MCWBR	5.6	6.6	6.3	6.3	6.6	6.4	5.8	6.0	5.7	6.2	6.0	5.9	
Clear-Sky Solar Irradiance	taub	0.310	0.319	0.341	0.375	0.373	0.371	0.371	0.368	0.360	0.343	0.315	0.302		
	taud	2.390	2.485	2.444	2.343	2.412	2.452	2.496	2.519	2.508	2.451	2.358	2.313		
	Ebn at Noon	207	249	267	270	277	279	276	271	258	234	200	180		
	Edh at Noon	17	22	28	35	34	33	31	29	26	22	17	15		
All-Sky Solar Radiation	RadAvg	165	424	765	1219	1547	1629	1483	1277	854	471	220	133		
	RadStd	21	72	92	71	135	122	160	111	93	63	28	22		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page