

SARTINE ISLAND, BC, Canada

WMO: 714780

Lat: 50.8194N

Lon: 128.9061W

Elev: 364

StdP: 14.50

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.5	32.7	18.3	14.0	32.4	22.4	17.0	35.6	69.9	44.8	64.5	44.4	24.1	10	0.989

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.3	61.2	58.5	59.9	57.8	58.9	57.1	59.4	60.4	58.5	59.4	57.6	58.6	13.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.0	75.4	59.8	58.0	72.8	58.9	57.1	70.5	58.2	26.1	60.4	25.5	59.7	25.0	58.7	64.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 64.2	56.5	49.2	DB	26.4	67.2	5.2	5.1	22.7	70.9	19.7	73.8	16.8	76.7	13.1	80.4	(4)
(5)			WB	22.6	61.3	6.0	1.9	18.3	62.7	14.8	63.8	11.5	64.9	7.1	66.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.9	42.8	41.7	41.9	44.4	47.8	51.4	54.9	56.4	54.6	50.1	45.7	42.7	(6)
(7)		DBStd	6.15	4.39	3.94	3.54	2.94	2.79	2.65	2.31	2.05	2.32	2.71	4.04	4.01	(7)
(8)		HDD50	1359	225	233	251	169	78	13	0	0	1	30	134	225	(8)
(9)		HDD65	6237	690	653	715	617	533	408	313	265	313	461	579	690	(9)
(10)		CDD50	597	0	0	1	2	10	55	152	200	138	34	5	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	1	0	0	0	0	0	0	0	1	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	21.5	27.6	24.2	24.6	20.9	17.6	16.2	16.1	17.9	23.5	26.3	27.1	(14)	
(15)	Precipitation	PrecAvg	110.1	12.8	9.8	10.7	7.8	5.5	4.4	3.3	4.9	7.0	13.4	15.9	15.2	(15)
(16)		PrecMax	134.7	20.4	20.6	18.5	14.6	8.0	7.2	8.3	10.7	13.7	20.8	23.3	26.9	(16)
(17)		PrecMin	85.2	6.3	3.8	4.9	3.3	2.1	2.4	0.9	1.2	1.9	6.1	10.0	8.2	(17)
(18)		PrecStd	11.1	3.0	3.2	2.8	2.2	1.4	1.2	1.7	2.4	2.8	4.3	3.8	3.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	51.2	53.4	54.7	56.4	62.4	62.4	63.8	62.0	58.5	54.9	52.1	(19)
(20)			MCWB	48.7	46.9	46.8	50.4	51.2	57.0	59.2	59.5	58.4	55.4	54.4	46.4	(20)
(21)		2%	DB	49.7	49.0	48.7	50.6	53.7	57.4	60.2	61.5	59.8	56.4	53.0	50.1	(21)
(22)			MCWB	48.2	46.8	45.9	47.7	50.6	55.1	57.7	59.0	57.8	54.2	51.8	47.7	(22)
(23)		5%	DB	48.5	47.5	47.3	49.0	52.3	55.7	59.0	60.2	58.7	55.0	51.8	48.8	(23)
(24)			MCWB	47.0	45.6	45.2	46.6	49.9	53.7	57.1	58.2	57.0	53.1	50.7	46.9	(24)
(25)		10%	DB	47.5	46.3	46.1	47.8	51.2	54.5	58.0	59.3	57.6	53.9	50.7	47.6	(25)
(26)			MCWB	46.1	44.5	44.4	45.6	49.2	52.8	56.4	57.5	56.2	52.2	49.4	46.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	49.4	47.8	50.4	52.8	57.4	60.1	61.2	60.2	56.6	53.7	49.4	(27)
(28)			MCD B	50.3	49.9	49.9	52.6	54.3	59.6	61.7	62.0	61.3	57.1	53.8	49.6	(28)
(29)		2%	WB	48.4	47.6	46.6	48.5	51.5	55.6	58.7	59.7	58.7	54.6	51.9	48.2	(29)
(30)			MCD B	49.0	48.4	48.6	49.9	52.8	57.3	59.8	60.7	59.2	55.1	52.0	48.6	(30)
(31)		5%	WB	47.4	46.5	45.7	47.4	50.5	54.4	57.8	58.8	57.5	53.1	50.8	47.1	(31)
(32)			MCD B	47.9	47.4	47.3	48.5	51.8	55.7	58.9	59.8	58.1	53.6	51.2	47.9	(32)
(33)		10%	WB	46.5	45.0	44.8	46.3	49.8	53.4	57.0	58.0	56.5	52.2	49.4	46.2	(33)
(34)			MCD B	46.9	45.9	45.8	47.5	51.1	54.5	58.0	59.0	57.1	52.9	50.1	47.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	4.6	5.1	5.0	4.6	4.5	4.2	4.3	4.4	4.2	4.7	4.7	(35)
(36)			MCDBR	5.2	5.5	5.8	6.4	6.1	6.3	5.5	5.7	5.7	5.0	4.9	5.1	(36)
(37)			MCWBR	3.9	4.4	4.4	4.8	4.5	4.4	4.1	4.4	4.9	5.0	5.2	5.0	(37)
(38)		5% WB	MCDBR	4.2	4.6	5.2	5.6	5.6	5.4	5.4	5.5	5.4	4.6	4.7	4.6	(38)
(39)			MCWBR	4.4	4.7	4.4	4.9	4.5	4.3	4.2	4.4	4.9	5.0	5.4	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.317	0.324	0.347	0.377	0.379	0.365	0.360	0.364	0.361	0.343	0.325	0.311	(40)
(41)		taud		2.450	2.503	2.450	2.350	2.391	2.471	2.533	2.524	2.507	2.491	2.414	2.391	(41)
(42)		Ebn at Noon		227	259	272	274	278	283	283	276	264	247	219	207	(42)
(43)		Edh at Noon		19	23	29	36	36	33	31	30	27	23	19	17	(43)
(44)	All-Sky Solar Radiation	RadAvg		227	500	825	1291	1589	1697	1639	1426	1045	582	284	189	(44)
(45)		RadStd		27	75	101	81	132	162	163	144	86	68	37	25	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	+0.81	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page