

SARTINE ISLAND, BC, Canada

WMO: 714780

Lat: 50.8194N

Lon: 128.9061W

Elev: 111

StdP: 100.00

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.4	0.4	-7.6	2.0	0.2	-5.4	2.4	2.0	31.3	7.1	28.8	6.9	10.8	10	0.989

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	16.2	14.7	15.5	14.3	15.0	14.0	15.2	15.8	14.7	15.2	14.2	14.8	6.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.8	15.4	14.4	10.4	14.9	14.0	10.1	14.5	42.9	15.8	41.4	15.4	40.2	14.8	17.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.7	25.3	22.0	DB	-3.1	19.6	2.9	2.8	-5.2	21.6	-6.8	23.2	-8.4	24.8	-10.5	26.9	(4)
(5)			WB	-5.2	16.3	3.3	1.1	-7.6	17.1	-9.6	17.7	-11.4	18.3	-13.8	19.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	6.0	5.4	5.5	6.9	8.8	10.8	12.7	13.6	12.5	10.1	7.6	6.0	(6)	
	DBStd	3.41	2.44	2.19	1.97	1.63	1.55	1.47	1.29	1.14	1.29	1.50	2.24	2.23	(7)	
	HDD10.0	755	125	129	139	94	43	7	0	0	1	17	74	125	(8)	
	HDD18.3	3465	383	363	397	343	296	227	174	147	174	256	322	383	(9)	
	CDD10.0	332	0	0	1	1	6	31	84	111	77	19	3	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	0	0	1	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	9.6	12.3	10.8	11.0	9.4	7.9	7.2	7.2	7.2	8.0	10.5	11.7	12.1	(14)	
(15) Precipitation	PrecAvg	2797	325	249	271	198	140	112	83	124	179	340	403	387	(15)	
	PrecMax	3421	518	522	469	372	204	182	210	271	349	528	593	682	(16)	
	PrecMin	2165	159	96	124	83	53	61	22	31	47	155	255	208	(17)	
	PrecStd	283	76	81	70	57	36	31	44	60	70	109	97	98	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	10.7	11.9	12.6	13.5	16.9	16.9	17.7	16.7	14.7	12.7	11.2	(19)	
		MCWB	9.3	8.3	8.2	10.2	10.7	13.9	15.1	15.3	14.7	13.0	12.4	8.0	(20)	
	2%	DB	9.8	9.4	9.3	10.3	12.0	14.1	15.7	16.4	15.4	13.6	11.7	10.1	(21)	
		MCWB	9.0	8.2	7.7	8.7	10.4	12.8	14.3	15.0	14.4	12.3	11.0	8.7	(22)	
	5%	DB	9.2	8.6	8.5	9.4	11.3	13.2	15.0	15.7	14.8	12.8	11.0	9.3	(23)	
		MCWB	8.3	7.5	7.3	8.1	9.9	12.1	13.9	14.6	13.9	11.7	10.4	8.3	(24)	
	10%	DB	8.6	8.0	7.8	8.8	10.7	12.5	14.4	15.1	14.2	12.2	10.4	8.7	(25)	
		MCWB	7.9	6.9	6.9	7.6	9.6	11.5	13.5	14.2	13.4	11.2	9.7	7.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	9.7	8.8	10.2	11.5	14.1	15.6	16.2	15.7	13.7	12.1	9.6	(27)	
		MCDB	10.1	10.0	9.9	11.4	12.4	15.3	16.5	16.7	16.3	13.9	12.1	9.8	(28)	
	2%	WB	9.1	8.7	8.1	9.2	10.8	13.1	14.8	15.4	14.9	12.6	11.0	9.0	(29)	
		MCDB	9.5	9.1	9.2	9.9	11.6	14.1	15.4	15.9	15.1	12.8	11.1	9.2	(30)	
	5%	WB	8.5	8.0	7.6	8.5	10.3	12.4	14.3	14.9	14.2	11.7	10.4	8.4	(31)	
		MCDB	8.8	8.6	8.5	9.2	11.0	13.2	14.9	15.5	14.5	12.0	10.6	8.8	(32)	
	10%	WB	8.0	7.2	7.1	8.0	9.9	11.9	13.9	14.4	13.6	11.2	9.7	7.9	(33)	
		MCDB	8.3	7.7	7.7	8.6	10.6	12.5	14.5	15.0	13.9	11.6	10.0	8.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.4	2.6	2.8	2.8	2.6	2.5	2.3	2.4	2.4	2.4	2.6	2.6	(35)	
		MCDBR	2.9	3.0	3.2	3.6	3.4	3.5	3.1	3.2	3.2	2.8	2.7	2.8	(36)	
	5% WB	MCWBR	2.2	2.5	2.4	2.7	2.5	2.4	2.3	2.5	2.7	2.8	2.9	2.8	(37)	
		MCWBR	2.3	2.5	2.9	3.1	3.1	3.0	3.0	3.0	3.0	2.6	2.6	2.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.317	0.324	0.347	0.377	0.379	0.365	0.360	0.364	0.361	0.343	0.325	0.311	(40)	
		taud	2.450	2.503	2.450	2.350	2.391	2.471	2.533	2.524	2.507	2.491	2.414	2.391	(41)	
	Ebn at Noon		715	817	857	864	877	891	891	870	833	778	689	652	(42)	
		Edh at Noon	60	73	91	112	113	105	97	94	86	73	61	55	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.72	1.58	2.60	4.07	5.01	5.35	5.17	4.50	3.29	1.84	0.90	0.60	(44)	
	RadStd		0.08	0.24	0.32	0.26	0.42	0.51	0.52	0.45	0.27	0.21	0.12	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page