

EVANSBURG2 AGCM, AB, Canada

WMO: 714810

Lat: 53.573N

Lon: 115.124W

Elev: 2687

StdP: 13.32

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-23.9	-17.7	-29.7	1.1	-23.6	-23.7	1.6	-17.3	19.6	34.2	17.4	25.7	2.4	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	78.7	61.0	75.9	60.4	73.3	58.9	64.3	74.3	62.1	72.6	60.6	70.8	6.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.2	86.0	71.1	58.0	79.3	67.1	56.2	74.3	65.0	30.9	74.2	29.3	72.6	28.1	71.0	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.3	12.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	-32.3	67.8	6.0	3.1	-36.6	70.0	-40.1	71.9	-43.4	73.6	-47.8	75.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.6	15.9	13.1	24.6	37.4	49.4	56.2	60.1	58.2	49.6	38.3	23.6	10.9
	DBStd	20.51	15.74	15.69	13.98	8.68	7.50	5.34	4.48	5.30	7.71	7.80	12.25	14.12
	HDD50	5859	1059	1033	789	384	103	10	0	5	98	372	793	1213
	HDD65	10398	1524	1453	1254	827	484	269	160	217	461	828	1243	1678
	CDD50	953	0	0	0	7	84	195	314	258	87	8	0	0
	CDD65	19	0	0	0	0	0	4	9	5	1	0	0	0
	CDH74	457	0	0	0	5	54	74	191	94	38	1	0	0
	CDH80	41	0	0	0	0	5	6	20	9	1	0	0	0
	WSAvg	5.2	5.0	4.9	5.1	6.5	6.5	6.1	5.0	4.5	4.5	5.1	4.0	4.8
	PrecAvg	21.6	1.0	0.7	0.7	1.3	2.5	3.7	4.2	2.8	1.7	1.1	0.9	0.6
(15) Precipitation	PrecMax	24.1	3.1	1.5	1.7	2.8	4.0	5.9	9.8	5.1	3.7	2.8	2.4	1.4
	PrecMin	17.6	0.1	0.1	0.1	0.3	1.1	1.1	1.8	1.1	0.4	0.3	0.2	0.2
	PrecStd	1.9	0.8	0.4	0.4	0.6	0.7	1.3	1.8	0.9	0.9	0.7	0.7	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.3	45.5	54.6	72.2	80.0	80.0	82.7	80.1	78.6	67.5	52.2	44.5
		MCWB	37.1	36.3	42.0	50.9	55.0	60.6	65.2	63.3	60.3	52.1	43.3	36.8
	2%	DB	44.4	40.8	50.1	62.8	74.2	76.0	78.7	76.4	74.2	60.4	46.0	38.8
		MCWB	36.8	34.4	39.3	46.5	53.7	58.6	63.3	62.5	58.0	48.3	38.8	32.6
	5%	DB	41.2	37.8	45.4	56.8	69.9	72.1	75.7	73.7	69.3	55.8	42.0	35.3
		MCWB	34.7	32.2	36.5	42.7	51.6	57.0	62.0	61.2	55.8	45.2	36.4	30.2
	10%	DB	37.2	34.9	41.7	52.2	65.4	68.7	72.8	70.9	64.5	52.1	38.5	31.2
		MCWB	32.4	29.8	34.6	40.5	49.6	55.8	60.3	59.6	53.7	42.9	33.9	27.6
	0.4%	WB	38.7	37.6	42.9	51.5	57.3	62.8	68.2	66.5	61.6	52.7	43.9	37.0
		MCDB	45.1	43.9	53.0	72.6	76.2	75.1	79.3	77.4	76.7	65.5	50.5	43.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.8	35.1	39.7	46.9	54.8	60.7	65.2	63.9	59.0	48.9	39.6	33.4
		MCDB	43.8	40.2	48.8	61.9	69.9	72.3	75.4	72.9	72.4	59.0	44.4	38.1
	5%	WB	35.0	32.5	37.2	43.6	53.0	58.7	62.8	62.0	56.6	45.9	36.9	30.5
		MCDB	40.8	37.5	44.6	54.5	67.4	69.1	73.8	71.3	67.2	54.6	41.5	35.0
	10%	WB	32.7	30.0	34.6	41.3	50.8	57.0	61.0	60.4	54.5	43.6	34.4	27.5
		MCDB	37.1	34.9	40.9	50.9	63.4	66.9	71.1	69.8	63.4	50.8	38.1	31.0
(35) Mean Daily Temperature Range	5% DB	MDBR	16.1	18.0	19.1	20.3	23.0	20.1	21.1	21.1	20.6	16.8	13.5	15.6
		MCDBR	16.0	17.3	22.9	30.8	33.9	27.6	28.5	26.5	30.4	24.2	19.0	18.8
		MCWBR	11.7	12.4	14.0	16.1	15.9	12.7	14.5	13.9	15.7	13.9	13.6	14.5
	5% WB	MCDBR	15.2	16.9	21.8	28.3	30.2	22.4	26.3	24.5	27.9	22.6	18.0	18.9
		MCWBR	11.4	12.8	13.7	15.3	14.8	11.7	14.4	13.8	14.9	13.8	13.6	15.3
(40) Clear-Sky Solar Irradiance	taub		0.243	0.256	0.286	0.329	0.343	0.353	0.352	0.356	0.313	0.281	0.253	0.235
	taud		2.390	2.436	2.445	2.393	2.397	2.384	2.440	2.382	2.509	2.579	2.488	2.352
	Ebn at Noon		243	277	289	287	287	284	282	274	276	265	240	222
	Edh at Noon		16	22	27	33	35	36	33	33	26	19	15	14
(44) All-Sky Solar Radiation	RadAvg		300	625	1090	1469	1765	1880	1914	1584	1099	629	312	217
	RadStd		23	48	70	134	129	127	117	108	113	67	29	19

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page