

EVANSBURG2 AGCM, AB, Canada

WMO: 714810

Lat: 53.573N

Lon: 115.124W

Elev: 819

StdP: 91.87

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -31.1	(c) -27.6	(d) -34.3	(e) 0.2	(f) -30.9	(g) -30.9	(h) 0.2	(i) -27.4	(j) 8.8	(k) 1.2	(l) 7.8	(m) -3.5	(n) 1.1	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	25.9	16.1	24.4	15.8	23.0	14.9	17.9	23.5	16.7	22.6	15.9	21.5	2.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	12.3	21.7	14.4	11.3	19.5	13.4	10.6	18.4	53.9	23.4	50.2	22.6	47.4	21.7	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.1	6.8	5.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-35.7	19.9	3.3	1.7	-38.1	21.1	-40.0	22.1	-41.9	23.1	-44.3	24.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-9.0	-10.5	-4.1	3.0	9.7	13.4	15.6	14.5	9.8	3.5	-4.7	-11.7		
	DBStd	11.40	8.74	8.72	7.77	4.82	4.17	2.97	2.49	2.94	4.28	4.34	6.81	7.84		
	HDD10.0	3255	588	574	438	213	57	6	0	3	54	207	441	674		
	HDD18.3	5777	847	807	697	459	269	149	89	121	256	460	691	932		
	CDD10.0	529	0	0	0	4	47	108	174	143	48	4	0	0		
	CDD18.3	11	0	0	0	0	0	2	5	3	1	0	0	0		
	CDH23.3	254	0	0	0	3	30	41	106	52	21	1	0	0		
	CDH26.7	23	0	0	0	0	3	3	11	5	1	0	0	0		
(14) Wind	WSAvg	2.3	2.2	2.2	2.3	2.9	2.9	2.7	2.3	2.0	2.0	2.3	1.8	2.2		
(15) Precipitation	PrecAvg	549	26	19	19	32	63	95	106	70	42	28	24	15		
	PrecMax	612	78	39	44	70	102	151	249	129	95	71	61	35		
	PrecMin	448	2	3	3	7	28	28	45	28	10	7	6	4		
	PrecStd	49	20	9	10	16	19	33	46	23	24	18	18	9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	7.5	12.6	22.3	26.6	26.6	28.2	26.7	25.9	19.7	11.2	7.0		
		MCWB	2.8	2.4	5.6	10.5	12.8	15.9	18.5	17.4	15.7	11.2	6.3	2.7		
	2%	DB	6.9	4.9	10.1	17.1	23.4	24.5	25.9	24.6	23.4	15.8	7.8	3.8		
		MCWB	2.7	1.3	4.1	8.0	12.0	14.8	17.4	16.9	14.5	9.1	3.8	0.3		
	5%	DB	5.1	3.2	7.4	13.8	21.1	22.3	24.3	23.2	20.7	13.2	5.6	1.8		
		MCWB	1.5	0.1	2.5	5.9	10.9	13.9	16.6	16.2	13.2	7.3	2.4	-1.0		
	10%	DB	2.9	1.6	5.4	11.2	18.6	20.4	22.7	21.6	18.1	11.2	3.6	-0.5		
		MCWB	0.2	-1.2	1.4	4.7	9.8	13.2	15.7	15.3	12.0	6.0	1.1	-2.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	3.1	6.1	10.8	14.0	17.1	20.1	19.2	16.5	11.5	6.6	2.8		
		MCDB	7.3	6.6	11.7	22.6	24.5	23.9	26.3	25.2	24.8	18.6	10.3	6.3		
	2%	WB	2.7	1.7	4.3	8.3	12.7	15.9	18.4	17.7	15.0	9.4	4.2	0.8		
		MCDB	6.5	4.6	9.3	16.6	21.1	22.4	24.1	22.7	22.4	15.0	6.9	3.4		
	5%	WB	1.7	0.3	2.9	6.5	11.6	14.8	17.1	16.7	13.7	7.7	2.7	-0.8		
		MCDB	4.9	3.1	7.0	12.5	19.6	20.6	23.2	21.9	19.6	12.5	5.3	1.7		
	10%	WB	0.4	-1.1	1.5	5.2	10.4	13.9	16.1	15.8	12.5	6.4	1.4	-2.5		
		MCDB	2.8	1.6	5.0	10.5	17.5	19.4	21.7	21.0	17.4	10.4	3.4	-0.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	10.0	10.6	11.3	12.8	11.2	11.7	11.7	11.5	9.3	7.5	8.7		
		MCDBR	8.9	9.6	12.7	17.1	18.9	15.3	15.8	14.7	16.9	13.5	10.6	10.5		
	5% WB	MCWBR	6.5	6.9	7.8	9.0	8.8	7.0	8.1	7.7	8.7	7.7	7.5	8.1		
		MCWBR	8.5	9.4	12.1	15.7	16.8	12.5	14.6	13.6	15.5	12.5	10.0	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.243	0.256	0.286	0.329	0.343	0.353	0.352	0.356	0.313	0.281	0.253	0.235		
	taud		2.390	2.436	2.445	2.393	2.397	2.384	2.440	2.382	2.509	2.579	2.488	2.352		
	Ebn at Noon		767	874	912	904	905	896	890	864	870	836	756	700		
	Edh at Noon		52	69	86	104	110	113	105	105	81	61	48	44		
(44) All-Sky Solar Radiation	RadAvg		0.95	1.97	3.44	4.63	5.56	5.93	6.04	4.99	3.46	1.98	0.98	0.68		
	RadStd		0.07	0.15	0.22	0.42	0.41	0.40	0.37	0.34	0.35	0.21	0.09	0.06		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page