

FORT GOOD HOPE, NT, Canada

WMO: 714910

Lat: 66.242N

Lon: 128.644W

Elev: 82

StdP: 100.35

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.9	-39.1	-45.7	0.0	-41.0	-43.1	0.1	-38.3	7.9	-15.0	6.5	-15.0	0.4	90	0.717

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	28.5	16.9	26.3	16.1	24.4	15.2	18.0	26.0	17.0	24.2	16.1	22.7	3.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	10.9	19.9	14.2	10.2	19.0	13.2	9.5	18.3	51.1	26.0	48.1	24.5	45.5	22.7	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	6.0	5.2	-43.3	31.3	2.5	2.0	-45.2	32.8	-46.6	33.9	-48.0	35.0	-49.9	36.5		
			-42.7	19.7	2.3	1.1	-44.4	20.5	-45.7	21.2	-47.0	21.8	-48.7	22.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.0	-25.5	-23.1	-18.5	-6.0	6.0	15.2	17.1	13.3	6.3	-4.1	-17.7	-23.8
	DBStd	16.81	8.48	7.66	7.24	6.69	5.74	4.23	3.73	4.19	4.33	5.40	6.68	7.51
	HDD10.0	6006	1101	928	883	481	149	6	2	16	124	436	832	1049
	HDD18.3	8561	1359	1162	1141	731	383	111	67	165	359	694	1082	1307
	CDD10.0	542	0	0	0	0	25	163	223	117	14	0	0	0
	CDD18.3	55	0	0	0	0	0	18	29	8	0	0	0	0
	CDH23.3	648	0	0	0	0	17	218	318	95	1	0	0	0
	CDH26.7	159	0	0	0	0	2	57	81	19	0	0	0	0
Wind	WSAvg	2.0	1.4	1.5	2.0	2.3	2.6	2.6	2.4	2.3	2.2	1.9	1.5	1.3
Precipitation	PrecAvg	331	19	19	15	12	19	39	50	51	40	27	22	17
	PrecMax	449	43	51	32	35	53	60	104	89	70	46	45	37
	PrecMin	234	4	6	2	1	3	11	21	22	25	13	10	4
	PrecStd	44	10	10	8	8	10	14	20	17	11	8	9	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.9	-2.3	4.7	14.8	25.6	31.2	32.0	29.1	21.3	11.4	0.3	-3.0
		MCWB	-2.3	-3.6	0.8	7.2	14.0	17.6	18.5	17.5	12.9	7.1	-0.2	-4.0
	2%	DB	-7.0	-6.5	-1.0	10.3	21.9	28.2	28.9	26.0	18.4	6.9	-3.3	-7.7
		MCWB	-7.6	-7.3	-3.2	4.9	12.3	16.2	17.3	16.8	11.5	4.6	-3.8	-8.1
	5%	DB	-10.7	-9.8	-4.9	7.3	19.0	25.7	26.7	23.5	16.3	4.5	-6.1	-10.7
		MCWB	-11.2	-10.5	-6.5	2.9	10.7	15.1	16.4	15.5	10.4	3.0	-6.6	-11.1
	10%	DB	-14.2	-12.5	-8.1	4.5	15.9	23.6	24.8	20.9	13.7	2.6	-8.7	-13.4
		MCWB	-14.5	-13.0	-9.3	1.2	8.9	14.1	15.8	14.4	9.4	1.4	-9.2	-13.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.3	-3.3	2.0	6.7	14.4	18.7	19.5	19.1	13.8	7.7	0.0	-3.9
		MCDB	-0.7	-2.3	4.4	13.1	24.6	28.8	28.3	26.1	19.6	10.4	0.6	-2.9
	2%	WB	-7.8	-7.1	-2.6	4.7	12.5	17.2	18.2	17.5	12.1	4.9	-3.4	-8.0
		MCDB	-7.3	-6.3	-0.5	9.5	21.0	25.9	26.2	24.7	16.9	6.5	-3.0	-7.6
	5%	WB	-11.2	-10.2	-6.4	2.9	10.9	16.0	17.3	16.2	10.9	3.2	-6.3	-10.9
		MCDB	-10.8	-9.6	-4.8	6.7	18.4	23.9	24.4	22.4	15.0	4.5	-5.9	-10.6
	10%	WB	-14.5	-12.8	-9.2	1.2	9.3	14.8	16.6	15.0	9.7	1.6	-9.0	-13.6
		MCDB	-14.2	-12.2	-8.0	4.2	15.4	22.3	23.1	19.7	13.2	2.6	-8.6	-13.3
Mean Daily Temperature Range	5% DB	MDBR	7.2	8.5	11.9	13.3	11.8	11.5	11.1	10.3	9.0	6.5	7.1	7.1
		MCDBR	11.0	10.7	15.6	15.3	16.4	14.6	14.7	14.8	14.1	8.4	8.0	9.2
		MCWBR	10.4	10.0	13.2	10.7	8.6	5.8	5.8	6.5	7.8	6.0	7.7	8.7
	5% WB	MCDBR	10.9	10.6	15.0	14.6	15.8	12.8	12.7	12.9	12.6	7.6	7.9	9.1
		MCWBR	10.4	10.1	12.6	10.1	8.4	5.3	5.6	6.2	7.2	5.7	7.7	8.8
Clear-Sky Solar Irradiance	taub	0.152	0.224	0.254	0.306	0.337	0.345	0.366	0.342	0.299	0.251	0.159	0.156	
	taud	1.943	2.211	2.249	2.192	2.385	2.447	2.405	2.484	2.557	2.376	1.950	1.943	
	Ebn at Noon	324	675	827	853	864	865	829	818	785	636	280	48	
	Edh at Noon	15	47	77	107	99	96	98	82	60	41	14	3	
All-Sky Solar Radiation	RadAvg	0.10	0.74	2.51	4.75	5.69	6.03	5.08	3.68	2.13	0.77	0.17	0.01	
	RadStd	0.01	0.05	0.11	0.20	0.46	0.44	0.35	0.34	0.21	0.08	0.02	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.89	N/A	N/A	N/A	N/A	N/A	-323	-354	N/A	N/A
(47)	Regional (4 neighbors)	+0.70	+1.39	+1.33	N/A	N/A	N/A	-220	-203	N/A	N/A

Nomenclature: See separate page