

PARRSBORO, NS, Canada

WMO: 714930

Lat: 45.4135N

Lon: 64.3462W

Elev: 101

StdP: 14.64

Time Zone: -4.00 (NAA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.0	0.7	-11.2	3.0	-1.8	-6.9	3.8	3.8	27.9	23.2	23.1	26.8	3.5	290	0.575

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	78.0	67.4	75.5	65.9	73.2	64.8	69.9	74.9	68.2	73.0	66.5	71.0	6.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.1	103.7	72.7	66.3	97.3	71.0	64.7	91.8	69.3	34.0	75.0	32.6	73.3	31.2	71.1	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.6	17.3	14.5	DB	-12.6	83.5	4.0	1.9	-15.5	84.8	-17.8	85.9	-20.1	87.0	-23.0	88.4	(4)
(5)			WB	-13.0	73.7	3.9	1.7	-15.8	74.9	-18.1	75.9	-20.3	76.8	-23.1	78.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.1	21.6	21.9	28.8	39.4	49.0	56.7	63.5	63.1	57.1	47.8	38.4	28.4	(6)	
	DBStd	16.63	11.21	10.25	8.61	6.15	5.38	4.94	4.04	4.40	6.35	7.27	8.59	10.20	(7)	
	HDD50	3909	882	787	658	322	84	6	0	0	11	130	360	669	(8)	
	HDD65	8061	1347	1207	1123	767	495	251	75	88	244	533	797	1134	(9)	
	CDD50	1395	0	0	0	5	54	208	420	405	226	64	13	0	(10)	
	CDD65	70	0	0	0	0	0	3	30	28	8	1	0	0	(11)	
	CDH74	377	0	0	0	0	2	30	180	138	25	2	0	0	(12)	
	CDH80	19	0	0	0	0	0	2	8	8	1	0	0	0	(13)	
	WSAvg	6.3	7.0	7.2	7.7	7.3	6.7	6.0	4.6	4.6	5.2	6.1	6.8	7.0	(14)	
	PrecAvg	47.4	4.1	3.4	3.8	3.7	3.8	3.3	3.3	3.1	4.4	4.7	4.5	5.2	(15)	
(16) Precipitation	PrecMax	62.0	6.5	6.9	8.2	6.0	8.6	8.3	6.6	7.1	9.6	9.5	7.6	9.2	(16)	
	PrecMin	36.9	1.4	1.3	1.1	1.2	1.2	0.5	0.9	0.9	0.9	1.0	1.8	2.6	(17)	
	PrecStd	6.1	1.2	1.5	1.7	1.2	1.9	2.0	1.6	1.8	2.5	2.2	1.4	1.7	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	50.3	54.0	63.9	72.5	77.8	81.2	80.9	77.2	70.7	65.6	56.4	(19)	
		MCWB	55.1	48.1	47.8	53.6	60.1	65.0	69.2	69.5	68.0	63.4	61.5	53.8	(20)	
	2%	DB	46.6	43.1	48.0	59.3	67.2	73.3	78.4	77.6	73.1	65.6	59.1	51.6	(21)	
		MCWB	45.4	40.9	43.1	51.3	56.3	62.9	67.8	67.2	65.9	61.0	56.2	50.0	(22)	
	5%	DB	42.2	39.4	44.2	54.7	63.1	70.2	75.8	75.0	70.2	62.8	56.2	47.7	(23)	
		MCWB	40.5	37.0	39.7	47.6	53.3	60.4	66.2	65.8	63.7	59.2	53.8	46.1	(24)	
	10%	DB	37.4	36.3	40.9	51.3	59.8	67.3	73.4	72.8	67.9	60.0	52.5	43.3	(25)	
		MCWB	35.7	34.4	37.0	45.3	51.9	59.0	65.1	64.9	62.7	56.2	49.9	41.2	(26)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.5	47.7	49.1	58.5	62.8	67.9	72.5	72.3	70.2	65.6	61.7	54.5	(27)	
		MCDB	56.5	50.1	52.6	62.3	70.1	74.3	78.5	77.8	75.1	67.8	64.6	55.9	(28)	
	2%	WB	45.5	41.3	44.6	53.3	58.7	65.2	70.1	69.8	67.7	62.3	57.3	50.3	(29)	
		MCDB	46.2	42.4	46.5	55.9	63.3	70.7	75.2	74.7	71.0	64.4	58.9	51.5	(30)	
	5%	WB	40.6	37.6	40.7	49.6	55.8	62.7	68.2	68.1	65.9	59.8	54.2	46.4	(31)	
		MCDB	42.1	39.0	43.0	53.2	60.7	67.6	73.5	72.6	68.9	62.2	55.8	47.5	(32)	
	10%	WB	35.8	34.4	37.4	46.2	53.4	60.4	66.4	66.2	63.8	57.0	50.1	41.7	(33)	
		MCDB	37.1	35.7	40.3	49.9	57.9	65.1	71.3	70.7	67.1	59.3	52.3	43.1	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	18.2	17.4	16.9	17.8	18.8	18.9	19.5	19.3	18.9	17.4	15.5	15.1	(35)	
		MCDBR	22.8	17.9	20.3	24.9	24.9	24.6	23.5	22.8	20.1	18.5	18.4	19.1	(36)	
		MCWBR	22.6	15.9	15.7	17.1	14.9	14.5	14.1	13.5	13.6	14.5	16.7	19.0	(37)	
	5% WB	MCDBR	22.8	17.7	18.6	20.6	20.1	19.8	19.2	18.1	15.8	15.8	17.7	19.2	(38)	
		MCWBR	22.6	16.7	16.5	16.7	14.0	13.2	13.0	12.2	12.0	13.8	17.1	19.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.295	0.290	0.324	0.350	0.372	0.392	0.417	0.396	0.359	0.328	0.308	0.291	(40)	
	taud		2.441	2.476	2.442	2.415	2.394	2.355	2.315	2.367	2.454	2.541	2.541	2.506	(41)	
	Ebn at Noon		260	286	289	289	284	278	269	271	273	268	255	251	(42)	
	Edh at Noon		22	26	31	35	36	38	39	36	30	24	20	19	(43)	
(44) All-Sky Solar Radiation	RadAvg		457	727	1094	1359	1577	1709	1750	1575	1253	800	448	344	(44)	
	RadStd		40	54	71	126	169	147	118	109	93	84	49	25	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A	

Nomenclature: See separate page