

PARRSBORO, NS, Canada

WMO: 714930

Lat: 45.4135N

Lon: 64.3462W

Elev: 31

StdP: 100.95

Time Zone: -4.00 (NAA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.0	-17.4	-24.0	0.4	-18.8	-21.6	0.5	-15.7	12.5	-4.9	10.3	-2.9	1.6	290	0.575

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	25.5	19.6	24.2	18.8	22.9	18.2	21.1	23.8	20.1	22.8	19.2	21.6	3.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	14.8	22.6	19.1	13.9	21.7	18.1	13.1	20.7	61.2	23.9	57.9	22.9	54.8	21.7	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	7.7	6.5	-24.8	28.6	2.2	1.1	-26.4	29.3	-27.7	30.0	-28.9	30.6	-30.6	31.3		
(5)			-25.0	23.2	2.2	0.9	-26.6	23.8	-27.8	24.4	-29.0	24.9	-30.6	25.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.2	-5.8	-5.6	-1.8	4.1	9.5	13.7	17.5	17.3	14.0	8.8	3.6	-2.0
	DBStd	9.24	6.23	5.69	4.78	3.42	2.99	2.74	2.25	2.44	3.53	4.04	4.77	5.67
	HDD10.0	2172	490	437	366	179	47	3	0	0	6	72	200	372
	HDD18.3	4478	748	671	624	426	275	139	42	49	136	296	443	630
	CDD10.0	775	0	0	0	3	30	116	233	225	126	36	7	0
	CDD18.3	39	0	0	0	0	0	2	17	16	4	1	0	0
	CDH23.3	209	0	0	0	0	1	17	100	77	14	1	0	0
	CDH26.7	11	0	0	0	0	0	1	4	4	1	0	0	0
Wind	WSAvg	2.8	3.1	3.2	3.4	3.3	3.0	2.7	2.1	2.1	2.3	2.7	3.0	3.1
Precipitation	PrecAvg	1203	105	87	96	94	96	85	83	80	111	120	115	132
	PrecMax	1574	165	174	209	153	219	212	167	180	243	242	192	234
	PrecMin	937	35	33	28	31	30	13	22	23	24	25	45	66
	PrecStd	156	30	38	43	30	47	50	41	46	63	55	36	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	10.2	12.2	17.7	22.5	25.4	27.3	27.2	25.1	21.5	18.7	13.6
		MCWB	12.8	8.9	8.8	12.0	15.6	18.3	20.7	20.8	20.0	17.4	16.4	12.1
	2%	DB	8.1	6.2	8.9	15.1	19.5	22.9	25.8	25.3	22.8	18.7	15.1	10.9
		MCWB	7.4	4.9	6.2	10.7	13.5	17.1	19.9	19.6	18.8	16.1	13.5	10.0
	5%	DB	5.6	4.1	6.8	12.6	17.3	21.2	24.4	23.9	21.2	17.1	13.5	8.7
		MCWB	4.7	2.8	4.3	8.7	11.8	15.8	19.0	18.8	17.6	15.1	12.1	7.8
	10%	DB	3.0	2.4	4.9	10.7	15.4	19.6	23.0	22.7	19.9	15.6	11.4	6.3
		MCWB	2.0	1.3	2.8	7.4	11.1	15.0	18.4	18.3	17.0	13.5	9.9	5.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.5	8.7	9.5	14.7	17.1	20.0	22.5	22.4	21.2	18.7	16.5	12.5
		MCDB	13.6	10.1	11.4	16.8	21.1	23.5	25.8	25.5	24.0	19.9	18.1	13.3
	2%	WB	7.5	5.2	7.0	11.8	14.9	18.4	21.2	21.0	19.8	16.8	14.1	10.2
		MCDB	7.9	5.8	8.1	13.3	17.4	21.5	24.0	23.7	21.6	18.0	14.9	10.8
	5%	WB	4.8	3.1	4.8	9.8	13.2	17.0	20.1	20.0	18.8	15.5	12.3	8.0
		MCDB	5.6	3.9	6.1	11.8	15.9	19.8	23.0	22.5	20.5	16.8	13.2	8.6
	10%	WB	2.1	1.4	3.0	7.9	11.9	15.8	19.1	19.0	17.7	13.9	10.1	5.4
		MCDB	2.8	2.1	4.6	9.9	14.4	18.4	21.8	21.5	19.5	15.2	11.3	6.2
Mean Daily Temperature Range	5% DB	MDBR	10.1	9.7	9.4	9.9	10.5	10.5	10.8	10.7	10.5	9.6	8.6	8.4
		MCDBR	12.7	9.9	11.3	13.8	13.8	13.7	13.1	12.7	11.2	10.3	10.2	10.6
		MCWBR	12.6	8.8	8.7	9.5	8.3	8.1	7.8	7.5	7.6	8.1	9.3	10.6
	5% WB	MCDBR	12.6	9.9	10.3	11.5	11.2	11.0	10.7	10.1	8.8	8.8	9.9	10.6
		MCWBR	12.6	9.3	9.1	9.3	7.8	7.3	7.2	6.8	6.7	7.7	9.5	10.8
Clear-Sky Solar Irradiance	taub	0.295	0.290	0.324	0.350	0.372	0.392	0.417	0.396	0.359	0.328	0.308	0.291	
	taud	2.441	2.476	2.442	2.415	2.394	2.355	2.315	2.367	2.454	2.541	2.541	2.506	
	Ebn at Noon	819	903	910	911	896	876	847	853	860	845	803	791	
	Edh at Noon	70	81	97	109	115	121	124	114	96	76	64	60	
All-Sky Solar Radiation	RadAvg	1.44	2.29	3.45	4.29	4.97	5.39	5.52	4.96	3.95	2.52	1.41	1.09	
	RadStd	0.13	0.17	0.22	0.40	0.53	0.46	0.37	0.34	0.29	0.27	0.15	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.38	N/A	N/A	N/A	N/A

Nomenclature: See separate page