

DUBAWNT LAKE, NU, Canada

WMO: 714999

Lat: 63.230N

Lon: 101.760W

Elev: 237

StdP: 98.51

Time Zone: -6.00 (NAC)

Period: 93-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-39.9	-38.3	-42.7	0.1	-39.9	-40.9	0.1	-38.2	17.2	-24.3	16.1	-24.7	4.4	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.9	19.9	14.6	17.3	13.2	15.5	12.1	15.4	19.0	13.9	16.6	12.6	15.0	5.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	10.2	16.2	12.4	9.2	15.0	11.2	8.5	13.8	43.9	19.5	39.6	16.6	36.3	15.1	20.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.5	13.1	11.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.5	-29.2	-27.0	-24.0	-14.9	-5.3	5.1	10.3	10.6	5.5	-4.9	-15.7	-25.7
	DBStd	15.57	6.82	6.35	7.10	6.94	5.82	3.49	3.61	3.40	4.45	5.58	6.33	7.44
	HDD10.0	7236	1216	1035	1056	747	473	151	41	34	146	461	772	1106
	HDD18.3	10162	1474	1268	1314	997	731	397	251	239	384	719	1022	1364
	CDD10.0	116	0	0	0	0	0	3	49	52	11	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	8	0	0	0	0	0	0	3	2	2	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	0	1	0	0	0
Wind	WSAvg	5.6	5.7	5.5	5.7	5.3	5.3	4.4	4.7	5.4	6.9	7.3	5.8	5.2
Precipitation	PrecAvg	303	9	9	15	13	18	29	47	56	46	30	18	12
	PrecMax	431	21	24	41	39	39	68	95	94	74	47	40	23
	PrecMin	205	3	2	3	4	4	10	21	23	12	11	5	4
	PrecStd	44	5	5	8	8	9	14	18	19	17	8	8	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.4	-8.3	-1.2	1.7	7.7	18.6	23.6	23.0	16.6	7.5	-0.1	-7.2
		MCWB	-8.7	-8.6	-1.7	0.5	5.5	12.3	16.7	15.3	11.8	5.8	-0.6	-7.5
	2%	DB	-11.7	-11.4	-7.3	0.4	4.6	14.6	20.8	19.5	14.0	5.6	-2.3	-9.4
		MCWB	-12.0	-11.8	-7.5	-0.4	3.2	9.9	15.0	14.1	10.8	4.4	-2.7	-9.8
	5%	DB	-15.0	-13.5	-11.1	-1.3	3.0	12.4	18.3	16.9	12.4	4.0	-4.4	-11.2
		MCWB	-15.3	-13.8	-11.4	-2.0	1.8	8.7	13.9	13.0	10.4	3.3	-4.9	-11.5
	10%	DB	-18.4	-16.3	-13.6	-3.6	1.7	10.5	16.5	15.2	11.0	2.6	-5.9	-14.3
		MCWB	-18.8	-16.6	-14.0	-4.2	0.8	7.6	12.9	12.4	9.5	2.0	-6.3	-14.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.7	-8.5	-1.9	0.7	5.7	12.8	18.6	16.2	13.1	6.2	-0.4	-7.4
		MCDB	-8.5	-8.2	-1.3	1.3	7.4	16.8	21.1	20.8	15.5	7.1	-0.2	-7.1
	2%	WB	-12.0	-11.6	-7.6	-0.3	3.4	10.3	16.6	14.8	11.6	4.6	-2.6	-9.8
		MCDB	-11.6	-11.3	-7.3	0.4	4.4	13.6	19.2	18.0	13.3	5.4	-2.3	-9.6
	5%	WB	-15.3	-13.7	-11.4	-2.1	2.0	8.9	14.6	13.7	10.6	3.3	-4.9	-11.5
		MCDB	-15.0	-13.4	-11.0	-1.4	2.7	11.9	17.5	16.2	12.2	3.9	-4.6	-11.2
	10%	WB	-18.8	-16.6	-14.0	-4.1	0.9	7.7	13.0	12.7	9.6	2.0	-6.4	-14.5
		MCDB	-18.4	-16.3	-13.6	-3.5	1.7	10.3	15.6	14.9	11.0	2.8	-6.0	-14.3
Mean Daily Temperature Range	5% DB	MDBR	6.5	7.8	8.1	9.1	6.6	7.9	8.7	5.9	4.9	4.8	6.5	6.6
		MCDBR	10.1	11.1	10.0	9.7	6.6	11.8	11.5	9.0	7.0	4.4	8.0	9.2
		MCWBR	10.0	10.9	9.9	9.1	5.3	7.5	6.5	4.7	4.1	3.8	7.8	9.1
	5% WB	MCDBR	10.1	11.2	10.1	9.9	6.5	11.2	9.8	8.2	7.0	4.1	8.0	9.4
		MCWBR	10.0	11.0	10.0	9.4	5.3	7.4	5.9	4.9	4.4	3.7	7.9	9.2
Clear-Sky Solar Irradiance	taub	0.176	0.236	0.252	0.303	0.318	0.341	0.349	0.326	0.301	0.256	0.178	0.147	
	taud	1.975	2.159	2.249	2.167	2.311	2.450	2.448	2.487	2.544	2.312	1.980	1.920	
	Ebn at Noon	486	721	864	876	896	881	862	854	813	692	461	305	
	Edh at Noon	30	61	84	115	110	99	96	85	65	52	28	14	
All-Sky Solar Radiation	RadAvg	0.22	1.00	2.79	5.11	6.23	5.68	5.32	3.88	2.26	0.84	0.32	0.10	
	RadStd	0.01	0.05	0.15	0.27	0.42	0.39	0.38	0.33	0.29	0.13	0.03	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page