

GLENEVIS AGCM, AB, Canada

WMO: 715000

Lat: 53.8325N

Lon: 114.5389W

Elev: 2198

StdP: 13.57

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-20.4	-15.0	-26.7	1.3	-19.4	-21.3	1.8	-14.7	25.3	32.9	22.5	28.5	3.9	200	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	81.0	62.6	78.2	61.2	75.4	60.1	65.6	76.6	63.5	74.5	61.8	72.3	6.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.4	88.1	71.4	59.1	81.0	68.4	57.3	75.9	66.5	31.6	76.4	30.0	74.9	28.7	72.7	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.3	18.7	16.0	DB	-26.9	86.7	4.9	3.3	-30.4	89.0	-33.3	90.9	-36.1	92.8	-39.7	95.2
			WB	-27.2	69.3	4.9	2.5	-30.7	71.0	-33.5	72.5	-36.2	73.9	-39.8	75.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.8	17.7	15.8	26.0	39.5	51.5	58.0	62.1	60.7	52.1	40.6	26.1	14.1		
	DBStd	20.55	15.99	15.83	13.90	9.08	8.06	5.64	4.99	5.65	8.10	8.81	12.51	14.34		
	HDD50	5332	1000	958	743	330	79	7	0	2	70	311	718	1114		
	HDD65	9620	1465	1378	1208	764	421	219	117	155	389	758	1167	1579		
	CDD50	1250	0	0	0	16	126	246	376	333	133	19	1	0		
	CDD65	61	0	0	0	0	3	8	28	20	2	0	0	0		
	CDH74	900	0	0	0	4	86	118	349	241	99	3	0	0		
	CDH80	129	0	0	0	0	9	12	57	35	16	0	0	0		
	WSAvg	6.6	6.9	6.7	6.6	7.9	7.4	6.5	6.1	5.6	6.0	7.0	6.1	6.5		
	PrecAvg	19.3	1.0	0.6	0.7	1.2	2.2	3.4	3.7	2.5	1.5	0.9	0.8	0.7		
(15) Precipitation	PrecMax	25.7	3.0	1.2	1.4	2.2	4.3	6.9	8.2	5.4	3.4	3.0	2.4	1.9		
	PrecMin	12.6	0.1	0.0	0.1	0.2	0.7	1.0	1.8	1.2	0.4	0.2	0.2	0.2		
	PrecStd	3.1	0.7	0.3	0.3	0.6	0.9	1.3	1.5	0.8	0.9	0.7	0.6	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	51.1	57.4	73.1	81.0	81.4	85.0	84.0	82.3	71.7	57.3	45.8		
		MCWB	38.9	40.6	43.0	52.2	56.6	61.1	64.8	64.1	61.4	53.7	45.2	36.9		
	2%	DB	45.5	44.0	51.1	65.2	76.1	77.3	81.0	79.7	76.6	62.4	48.8	41.0		
		MCWB	37.3	35.9	39.8	47.8	55.0	60.1	64.3	63.9	59.4	49.1	40.2	34.1		
	5%	DB	42.5	40.6	46.6	59.2	71.4	74.0	77.8	76.5	71.9	57.9	44.3	37.7		
		MCWB	35.8	34.1	37.2	43.9	52.8	58.1	62.1	62.4	57.2	46.4	37.9	32.1		
	10%	DB	38.9	37.2	42.7	54.3	67.4	70.8	74.9	73.3	66.6	53.8	40.5	33.7		
		MCWB	33.2	31.8	35.1	41.8	50.6	56.8	61.1	60.9	54.8	44.0	35.3	28.8		
	0.4%	WB	39.6	40.4	43.7	52.0	58.2	64.2	68.8	68.2	63.4	54.3	46.1	37.6		
		MCDB	46.8	50.1	55.3	72.5	75.9	77.0	79.5	78.9	78.0	69.7	56.3	44.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.8	36.8	40.5	48.0	56.2	61.7	66.0	65.8	60.6	50.3	41.3	34.3		
		MCDB	44.8	42.9	50.4	63.6	72.0	73.2	76.9	76.6	74.6	60.7	47.9	39.9		
	5%	WB	35.9	34.5	37.8	44.9	54.2	59.8	63.8	63.6	58.0	47.3	38.3	32.0		
		MCDB	41.8	40.0	45.7	57.3	68.8	70.9	75.2	73.4	69.9	56.3	43.5	37.2		
	10%	WB	33.5	32.0	35.3	42.3	52.0	58.2	61.9	61.7	55.7	44.8	35.8	29.1		
		MCDB	38.7	37.1	42.0	52.6	65.4	68.6	72.6	71.4	65.2	52.3	39.9	33.1		
	5% DB	MDBR	15.9	16.7	17.8	18.6	21.8	20.3	20.6	20.5	20.9	16.2	13.7	14.6		
		MCDBR	14.8	18.2	21.6	27.3	28.7	25.4	25.8	26.2	30.4	22.8	17.3	17.1		
		MCWBR	10.0	12.6	12.4	14.0	12.8	11.4	11.8	12.4	15.1	12.4	11.2	12.8		
		MCWBR	15.0	17.5	21.1	25.2	26.7	22.7	24.0	23.9	28.8	22.1	16.4	17.7		
(40) Clear-Sky Solar Irradiance	taub		0.248	0.265	0.296	0.333	0.349	0.357	0.359	0.362	0.315	0.284	0.256	0.240		
		taud	2.340	2.364	2.373	2.374	2.372	2.363	2.413	2.355	2.490	2.555	2.454	2.307		
	Ebn at Noon		237	270	284	285	285	283	280	272	274	263	235	214		
		Edh at Noon	17	23	29	34	36	36	34	34	26	20	15	14		
(44) All-Sky Solar Radiation	RadAvg		291	613	1073	1465	1761	1867	1894	1571	1089	620	303	209		
	RadStd		23	47	75	131	133	130	118	111	112	67	29	18		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (50 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page