

PELLEY ISLAND, NT, Canada

WMO: 715020

Lat: 69.623N

Lon: 135.436W

Elev: 17

StdP: 101.12

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.5	-34.9	-42.1	0.1	-34.7	-40.1	0.1	-33.9	21.0	-15.7	18.4	-18.7	4.0	110	1.094

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	18.7	15.1	16.3	13.5	14.3	12.1	15.4	18.5	13.9	16.2	12.3	14.2	6.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	9.9	17.1	12.4	9.0	15.4	11.1	8.2	13.8	43.3	18.2	39.1	16.3	35.1	14.2	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.6	13.3	11.9	DB	-37.8	24.0	0.9	2.5	-38.5	25.8	-39.0	27.3	-39.6	28.7	-40.2	30.5	(4)
(5)			WB	-37.6	17.2	1.6	1.7	-38.8	18.4	-39.7	19.4	-40.6	20.3	-41.8	21.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.0	-24.7	-23.7	-22.8	-14.1	-4.2	3.1	8.9	7.8	3.1	-5.1	-15.8	-21.5
	DBStd	13.39	6.70	6.60	6.17	6.22	4.63	3.57	4.35	4.02	3.56	4.60	5.73	5.91
	HDD10.0	7006	1076	943	1016	724	441	212	73	94	208	467	774	977
	HDD18.3	9978	1334	1177	1274	974	699	458	292	328	456	726	1024	1235
	CDD10.0	72	0	0	0	0	0	4	41	25	2	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	6	0	0	0	0	0	1	5	1	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.9	6.0	6.3	5.6	5.6	5.8	5.3	5.9	6.0	6.4	6.4	5.8	5.8
Precipitation	PrecAvg	290	11	9	11	8	13	31	52	58	39	28	16	12
	PrecMax	362	25	20	24	23	30	67	123	92	66	47	35	28
	PrecMin	231	1	1	2	3	2	10	17	26	20	10	3	2
	PrecStd	34	7	5	6	5	6	15	19	18	10	9	7	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.4	-4.5	-3.7	2.3	8.4	19.3	23.5	20.3	14.9	4.2	-0.8	-4.6
		MCWB	-4.1	-4.8	-4.3	1.3	5.6	13.6	16.7	16.1	11.1	3.3	-1.3	-5.3
	2%	DB	-7.7	-8.6	-7.8	0.2	4.4	14.6	19.8	17.4	11.7	2.3	-3.1	-8.5
		MCWB	-8.1	-9.0	-8.2	-0.6	2.7	11.4	15.9	14.1	9.4	1.6	-3.6	-9.0
	5%	DB	-12.0	-11.2	-10.8	-2.3	2.7	10.4	17.5	15.4	9.5	1.0	-5.2	-11.0
		MCWB	-12.3	-11.5	-11.2	-2.8	1.5	8.1	14.6	12.9	8.1	0.4	-5.6	-11.5
	10%	DB	-15.6	-14.1	-14.0	-4.8	1.4	7.7	15.2	13.4	7.9	0.0	-7.4	-13.2
		MCWB	-16.0	-14.5	-14.5	-5.4	0.5	5.9	13.1	11.5	6.9	-0.5	-7.8	-13.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.2	-4.6	-4.1	1.4	5.7	14.4	17.8	16.6	11.5	3.5	-1.2	-5.1
		MCDB	-3.7	-4.4	-3.6	2.2	8.3	19.0	21.5	19.5	14.1	4.1	-0.6	-4.7
	2%	WB	-8.2	-9.0	-8.0	-0.4	2.9	11.4	16.2	14.7	9.7	1.7	-3.6	-8.8
		MCDB	-7.9	-8.7	-7.6	0.3	4.3	14.7	19.6	17.1	11.6	2.2	-3.2	-8.4
	5%	WB	-12.4	-11.6	-11.0	-2.7	1.7	8.4	14.7	13.2	8.3	0.5	-5.6	-11.3
		MCDB	-12.0	-11.3	-10.6	-2.2	2.7	10.5	17.4	15.1	9.5	0.9	-5.2	-10.9
	10%	WB	-16.0	-14.4	-14.1	-5.2	0.7	6.2	13.3	11.8	7.0	-0.4	-7.7	-13.3
		MCDB	-15.7	-14.1	-13.7	-4.7	1.4	7.8	15.3	13.2	8.1	-0.1	-7.3	-13.0
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.0	6.4	7.4	5.4	5.2	5.9	4.8	3.5	3.4	5.3	5.4
		MCDBR	9.4	9.7	8.5	8.4	6.9	11.1	10.2	8.3	6.4	3.1	6.3	8.3
		MCWBR	9.2	9.4	8.4	7.9	5.5	8.1	7.0	5.8	4.4	2.9	6.5	8.3
	5% WB	MCDBR	9.1	9.5	8.3	8.3	6.5	11.1	9.7	7.9	6.2	3.1	6.4	8.3
		MCWBR	9.0	9.5	8.2	7.8	5.3	8.2	7.0	5.8	4.4	2.8	6.4	8.3
Clear-Sky Solar Irradiance	taub	0.161	0.206	0.240	0.303	0.342	0.342	0.363	0.335	0.294	0.232	N/A	N/A	
	taud	1.883	2.043	2.182	2.068	2.083	2.299	2.416	2.523	2.552	2.189	N/A	N/A	
	Ebn at Noon	32	555	792	822	829	849	816	804	749	511	0	0	
	Edh at Noon	3	40	72	114	128	107	93	75	54	34	0	0	
All-Sky Solar Radiation	RadAvg	0.01	0.40	2.02	4.29	6.03	6.50	5.13	3.17	1.63	0.49	0.00	0.00	
	RadStd	0.00	0.02	0.10	0.24	0.38	0.47	0.40	0.28	0.15	0.06	0.00	0.00	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.94	+1.50	+1.89	N/A	N/A	N/A	-352	-357	N/A	N/A

Nomenclature: See separate page