

ROCK RIVER, YT, Canada

WMO: 715060

Lat: 66.9811N

Lon: 136.2181W

Elev: 731

StdP: 92.85

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.0	-32.1	-38.2	0.1	-33.7	-36.2	0.1	-31.8	29.3	-23.0	26.5	-22.6	1.9	0	0.956

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	22.0	13.4	20.1	12.6	18.4	11.8	14.6	20.2	13.5	18.6	12.5	17.0	4.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	9.6	16.3	11.1	9.0	15.3	10.1	8.4	14.3	43.1	20.2	40.2	18.7	37.5	17.2	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.6	19.6	16.3	DB	-34.9	24.8	2.6	2.4	-36.7	26.5	-38.2	28.0	-39.7	29.3	-41.5	31.1	(4)
			WB	-35.3	15.8	2.5	1.3	-37.1	16.7	-38.5	17.4	-39.9	18.1	-41.7	19.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.4	-20.1	-17.5	-16.6	-7.7	2.8	10.5	12.6	9.0	2.7	-6.9	-15.5	-18.5
	DBStd	13.44	8.62	7.51	7.46	6.96	6.36	4.57	3.90	4.52	5.13	5.36	6.46	7.14
	HDD10.0	5833	932	769	823	532	235	49	21	73	224	525	766	885
	HDD18.3	8657	1191	1002	1082	781	483	237	180	291	470	783	1016	1143
	CDD10.0	221	0	0	0	0	11	63	101	42	4	1	0	0
	CDD18.3	6	0	0	0	0	0	1	3	2	0	0	0	0
	CDH23.3	26	0	0	0	0	0	6	11	9	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	4.8	4.1	3.5	4.0	5.3	6.1	6.1	4.7	5.0	4.8	5.1	4.3	4.3
Precipitation	PrecAvg	368	19	16	14	12	21	45	67	60	42	31	21	20
	PrecMax	431	43	44	36	25	41	86	111	121	65	51	52	50
	PrecMin	301	5	2	4	2	6	11	28	20	27	6	3	7
	PrecStd	34	10	9	8	6	9	17	19	22	9	11	10	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.6	1.7	2.3	9.8	19.6	24.0	25.0	24.2	17.3	8.3	1.8	1.3
		MCWB	0.1	-1.4	-0.7	4.5	10.0	13.0	14.9	15.6	9.2	4.8	-1.0	-1.3
	2%	DB	-1.5	-1.5	-1.1	6.5	16.9	21.1	22.4	20.6	13.8	4.5	-1.8	-2.4
		MCWB	-3.4	-3.8	-3.2	2.3	8.9	11.9	13.9	13.9	8.3	1.9	-3.5	-4.0
	5%	DB	-4.3	-4.3	-3.4	4.2	14.4	19.3	20.3	17.9	11.7	2.2	-3.8	-5.0
		MCWB	-5.9	-5.9	-5.3	0.8	7.7	11.5	13.2	12.5	7.3	0.3	-5.1	-6.3
	10%	DB	-7.0	-6.7	-5.9	2.0	12.0	17.4	18.7	15.6	9.7	0.3	-6.3	-7.9
		MCWB	-8.1	-7.9	-7.4	-0.7	6.6	10.6	12.4	11.2	6.3	-1.1	-7.2	-8.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.4	-1.1	-0.2	4.5	10.6	15.0	15.7	16.5	10.5	5.1	-0.8	-0.9
		MCDB	2.4	1.9	1.9	9.3	18.3	21.1	22.2	21.9	15.3	8.2	1.4	0.6
	2%	WB	-3.4	-3.7	-2.9	2.6	9.3	13.2	14.7	14.3	8.8	2.2	-3.3	-4.0
		MCDB	-1.8	-1.8	-1.1	6.3	15.8	19.0	20.6	19.5	12.5	4.1	-2.0	-2.7
	5%	WB	-5.7	-5.8	-5.2	0.9	8.1	12.1	13.9	12.9	7.7	0.5	-5.1	-6.3
		MCDB	-4.3	-4.5	-3.6	4.0	13.8	17.9	19.2	17.2	11.0	2.1	-3.8	-5.1
	10%	WB	-8.1	-7.8	-7.4	-0.6	6.8	11.1	13.0	11.5	6.6	-1.0	-7.2	-8.7
		MCDB	-6.9	-6.7	-5.9	1.8	11.7	16.5	17.5	15.1	9.3	0.0	-6.3	-7.8
Mean Daily Temperature Range	5% DB	MDBR	6.4	6.8	6.8	7.0	7.6	8.2	7.5	6.7	5.8	4.6	5.6	6.2
		MCDBR	8.0	9.0	9.3	8.5	9.9	10.1	9.8	9.6	8.8	6.4	7.5	9.3
		MCWBR	6.7	7.5	7.7	5.7	5.2	4.7	4.7	5.0	4.9	4.5	6.3	7.9
	5% WB	MCDBR	8.0	8.9	9.0	8.4	9.3	9.3	9.1	8.9	7.6	6.1	7.4	8.8
		MCWBR	6.9	7.6	7.7	5.7	5.1	4.8	4.8	5.0	4.5	4.4	6.4	7.6
Clear-Sky Solar Irradiance	taub	0.159	0.218	0.235	0.286	0.322	0.330	0.349	0.322	0.280	0.222	0.147	N/A	
	taud	1.906	2.159	2.273	2.192	2.275	2.420	2.381	2.494	2.538	2.290	1.935	N/A	
	Ebn at Noon	231	654	849	872	873	877	843	836	800	649	240	0	
	Edh at Noon	13	47	73	105	109	98	99	79	59	40	11	0	
All-Sky Solar Radiation	RadAvg	0.07	0.68	2.46	4.78	5.67	5.83	4.69	3.43	2.01	0.78	0.15	0.00	
	RadStd	0.01	0.04	0.12	0.18	0.49	0.53	0.37	0.33	0.19	0.08	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.69	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)		+1.13	+1.95	+2.05	N/A	N/A	N/A	-456	-466	N/A	N/A

Nomenclature: See separate page