

NATASHQUAN, QC, Canada

WMO: 715130

Lat: 50.190N

Lon: 61.790W

Elev: 12

StdP: 101.18

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -26.6	(c) -24.0	(d) -32.8	(e) 0.2	(f) -26.0	(g) -30.1	(h) 0.2	(i) -23.3	(j) 16.0	(k) -6.4	(l) 14.4	(m) -6.2	(n) 3.4	(o) 300	(p) 0.770

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	22.2	17.1	20.8	16.6	19.5	16.0	18.4	20.7	17.5	19.6	16.7	18.6	4.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.6	19.5	16.6	11.9	18.5	15.9	11.3	17.9	52.3	20.7	49.5	19.7	47.2	18.6	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.3	11.4	10.0	-31.7	25.9	2.6	1.6	-33.5	27.0	-35.0	27.9	-36.5	28.8	-38.4	29.9
			-31.8	20.6	2.5	0.9	-33.7	21.3	-35.1	21.8	-36.6	22.3	-38.4	22.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.1	-12.3	-11.5	-6.5	-0.2	5.8	11.3	15.3	15.1	10.6	5.3	-0.7	-7.9
	DBStd	10.51	6.58	6.32	5.53	3.42	2.89	2.94	2.27	2.50	3.07	3.17	4.52	5.97
	HDD10.0	3311	690	601	511	306	132	19	0	1	28	148	321	554
	HDD18.3	5925	948	834	769	556	387	211	97	104	231	404	571	812
	CDD10.0	434	0	0	0	0	3	59	165	157	47	2	0	0
	CDD18.3	7	0	0	0	0	0	1	3	3	0	0	0	0
	CDH23.3	16	0	0	0	0	0	1	11	4	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
(14) Wind	WSAvg	4.7	5.2	5.1	5.3	4.9	4.3	4.4	3.9	3.9	4.3	4.7	4.9	5.2
(15) Precipitation	PrecAvg	1182	94	77	88	85	93	94	91	105	99	112	124	120
	PrecMax	1424	174	180	173	156	236	176	176	168	186	250	197	240
	PrecMin	783	43	18	31	25	26	38	18	42	37	31	58	72
	PrecStd	155	34	36	38	35	46	38	40	34	35	50	39	43
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.7	4.0	5.2	10.1	17.7	22.7	24.6	23.8	20.6	15.0	10.3	4.9
		MCWB	3.1	3.3	2.1	5.7	11.5	16.4	18.9	18.6	15.9	12.0	9.7	4.2
	2%	DB	1.7	2.1	3.2	7.5	14.6	20.0	22.5	22.0	18.2	12.9	8.4	3.4
		MCWB	1.3	1.3	1.3	4.2	9.4	14.6	17.4	17.4	15.0	10.8	7.8	2.7
	5%	DB	0.2	0.4	2.0	5.7	12.6	18.1	21.0	20.6	16.7	11.5	7.1	2.2
		MCWB	-0.1	-0.3	0.4	3.2	8.4	13.6	16.6	17.0	14.2	9.7	6.3	1.4
	10%	DB	-1.6	-1.7	0.8	4.2	10.9	16.5	19.6	19.4	15.5	10.3	5.7	0.9
		MCWB	-2.2	-2.6	-0.4	2.2	7.5	12.6	16.0	16.4	13.4	8.7	4.7	0.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	3.5	3.0	6.4	12.5	17.6	20.2	19.9	17.5	13.0	10.1	4.5
		MCDB	3.5	3.9	4.1	8.6	16.2	21.0	23.6	22.3	18.9	14.0	10.2	4.7
	2%	WB	1.3	1.4	1.8	4.8	10.4	15.7	18.6	18.5	16.1	11.3	8.0	2.9
		MCDB	1.6	1.8	2.9	6.8	13.4	18.7	21.0	20.7	17.4	12.2	8.3	3.2
	5%	WB	0.0	-0.3	0.7	3.6	9.1	14.4	17.5	17.7	14.9	10.2	6.5	1.6
		MCDB	0.2	0.3	1.6	5.2	11.8	17.1	19.7	19.7	16.2	11.2	7.0	2.1
	10%	WB	-2.2	-2.5	-0.3	2.5	7.9	13.2	16.7	17.0	13.9	9.0	4.9	0.2
		MCDB	-1.7	-1.7	0.6	3.9	10.2	15.7	18.7	18.7	15.2	10.1	5.5	0.9
(35) Mean Daily Temperature Range	MDBR		9.9	9.9	8.9	6.8	8.0	8.2	7.8	7.8	7.8	7.0	6.7	8.2
	5% DB	MCDBR	9.5	7.6	7.3	8.3	11.2	10.9	10.3	9.5	9.1	8.1	6.4	7.4
		MCWBR	9.7	7.4	6.0	5.9	6.9	6.3	6.0	5.8	6.3	6.5	6.3	7.7
	5% WB	MCDBR	9.4	7.6	6.6	7.1	9.7	9.2	8.4	7.8	7.5	7.1	6.2	7.5
		MCWBR	9.5	7.5	5.9	5.5	6.5	6.0	5.5	5.3	6.0	6.3	6.5	7.8
(40) Clear-Sky Solar Irradiance	taub		0.281	0.292	0.301	0.332	0.367	0.387	0.415	0.383	0.355	0.333	0.297	0.279
	taud		2.367	2.323	2.378	2.409	2.405	2.369	2.341	2.433	2.481	2.502	2.512	2.400
	Ebn at Noon		765	849	910	913	891	872	838	851	842	797	751	713
	Edh at Noon		64	85	97	106	111	117	118	103	88	73	56	54
(44) All-Sky Solar Radiation	RadAvg		1.03	1.86	3.19	4.41	5.13	5.42	5.19	4.52	3.42	2.12	1.09	0.79
	RadStd		0.11	0.17	0.31	0.44	0.35	0.53	0.48	0.23	0.21	0.14	0.10	0.08

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+1.75	+0.66	+0.41	+0.41	N/A	N/A	+37	+3
(47) Regional (7 neighbors)	N/A	N/A	+1.41	N/A	+0.38	+0.43	N/A	N/A	N/A	N/A

Nomenclature: See separate page