

CORONACH SPC, SK, Canada

WMO: 715160

Lat: 49.050N

Lon: 105.480W

Elev: 2480

StdP: 13.43

Time Zone: -6.00 (W06)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.5	-17.6	-30.0	1.1	-23.4	-23.7	1.6	-17.5	33.1	20.8	30.2	19.2	6.8	310	0.714

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.4	90.6	64.4	86.8	63.3	83.2	62.5	69.1	81.8	66.7	79.6	64.8	77.6	11.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.9	100.9	74.4	62.5	92.9	71.8	60.3	85.7	70.0	34.8	81.2	32.7	79.2	31.2	77.7	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.8	24.5	21.5	-31.8	96.7	6.2	3.8	-36.2	99.4	-39.9	101.7	-43.3	103.8	-47.8	106.6
			-31.8	72.7	6.4	2.7	-36.4	74.6	-40.1	76.2	-43.7	77.7	-48.3	79.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.6	12.2	14.5	25.7	40.4	50.9	59.9	66.7	65.2	55.2	41.1	26.7	15.0
	DBStd	22.33	15.44	14.23	14.54	9.78	8.33	6.42	6.02	6.57	8.26	9.59	13.06	14.21
	HDD50	5452	1171	995	755	309	90	5	0	0	40	302	700	1085
	HDD65	9503	1636	1415	1218	738	441	177	52	80	306	741	1149	1550
	CDD50	1655	0	0	2	21	118	303	517	470	197	26	1	0
	CDD65	229	0	0	0	0	4	24	104	84	13	0	0	0
	CDH74	4108	0	0	0	19	143	433	1572	1484	433	24	0	0
	CDH80	1515	0	0	0	2	26	114	622	605	144	2	0	0
	WSAvg	9.7	10.2	9.5	10.2	10.7	10.9	9.7	8.5	8.3	9.1	9.9	9.6	9.7
	PrecAvg	15.6	0.9	0.6	0.9	1.2	2.5	2.8	2.1	1.6	1.0	1.0	0.6	0.7
Precipitation	PrecMax	23.9	2.0	1.5	2.0	2.3	6.9	5.9	9.3	5.5	2.8	3.2	2.1	1.6
	PrecMin	9.7	0.4	0.2	0.2	0.3	0.6	0.0	0.5	0.1	0.2	0.2	0.0	0.1
	PrecStd	3.2	0.5	0.3	0.4	0.6	1.7	1.1	1.7	1.2	0.7	0.8	0.5	0.4
	PrecStd	3.2	0.5	0.3	0.4	0.6	1.7	1.1	1.7	1.2	0.7	0.8	0.5	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.0	47.5	65.1	76.4	83.6	89.1	96.5	95.9	89.7	77.7	64.3	46.2
		MCWB	39.0	39.1	48.1	52.9	58.7	63.6	65.4	66.1	62.2	55.1	49.1	38.2
	2%	DB	40.0	41.1	56.0	69.0	78.1	82.9	90.9	90.7	84.2	69.3	54.8	41.2
		MCWB	35.5	35.9	44.1	50.6	57.0	63.2	65.6	63.6	59.6	51.8	44.1	35.7
	5%	DB	37.0	37.0	49.4	63.5	73.4	78.9	86.9	86.7	78.9	63.0	48.8	37.3
		MCWB	33.6	33.6	40.8	47.6	54.7	61.1	64.9	62.5	58.1	48.7	40.0	33.5
	10%	DB	33.6	33.3	43.7	58.6	68.6	75.1	82.7	82.8	73.5	57.5	43.3	33.8
		MCWB	31.1	31.0	37.8	45.4	52.5	59.6	64.4	61.9	56.1	46.4	37.4	30.9
	0.4%	WB	39.4	39.7	48.9	55.0	62.0	70.1	72.9	70.6	65.0	57.1	49.4	39.3
		MCDB	45.0	45.9	63.6	71.6	76.3	82.6	84.4	85.9	80.7	72.4	63.0	44.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.9	36.4	44.8	51.3	58.5	66.2	70.2	67.0	61.7	53.1	44.5	36.1
		MCDB	39.4	40.5	54.5	66.6	72.9	76.9	82.5	81.5	77.8	66.3	54.2	40.1
	5%	WB	33.7	33.8	41.3	48.9	56.4	63.5	68.0	65.1	59.4	50.0	40.7	33.7
		MCDB	36.8	37.0	48.7	60.9	69.4	74.1	80.0	79.4	74.4	60.9	47.6	37.3
	10%	WB	31.1	31.1	38.0	46.3	54.2	61.1	65.8	63.4	57.1	47.2	37.5	31.0
		MCDB	33.7	33.3	43.5	57.4	65.9	72.0	78.7	77.7	71.3	56.7	42.8	33.8
Mean Daily Temperature Range	5% DB	MDBR	19.3	19.2	19.8	24.3	25.0	23.4	27.4	29.0	27.3	23.8	20.6	18.5
		MCDBR	20.7	21.4	27.5	33.9	33.2	30.9	34.5	35.9	38.1	34.3	28.4	21.1
		MCWBR	16.8	16.8	17.0	17.9	15.8	14.4	13.7	13.6	16.6	18.7	17.7	16.5
		MCDBR	20.4	20.2	26.7	30.6	28.7	25.9	28.2	29.5	32.7	31.5	27.7	20.5
	5% WB	MCWBR	16.9	16.2	16.9	16.9	14.4	13.5	13.7	12.8	15.1	17.8	17.7	16.5
Clear-Sky Solar Irradiance	taub		0.249	0.261	0.273	0.319	0.339	0.346	0.356	0.365	0.320	0.283	0.254	0.235
	taud		2.430	2.440	2.529	2.412	2.404	2.429	2.422	2.371	2.462	2.555	2.523	2.479
	Ebn at Noon		266	289	303	295	292	289	285	277	281	278	264	259
	Edh at Noon		19	24	27	34	36	35	35	35	29	22	18	16
All-Sky Solar Radiation	RadAvg		442	770	1173	1553	1855	1993	2152	1740	1283	797	466	333
	RadStd		42	57	76	89	141	114	112	119	120	87	57	25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page