

CORONACH SPC, SK, Canada

WMO: 715160

Lat: 49.050N

Lon: 105.480W

Elev: 756

StdP: 92.57

Time Zone: -6.00 (W06)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.9	-27.6	-34.4	0.2	-30.8	-31.0	0.2	-27.5	14.8	-6.2	13.5	-7.1	3.0	310	0.714

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	32.5	18.0	30.4	17.4	28.4	17.0	20.6	27.7	19.3	26.5	18.2	25.4	5.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	14.4	23.5	17.0	13.3	22.1	15.7	12.2	21.1	63.2	27.3	58.2	26.2	54.6	25.4	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	10.9	9.6	DB	-35.4	35.9	3.4	2.1	-37.9	37.5	-39.9	38.7	-41.8	39.9	-44.3	41.4	(4)
(5)			WB	-35.4	22.6	3.5	1.5	-38.0	23.7	-40.1	24.6	-42.0	25.4	-44.6	26.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.2	-11.0	-9.7	-3.5	4.7	10.5	15.5	19.3	18.4	12.9	5.1	-2.9	-9.4	(6)	
	DBStd	12.41	8.58	7.91	8.08	5.43	4.63	3.57	3.35	3.65	4.59	5.33	7.25	7.89	(7)	
	HDD10.0	3029	651	553	419	172	50	3	0	0	22	168	389	603	(8)	
	HDD18.3	5279	909	786	677	410	245	98	29	44	170	412	638	861	(9)	
	CDD10.0	919	0	0	1	12	66	168	287	261	109	14	1	0	(10)	
	CDD18.3	127	0	0	0	0	2	13	58	47	7	0	0	0	(11)	
	CDH23.3	2282	0	0	0	11	79	241	873	824	241	13	0	0	(12)	
	CDH26.7	842	0	0	0	1	14	63	346	336	80	1	0	0	(13)	
(14) Wind	WSAvg	4.3	4.6	4.3	4.5	4.8	4.9	4.4	3.8	3.7	4.1	4.4	4.3	4.3	(14)	
(15) Precipitation	PrecAvg	395	22	15	22	30	63	72	53	41	25	25	14	18	(15)	
	PrecMax	608	52	38	50	59	176	150	236	140	70	81	53	41	(16)	
	PrecMin	247	9	4	5	8	16	0	13	3	5	4	0	3	(17)	
	PrecStd	82	12	7	11	14	44	29	44	30	18	21	12	9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.8	8.6	18.4	24.7	28.7	31.7	35.9	35.5	32.1	25.4	18.0	7.9	(19)	
		MCWB	3.9	4.0	9.0	11.6	14.8	17.6	18.5	18.9	16.8	12.8	9.5	3.4	(20)	
	2%	DB	4.5	5.0	13.3	20.5	25.6	28.3	32.7	32.6	29.0	20.7	12.7	5.1	(21)	
		MCWB	1.9	2.2	6.7	10.3	13.9	17.3	18.7	17.6	15.3	11.0	6.7	2.0	(22)	
	5%	DB	2.8	2.8	9.7	17.5	23.0	26.1	30.5	30.4	26.0	17.2	9.3	2.9	(23)	
		MCWB	0.9	0.9	4.9	8.6	12.6	16.2	18.3	17.0	14.5	9.3	4.4	0.8	(24)	
	10%	DB	0.9	0.7	6.5	14.8	20.3	23.9	28.2	28.2	23.0	14.2	6.3	1.0	(25)	
		MCWB	-0.5	-0.6	3.2	7.5	11.4	15.3	18.0	16.6	13.4	8.0	3.0	-0.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	4.3	9.4	12.8	16.7	21.2	22.7	21.4	18.3	14.0	9.7	4.0	(27)	
		MCDB	7.2	7.7	17.6	22.0	24.6	28.1	29.1	30.0	27.1	22.4	17.2	7.0	(28)	
	2%	WB	2.1	2.4	7.1	10.7	14.7	19.0	21.2	19.5	16.5	11.7	6.9	2.3	(29)	
		MCDB	4.1	4.7	12.5	19.2	22.7	25.0	28.0	27.5	25.4	19.0	12.4	4.5	(30)	
	5%	WB	1.0	1.0	5.1	9.4	13.5	17.5	20.0	18.4	15.2	10.0	4.8	0.9	(31)	
		MCDB	2.7	2.8	9.3	16.1	20.8	23.4	26.7	26.3	23.5	16.1	8.7	3.0	(32)	
	10%	WB	-0.5	-0.5	3.3	8.0	12.3	16.2	18.8	17.4	13.9	8.4	3.1	-0.6	(33)	
		MCDB	0.9	0.7	6.4	14.1	18.8	22.2	25.9	25.4	21.8	13.7	6.0	1.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.7	11.0	13.5	13.9	13.0	15.2	16.1	15.2	13.2	11.4	10.3	(35)	
		MCDBR	11.5	11.9	15.3	18.8	18.5	17.2	19.2	20.0	21.2	19.0	15.8	11.7	(36)	
	5% WB	MCWBR	9.4	9.3	9.4	10.0	8.8	8.0	7.6	7.6	9.2	10.4	9.8	9.1	(37)	
		MCWBR	11.3	11.2	14.8	17.0	15.9	14.4	15.7	16.4	18.2	17.5	15.4	11.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.249	0.261	0.273	0.319	0.339	0.346	0.356	0.365	0.320	0.283	0.254	0.235	(40)	
		taud	2.430	2.440	2.529	2.412	2.404	2.429	2.422	2.371	2.462	2.555	2.523	2.479	(41)	
	Ebn at Noon	Ebn at Noon	839	910	956	931	920	912	897	872	885	875	832	817	(42)	
		Edh at Noon	61	77	85	106	112	110	109	110	90	69	56	51	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.39	2.43	3.70	4.89	5.85	6.28	6.79	5.48	4.04	2.51	1.47	1.05	(44)	
	RadStd	RadStd	0.13	0.18	0.24	0.28	0.45	0.36	0.35	0.38	0.38	0.28	0.18	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page