

SEVEN PERSONS AGDM, AB, Canada

WMO: 715250

Lat: 49.9183N

Lon: 110.9149W

Elev: 743

StdP: 92.71

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-28.3	-25.1	-31.6	0.2	-28.3	-28.3	0.3	-25.1	13.9	0.5	12.5	-1.6	3.3	230	0.704

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	32.4	17.1	30.4	16.7	28.4	16.2	19.2	27.9	18.1	26.9	17.3	26.0	4.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.3	12.7	22.1	15.1	11.7	21.1	14.0	10.9	20.3	57.6	27.7	54.2	27.1	51.3	25.9	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	11.1	9.6	-33.6	35.7	2.6	1.7	-35.4	37.0	-37.0	38.0	-38.4	39.0	-40.3	40.2		
(5)			-33.7	21.4	2.6	1.1	-35.5	22.2	-37.1	22.9	-38.5	23.5	-40.4	24.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-7.1	-7.8	-0.6	5.8	11.5	15.6	19.4	18.3	13.2	6.2	-1.2	-7.1	(6)
(7)		DBStd	11.44	8.58	8.47	7.49	4.98	4.41	3.36	3.18	3.59	4.72	5.23	7.34	7.93	(7)
(8)		HDD10.0	2559	529	498	328	140	34	2	0	0	20	138	338	531	(8)
(9)		HDD18.3	4780	787	731	586	376	216	96	26	46	164	377	586	789	(9)
(10)		CDD10.0	951	0	0	1	13	81	170	291	257	116	20	2	0	(10)
(11)		CDD18.3	130	0	0	0	0	3	14	58	44	11	0	0	0	(11)
(12)		CDH23.3	2237	0	0	0	8	106	249	903	723	239	8	0	0	(12)
(13)		CDH26.7	811	0	0	0	1	22	69	355	278	84	1	0	0	(13)
(14)	Wind	WSAvg	4.7	5.3	4.7	4.9	5.2	4.8	4.5	3.9	3.9	4.3	4.8	5.0	4.9	(14)
(15)	Precipitation	PrecAvg	390	20	16	20	36	55	79	37	34	32	24	19	18	(15)
(16)		PrecMax	591	39	39	37	66	95	173	146	88	63	59	44	39	(16)
(17)		PrecMin	230	6	3	3	11	10	19	5	8	1	5	4	3	(17)
(18)		PrecStd	72	8	9	10	15	22	37	29	21	17	13	9	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	11.9	18.4	24.1	29.6	31.9	35.0	34.1	32.4	24.5	17.6	10.0	(19)
(20)			MCWB	5.9	5.5	9.2	11.7	15.2	17.6	18.3	16.8	15.7	13.4	9.0	4.7	(20)
(21)		2%	DB	7.3	7.9	15.3	20.7	26.2	28.5	32.7	32.0	29.3	20.2	13.4	7.1	(21)
(22)			MCWB	3.6	3.5	7.5	10.3	13.7	16.5	17.8	16.5	14.9	11.2	7.2	3.2	(22)
(23)		5%	DB	5.2	5.0	12.3	18.0	23.7	26.1	30.5	30.0	26.0	17.4	10.6	5.2	(23)
(24)			MCWB	2.4	1.7	5.9	8.8	12.8	15.8	17.6	16.3	14.0	9.7	5.5	2.2	(24)
(25)		10%	DB	3.6	3.0	9.5	15.3	21.0	23.9	28.4	27.6	22.8	14.8	8.1	3.3	(25)
(26)			MCWB	1.4	0.8	4.4	7.2	11.4	14.7	17.1	15.9	12.7	8.4	3.9	0.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	6.1	9.6	12.4	15.8	19.7	21.2	19.5	17.3	13.6	10.0	5.4	(27)
(28)			MCDWB	9.8	10.2	17.4	22.5	26.7	27.2	30.3	27.9	27.1	23.1	15.4	8.7	(28)
(29)		2%	WB	3.9	3.6	8.0	10.6	14.5	17.9	19.7	18.2	15.8	11.7	7.5	3.5	(29)
(30)			MCDWB	7.0	7.7	14.4	20.0	24.3	26.3	28.4	27.6	27.0	18.8	13.0	6.2	(30)
(31)		5%	WB	2.5	1.9	6.3	9.1	13.4	16.7	18.7	17.3	14.5	10.1	5.7	2.1	(31)
(32)			MCDWB	4.9	4.6	11.8	16.8	22.0	24.4	27.3	27.0	24.8	16.4	9.9	4.9	(32)
(33)		10%	WB	1.5	0.8	4.6	7.7	12.2	15.4	17.8	16.4	13.3	8.8	4.2	0.8	(33)
(34)			MCDWB	3.6	3.0	9.1	14.2	19.5	22.4	26.3	25.7	22.4	14.3	7.6	3.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.0	10.7	11.4	13.1	13.6	13.2	15.5	15.3	14.4	12.7	11.1	9.6	(35)
(36)			MCDBR	10.1	12.5	15.6	18.7	18.1	17.0	18.9	19.6	19.9	16.3	14.3	10.8	(36)
(37)			MCWBR	7.5	8.6	8.9	9.6	8.0	7.5	7.5	7.5	8.2	8.4	8.6	7.8	(37)
(38)		5% WB	MCDWB	9.8	11.7	15.1	17.3	16.1	15.7	16.5	17.1	18.7	15.5	13.4	11.0	(38)
(39)			MCWBR	7.4	8.5	8.9	9.2	7.5	7.7	7.6	7.1	8.0	8.3	8.6	8.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.271	0.271	0.300	0.356	0.379	0.369	0.368	0.390	0.343	0.301	0.269	0.258	(40)	
(41)		taud	2.393	2.463	2.443	2.285	2.264	2.353	2.372	2.278	2.392	2.490	2.482	2.405	(41)	
(42)		Ebn at Noon	788	892	915	887	878	888	883	842	852	838	792	753	(42)	
(43)		Edh at Noon	62	75	91	120	128	119	115	120	96	72	57	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.25	2.24	3.57	4.94	5.86	6.40	6.96	5.60	4.00	2.48	1.39	0.97	(44)	
(45)		RadStd	0.12	0.19	0.25	0.34	0.42	0.38	0.35	0.35	0.33	0.25	0.10	0.08	(45)	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (54 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page