

DRYDEN, ON, Canada

WMO: 715270

Lat: 49.830N

Lon: 92.740W

Elev: 413

StdP: 96.46

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.2	-28.7	-35.1	0.1	-30.9	-32.6	0.2	-28.4	9.4	-11.5	8.5	-11.9	3.0	250	0.657

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	28.9	19.8	27.2	18.7	25.7	17.9	21.7	26.2	20.6	24.8	19.6	23.6	5.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.2	15.7	24.0	19.2	14.7	22.9	18.1	13.7	21.6	65.7	26.4	61.5	24.8	57.8	23.6	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.4	DB	-34.8	32.1	2.4	1.7	-36.6	33.3	-37.9	34.3	-39.3	35.3	-41.0	36.5	(4)
(5)			WB	-35.0	23.6	2.3	1.1	-36.7	24.4	-38.0	25.1	-39.3	25.7	-41.0	26.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.0	-15.5	-13.6	-5.3	2.8	10.3	16.3	19.4	18.1	13.1	5.0	-3.5	-12.6	(6)	
	DBStd	13.59	7.81	7.16	7.59	5.81	5.25	3.85	3.31	3.50	4.84	5.03	6.43	7.40	(7)	
	HDD10.0	3515	789	662	476	224	62	3	0	1	23	171	404	701	(8)	
	HDD18.3	5747	1048	895	733	467	253	82	27	48	167	413	654	959	(9)	
	CDD10.0	946	0	0	1	7	71	192	291	250	116	17	1	0	(10)	
	CDD18.3	136	0	0	0	0	4	22	59	39	10	1	0	0	(11)	
	CDH23.3	983	0	0	0	1	45	172	433	267	63	2	0	0	(12)	
	CDH26.7	201	0	0	0	0	6	29	99	57	9	0	0	0	(13)	
(14) Wind	WSAvg	3.7	3.5	3.6	3.8	4.0	4.1	3.7	3.6	3.5	3.8	3.9	3.9	3.5	(14)	
(15) Precipitation	PrecAvg	710	31	23	35	44	70	109	106	96	84	61	39	30	(15)	
	PrecMax	898	100	64	88	116	160	215	201	195	174	137	103	61	(16)	
	PrecMin	568	6	4	11	0	16	42	52	48	21	16	7	14	(17)	
	PrecStd	104	21	11	18	31	37	43	35	39	39	33	19	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.7	5.0	15.7	20.5	27.4	29.9	31.7	30.7	28.1	21.9	13.5	3.2	(19)	
		MCWB	1.4	3.1	9.6	11.3	16.1	20.8	21.6	21.5	19.7	14.5	9.8	1.5	(20)	
	2%	DB	0.2	1.9	10.5	17.1	24.3	27.1	29.1	28.2	25.1	17.9	9.7	0.6	(21)	
		MCWB	-0.3	0.4	6.1	9.0	14.3	17.5	19.8	20.1	18.4	12.4	6.8	-0.3	(22)	
	5%	DB	-1.9	-0.2	6.9	14.5	21.8	25.3	27.5	26.2	22.8	15.3	7.0	-0.6	(23)	
		MCWB	-2.6	-1.5	3.3	7.4	13.1	16.8	19.2	18.8	17.1	11.0	5.0	-1.2	(24)	
	10%	DB	-4.2	-2.9	4.2	12.0	19.2	23.5	25.8	24.4	20.6	12.6	4.9	-2.1	(25)	
		MCWB	-4.8	-4.1	1.7	6.1	12.2	16.0	18.2	17.9	16.0	9.7	3.5	-2.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.5	3.4	11.9	12.5	19.0	22.4	23.2	23.2	21.3	15.9	10.6	1.9	(27)	
		MCDB	2.3	4.9	14.0	17.2	23.8	27.3	28.7	28.1	25.8	19.1	12.8	2.6	(28)	
	2%	WB	-0.2	0.6	6.7	10.1	16.8	20.2	21.9	21.4	19.7	13.4	7.4	0.1	(29)	
		MCDB	0.3	1.7	10.3	15.0	20.6	24.5	26.6	25.6	23.1	17.3	9.3	0.5	(30)	
	5%	WB	-2.4	-1.5	3.9	8.3	14.7	18.6	20.7	20.3	18.2	11.6	5.3	-1.2	(31)	
		MCDB	-1.9	-0.3	6.4	13.4	19.4	22.4	24.9	24.5	21.8	14.6	6.8	-0.6	(32)	
	10%	WB	-4.9	-4.1	1.8	6.6	13.2	17.2	19.6	19.1	16.7	9.7	3.3	-2.7	(33)	
		MCDB	-4.3	-3.1	3.9	11.6	17.9	21.3	23.8	23.1	19.6	12.0	4.9	-2.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	10.0	10.4	10.4	10.6	9.9	9.9	9.7	8.8	6.9	6.2	7.4	(35)	
		MCDBR	8.0	9.4	11.4	14.1	13.8	12.5	11.7	11.6	11.4	11.1	8.4	6.8	(36)	
	5% WB	MCWBR	7.4	7.8	7.5	8.2	6.4	5.3	4.9	5.1	5.9	6.7	6.0	6.2	(37)	
		MCWBR	7.7	8.2	10.6	12.5	11.2	9.9	10.0	10.0	10.1	10.0	7.8	6.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.249	0.257	0.292	0.326	0.347	0.364	0.383	0.362	0.348	0.298	0.278	0.254	(40)	
		taud	2.326	2.313	2.341	2.419	2.446	2.428	2.392	2.470	2.485	2.602	2.491	2.341	(41)	
	Ebn at Noon	Ebn at Noon	814	900	921	922	911	894	870	874	851	852	782	751	(42)	
		Edh at Noon	65	85	101	105	107	110	113	99	88	66	57	56	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.18	2.39	3.66	4.93	5.33	5.52	5.72	4.79	3.46	1.99	1.05	0.84	(44)	
	RadStd	RadStd	0.14	0.22	0.30	0.36	0.34	0.45	0.42	0.40	0.32	0.26	0.12	0.10	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (13 neighbors)	N/A	N/A	N/A	N/A	-0.99	-0.92	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page