

IRON SPRINGS AGDM, AB, Canada

WMO: 715280

Lat: 49.9005N

Lon: 112.7452W

Elev: 893

StdP: 91.05

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-27.2	-24.2	-30.6	0.2	-27.1	-27.4	0.3	-24.2	16.5	5.5	15.2	5.6	3.4	260	0.708

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	30.3	17.1	28.5	16.4	26.7	16.0	19.3	26.6	18.2	25.6	17.1	24.4	3.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	13.2	23.3	15.4	12.2	22.1	14.1	11.2	20.4	59.1	26.7	55.2	25.6	51.4	24.3	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.2	13.1	11.4	DB	-32.1	34.0	3.2	2.0	-34.4	35.4	-36.3	36.6	-38.1	37.7	-40.4	39.1	(4)
(5)			WB	-32.1	22.1	3.2	1.4	-34.4	23.1	-36.3	23.9	-38.1	24.7	-40.4	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	-5.3	-6.2	-0.2	5.5	11.3	15.0	18.2	17.3	12.8	6.2	-0.5	-6.3	(6)
(7)		DBStd	10.73	8.62	8.55	7.41	5.03	4.35	3.09	2.72	3.18	4.54	5.19	7.45	8.32	(7)
(8)		HDD10.0	2412	475	453	317	148	37	2	0	1	23	136	316	506	(8)
(9)		HDD18.3	4677	733	686	574	387	221	108	36	57	172	376	564	764	(9)
(10)		CDD10.0	851	0	0	1	12	77	151	254	227	107	19	2	0	(10)
(11)		CDD18.3	73	0	0	0	0	2	7	32	26	6	0	0	0	(11)
(12)		CDH23.3	1399	0	0	0	9	93	147	514	464	168	4	0	0	(12)
(13)		CDH26.7	387	0	0	0	1	17	31	147	146	46	0	0	0	(13)
(14)	Wind	WSAvg	5.0	6.1	4.9	5.3	5.4	4.9	4.6	3.7	4.3	5.2	5.8	5.7	(14)	
(15)	Precipitation	PrecAvg	377	12	9	15	27	63	91	40	36	32	23	14	14	(15)
(16)		PrecMax	585	26	20	35	74	112	247	132	99	117	73	32	32	(16)
(17)		PrecMin	196	4	0	0	10	19	20	3	0	5	5	2	0	(17)
(18)		PrecStd	104	6	6	10	14	25	53	31	24	26	16	8	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	13.6	17.2	24.5	28.7	30.3	32.5	32.5	30.5	23.4	17.8	11.2	(19)
(20)			MCWB	5.7	5.8	7.6	11.3	13.3	17.6	18.6	16.4	15.0	11.6	9.0	5.3	(20)
(21)		2%	DB	9.3	10.0	14.8	20.3	26.1	26.9	30.2	30.2	27.9	20.0	13.5	8.6	(21)
(22)			MCWB	4.6	4.2	6.9	9.3	13.0	15.9	18.6	16.4	14.3	10.6	7.1	3.6	(22)
(23)		5%	DB	7.3	7.2	12.5	17.3	23.3	24.8	28.2	28.1	25.1	17.1	11.1	6.6	(23)
(24)			MCWB	3.2	2.5	5.6	7.8	12.0	15.3	17.9	15.8	13.6	9.3	5.8	2.5	(24)
(25)		10%	DB	5.3	5.1	9.9	14.6	20.7	22.7	26.3	26.0	21.9	14.5	8.9	4.7	(25)
(26)			MCWB	1.9	1.3	4.3	6.7	10.8	14.2	17.3	15.7	12.4	8.0	4.4	1.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	6.5	8.9	11.6	15.0	19.5	22.0	19.5	16.7	12.9	9.9	6.2	(27)
(28)			MCDB	11.1	11.9	15.6	22.0	25.8	26.3	28.7	27.3	26.3	20.7	16.7	10.3	(28)
(29)		2%	WB	4.8	4.3	7.3	9.8	13.5	17.6	20.2	18.2	15.1	11.2	7.7	4.0	(29)
(30)			MCDB	9.0	9.4	13.8	19.2	24.1	25.0	27.5	26.6	25.3	18.8	12.8	7.5	(30)
(31)		5%	WB	3.4	2.8	5.9	8.3	12.5	16.1	19.0	17.1	14.0	9.7	6.0	2.6	(31)
(32)			MCDB	6.9	7.0	11.7	16.1	21.9	23.0	26.1	25.6	23.6	16.1	10.7	5.9	(32)
(33)		10%	WB	2.0	1.4	4.5	7.0	11.4	14.9	18.0	16.1	12.9	8.3	4.5	1.2	(33)
(34)			MCDB	5.1	4.9	9.6	13.8	19.4	21.5	25.0	24.0	21.4	14.0	8.6	4.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.1	11.0	11.5	12.7	13.1	12.5	14.4	14.8	13.9	12.2	10.6	9.8	(35)
(36)			MCDBR	10.1	13.7	15.3	18.2	17.9	16.6	17.8	19.6	19.7	16.2	13.0	10.4	(36)
(37)			MCWBR	6.8	8.8	8.8	9.1	7.7	7.8	8.8	8.2	8.3	8.4	7.9	7.1	(37)
(38)		5% WB	MCDBR	9.9	13.2	14.7	16.9	16.0	15.2	16.3	16.6	18.4	15.4	12.5	10.7	(38)
(39)			MCWBR	7.0	8.9	8.9	8.9	7.2	7.9	8.8	7.9	8.1	8.3	8.1	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.251	0.260	0.284	0.320	0.335	0.332	0.334	0.351	0.312	0.280	0.256	0.235	(40)	
(41)		taud	2.462	2.496	2.487	2.389	2.400	2.455	2.463	2.395	2.476	2.542	2.507	2.460	(41)	
(42)		Ebn at Noon	827	909	937	926	923	926	917	884	890	870	815	800	(42)	
(43)		Edh at Noon	58	72	87	108	112	107	104	107	88	68	55	50	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.23	2.23	3.51	4.84	5.77	6.39	7.00	5.58	3.96	2.46	1.36	0.96	(44)	
(45)		RadStd	0.10	0.18	0.28	0.33	0.46	0.45	0.36	0.35	0.34	0.26	0.11	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (69 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page