

LUTSELK'E, NT, Canada

WMO: 715290

Lat: 62.416N

Lon: 110.690W

Elev: 587

StdP: 14.39

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-39.1	-35.4	-47.8	0.3	-38.8	-43.6	0.4	-35.1	21.2	-7.0	19.3	-4.7	4.7	70	0.765

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	77.8	60.5	74.3	58.8	71.0	57.6	62.6	73.7	60.7	71.2	58.9	68.4	7.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.1	73.6	65.8	56.0	68.2	64.8	54.0	63.5	63.5	28.5	73.7	27.2	71.3	25.9	68.5	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	18.1	15.9	DB	-42.0	83.6	4.1	3.3	-44.9	86.0	-47.3	87.9	-49.7	89.8	-52.7	92.2
			WB	-42.1	66.7	4.1	2.2	-45.1	68.3	-47.5	69.6	-49.8	70.8	-52.8	72.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	24.1	-11.9	-10.0	1.2	19.3	37.6	53.0	59.9	55.5	45.4	30.8	12.4	-5.8	(6)
(7)		DBStd	27.97	14.55	13.49	16.25	14.38	10.84	8.13	6.49	6.84	7.73	8.03	10.50	14.65	(7)
(8)		HDD50	10153	1919	1679	1511	920	403	60	4	24	181	594	1129	1729	(8)
(9)		HDD65	14956	2384	2099	1976	1370	850	365	185	306	589	1059	1579	2194	(9)
(10)		CDD50	717	0	0	0	0	18	152	311	193	42	1	0	0	(10)
(11)		CDD65	44	0	0	0	0	0	7	27	10	0	0	0	0	(11)
(12)		CDH74	326	0	0	0	0	2	56	188	79	1	0	0	0	(12)
(13)		CDH80	39	0	0	0	0	0	3	26	10	0	0	0	0	(13)
(14)	Wind	WSAvg	7.1	5.9	5.9	6.9	8.0	8.7	7.2	6.4	6.8	7.7	7.5	7.7	6.0	(14)
(15)	Precipitation	PrecAvg	13.8	0.6	0.5	0.6	0.6	0.9	1.6	2.1	2.2	1.8	1.2	0.9	0.7	(15)
(16)		PrecMax	18.0	1.1	0.9	1.2	1.1	1.8	3.7	4.2	4.0	3.6	2.3	1.5	1.1	(16)
(17)		PrecMin	10.0	0.1	0.1	0.3	0.1	0.2	0.3	0.8	0.9	0.6	0.4	0.4	0.3	(17)
(18)		PrecStd	1.5	0.3	0.2	0.2	0.2	0.4	0.8	0.7	0.7	0.7	0.4	0.3	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	27.7	43.1	54.7	71.5	79.6	83.6	80.9	70.0	55.6	37.9	28.3	(19)
(20)		0.4%	MCWB	25.9	25.8	36.0	43.2	54.0	60.2	62.6	62.9	57.9	47.7	34.8	26.8	(20)
(21)		2%	DB	22.0	19.4	36.0	48.4	64.3	75.0	78.8	75.7	64.9	48.9	33.3	23.9	(21)
(22)		2%	MCWB	21.1	18.3	31.4	39.5	49.2	57.6	61.2	60.3	54.3	43.0	31.5	22.5	(22)
(23)		5%	DB	14.9	14.5	31.1	43.7	58.9	71.4	75.4	71.6	60.8	44.8	30.2	19.3	(23)
(24)		5%	MCWB	14.1	13.4	28.0	36.9	46.4	56.0	59.9	58.4	52.2	41.0	28.7	18.1	(24)
(25)		10%	DB	9.4	10.1	25.7	39.2	53.7	67.5	72.0	67.8	57.1	41.4	26.9	15.2	(25)
(26)		10%	MCWB	8.7	9.1	23.2	34.3	43.5	54.1	58.6	57.2	50.8	38.4	25.5	14.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	25.9	36.4	43.9	54.3	62.5	65.6	64.5	58.6	48.5	34.9	26.8	(27)
(28)		0.4%	MCDWB	27.6	27.6	41.8	53.3	68.9	74.1	77.6	77.9	67.6	55.1	37.3	27.8	(28)
(29)		2%	WB	21.0	18.3	31.7	39.9	49.9	59.4	63.2	61.9	55.3	43.5	31.7	22.7	(29)
(30)		2%	MCDWB	21.9	19.4	35.6	47.7	63.2	71.3	74.7	72.3	63.0	47.3	33.3	23.9	(30)
(31)		5%	WB	14.1	13.4	28.0	36.9	47.0	57.3	61.5	59.9	53.2	41.1	28.8	18.3	(31)
(32)		5%	MCDWB	14.8	14.5	31.1	43.0	58.3	68.9	72.5	68.7	59.6	45.2	30.2	19.4	(32)
(33)		10%	WB	8.7	9.1	23.3	34.5	44.0	55.3	59.8	58.0	51.1	38.6	25.6	14.2	(33)
(34)		10%	MCDWB	9.4	10.1	25.7	38.8	52.8	66.5	70.0	66.1	56.4	41.2	26.9	15.1	(34)
(35)	Mean Daily Temperature Range		MDBR	14.3	16.4	19.9	20.8	18.4	19.3	18.1	16.2	12.5	9.0	9.5	12.9	(35)
(36)		5% DB	MCDBR	15.7	18.4	21.3	22.2	25.9	24.2	22.4	22.5	18.5	13.9	9.7	13.0	(36)
(37)			MCWBR	15.2	17.6	17.8	15.3	15.2	12.9	11.5	11.6	10.9	10.1	9.1	12.5	(37)
(38)			5% WB	MCDWB	15.8	18.4	21.0	20.9	24.3	22.3	19.6	19.4	17.1	13.2	9.7	12.9
(39)		MCWBR		15.1	17.6	17.7	14.7	14.6	12.7	11.0	10.9	10.8	9.9	9.2	12.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.181	0.235	0.258	0.307	0.337	0.349	0.371	0.343	0.308	0.266	0.191	0.147	(40)	
(41)		taud	2.052	2.241	2.274	2.251	2.413	2.439	2.425	2.489	2.576	2.437	2.046	1.946	(41)	
(42)		Ebn at Noon	171	239	275	279	280	278	267	266	258	226	157	122	(42)	
(43)		Edh at Noon	10	19	27	34	32	32	32	27	21	16	10	6	(43)	
(44)	All-Sky Solar Radiation	RadAvg	87	339	884	1559	1812	1919	1713	1271	768	296	88	39	(44)	
(45)		RadStd	8	29	62	85	128	149	73	75	59	32	10	3	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page