

JEAN COTE AGCM, AB, Canada

WMO: 715410

Lat: 55.9128N

Lon: 117.1197W

Elev: 2093

StdP: 13.62

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-22.6	-17.9	-29.0	1.2	-22.5	-24.0	1.6	-17.7	25.6	34.2	22.6	30.7	6.1	210	0.677

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	81.8	61.4	78.3	60.0	75.4	59.1	64.8	76.1	63.0	74.4	61.2	71.8	7.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.4	84.8	69.7	58.5	79.2	67.6	56.7	74.1	65.4	30.9	75.5	29.5	74.8	28.3	71.8	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.3	18.9	16.7	DB	-29.6	86.2	4.4	2.8	-32.8	88.2	-35.4	89.9	-37.9	91.4	-41.1	93.4	(4)
(5)			WB	-29.8	67.4	4.4	3.0	-33.0	69.5	-35.5	71.3	-38.0	72.9	-41.1	75.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.5	12.3	11.9	22.3	37.3	51.3	58.0	61.5	59.9	51.1	38.3	21.4	10.6		
	DBStd	21.84	15.48	14.86	14.00	9.18	8.21	6.10	5.09	6.26	8.16	8.76	11.72	13.58		
	HDD50	6121	1168	1066	860	393	84	9	0	5	82	376	857	1221		
	HDD65	10477	1633	1486	1325	832	427	220	133	180	419	829	1307	1686		
	CDD50	1179	0	0	0	11	125	250	355	311	115	12	0	0		
	CDD65	61	0	0	0	0	3	11	23	22	2	0	0	0		
	CDH74	955	0	0	0	7	87	172	321	302	66	0	0	0		
	CDH80	170	0	0	0	1	16	26	52	68	7	0	0	0		
	WSAvg	8.1	9.0	8.3	8.2	8.8	8.9	7.9	6.8	6.9	7.6	8.4	8.2	8.4		
	PrecAvg	18.0	1.2	0.8	0.7	0.7	1.7	2.8	2.7	2.3	1.5	1.0	1.2	1.1		
(15) Precipitation	PrecMax	26.1	3.3	1.7	1.6	1.4	4.3	5.6	4.1	4.7	4.6	2.2	2.5	2.4		
	PrecMin	10.8	0.4	0.3	0.1	0.1	0.5	1.2	0.6	0.8	0.1	0.4	0.4	0.2		
	PrecStd	3.7	0.8	0.4	0.4	0.4	1.1	1.2	1.2	1.1	1.0	0.5	0.7	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	42.5	50.2	72.0	82.4	83.6	85.3	86.7	80.4	69.7	51.7	40.1		
		MCWB	36.8	36.5	41.7	51.1	55.7	61.2	65.3	64.0	60.7	53.3	44.0	34.9		
	2%	DB	40.0	38.7	46.1	62.4	75.6	78.5	80.7	81.3	75.1	60.4	43.9	36.5		
		MCWB	35.7	34.5	38.2	45.5	52.8	58.4	61.9	62.4	57.7	48.7	38.7	32.7		
	5%	DB	37.7	35.6	42.2	56.1	71.3	75.2	77.5	77.0	70.3	55.1	39.9	33.6		
		MCWB	34.2	32.3	35.8	42.9	51.1	57.5	61.5	60.7	56.1	45.0	35.8	30.1		
	10%	DB	34.3	32.1	39.1	51.2	67.6	71.7	74.5	73.4	65.0	51.2	36.1	29.8		
		MCWB	31.4	29.3	33.8	40.3	49.4	56.0	60.3	59.7	53.1	42.9	33.0	27.1		
	0.4%	WB	37.4	37.1	42.2	51.9	57.5	64.2	68.1	66.6	62.2	54.8	44.1	35.4		
		MCDB	41.4	41.8	49.6	71.4	75.7	78.3	80.3	79.9	77.8	66.2	50.6	39.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.9	34.9	38.8	46.9	54.8	61.6	65.5	64.4	59.2	49.7	39.4	33.0		
		MCDB	39.6	38.3	45.3	61.2	70.0	73.7	75.9	76.6	71.6	59.3	43.5	36.4		
	5%	WB	34.3	32.4	36.2	43.3	52.7	59.3	63.6	62.8	56.7	46.2	35.9	30.3		
		MCDB	37.6	35.5	41.6	54.3	68.0	70.9	73.8	74.5	67.9	53.0	39.0	33.6		
	10%	WB	31.3	29.2	34.1	40.9	50.9	57.3	61.7	60.9	54.4	43.7	33.2	27.1		
		MCDB	34.2	31.9	38.8	50.3	64.8	68.9	71.8	71.1	64.0	50.1	35.8	29.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.4	15.0	16.7	18.5	23.1	20.3	21.3	21.9	20.7	16.0	13.2	13.2		
		MCDBR	14.5	15.2	17.9	26.3	28.9	26.1	26.5	26.8	28.1	22.3	16.2	16.1		
		MCWBR	11.8	12.0	11.9	14.1	12.3	11.0	12.2	11.5	13.0	12.8	11.7	13.8		
	5% WB	MCDBR	13.8	14.5	17.2	24.7	26.3	22.6	23.6	24.6	26.3	21.2	15.3	16.4		
		MCWBR	11.4	11.6	11.8	14.0	11.9	10.7	12.4	11.9	12.9	12.8	11.6	14.1		
(40) Clear-Sky Solar Irradiance	taub		0.235	0.245	0.284	0.326	0.339	0.347	0.349	0.346	0.307	0.281	0.241	0.227		
	taud		2.301	2.353	2.346	2.377	2.407	2.407	2.427	2.414	2.532	2.563	2.431	2.223		
	Ebn at Noon		227	272	283	285	286	284	281	275	274	257	227	196		
	Edh at Noon		16	22	29	33	34	35	33	31	24	18	14	13		
(44) All-Sky Solar Radiation	RadAvg		232	546	1040	1490	1779	1907	1861	1513	1031	553	246	160		
	RadStd		23	46	86	95	133	148	121	124	84	68	20	13		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+103	N/A

Nomenclature: See separate page