

LA CRETE AGCM, AB, Canada

WMO: 715420

Lat: 58.1719N

Lon: 116.3428W

Elev: 323

StdP: 97.50

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-33.3	-30.8	-37.1	0.1	-33.2	-34.4	0.2	-30.7	10.6	-6.6	9.4	-7.5	1.4	250	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	28.7	16.9	26.8	16.3	25.2	15.5	18.6	25.4	17.7	24.4	16.8	23.3	3.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	11.8	21.3	15.0	11.1	20.2	14.2	10.5	19.5	53.9	25.4	50.9	24.5	48.4	23.4	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.4	7.4	-37.1	31.7	2.4	2.5	-38.8	33.5	-40.2	35.0	-41.5	36.4	-43.2	38.3		
			-37.2	20.6	2.4	1.3	-38.9	21.5	-40.3	22.3	-41.6	23.1	-43.3	24.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.0	-16.1	-15.2	-8.3	2.2	11.5	15.8	17.9	16.2	10.6	2.4	-9.4	-16.8	(6)
(7)		DBStd	14.27	7.95	7.56	8.20	6.01	4.90	3.65	2.71	3.44	4.34	4.88	7.19	8.14	(7)
(8)		HDD10.0	4066	809	705	566	242	41	4	0	2	43	239	582	831	(8)
(9)		HDD18.3	6391	1068	938	824	486	216	88	42	83	232	493	832	1089	(9)
(10)		CDD10.0	779	0	0	0	7	88	179	244	194	62	5	0	0	(10)
(11)		CDD18.3	61	0	0	0	0	4	13	27	16	1	0	0	0	(11)
(12)		CDH23.3	842	0	0	0	4	92	174	318	218	35	1	0	0	(12)
(13)		CDH26.7	177	0	0	0	0	18	34	71	49	5	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.2	3.1	3.3	3.8	3.7	3.3	2.8	2.9	3.0	3.2	3.1	3.0	(14)
(15)	Precipitation	PrecAvg	409	19	16	17	16	35	67	81	54	38	25	21	19	(15)
(16)		PrecMax	552	43	27	36	38	67	143	158	101	91	52	39	42	(16)
(17)		PrecMin	321	4	4	3	5	8	20	50	12	9	7	8	7	(17)
(18)		PrecStd	62	8	6	7	7	13	24	26	18	16	11	9	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	7.5	10.9	22.9	29.1	29.8	31.5	30.6	27.1	20.1	10.4	5.8	(19)
(20)			MCWB	2.9	3.0	5.0	11.6	14.1	16.7	18.0	17.7	16.5	11.4	5.9	1.9	(20)
(21)		2%	DB	4.1	3.2	8.1	16.7	25.8	27.3	28.6	27.9	23.8	15.1	6.1	2.3	(21)
(22)			MCWB	1.2	0.8	3.3	7.7	12.6	15.8	17.6	17.3	15.2	8.2	2.5	-0.1	(22)
(23)		5%	DB	1.0	-0.6	5.5	14.0	23.6	25.3	26.6	25.7	20.8	12.0	3.5	-0.9	(23)
(24)			MCWB	-1.2	-2.5	1.7	6.1	11.4	15.2	17.1	16.4	13.2	6.8	0.7	-2.5	(24)
(25)		10%	DB	-3.7	-4.5	3.2	11.3	21.3	23.4	24.9	23.8	18.3	9.7	0.7	-5.4	(25)
(26)			MCWB	-4.5	-5.7	0.3	5.1	10.7	14.2	16.2	15.5	11.6	5.5	-0.9	-6.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	3.1	5.1	11.8	14.7	19.0	20.1	19.7	17.5	12.9	6.2	1.8	(27)
(28)			MCDWB	6.0	6.5	10.7	22.6	25.7	25.9	27.4	27.4	25.5	19.6	10.5	4.9	(28)
(29)		2%	WB	1.4	0.9	3.5	8.3	13.4	17.4	18.7	18.3	15.6	9.1	2.8	-0.1	(29)
(30)			MCDWB	4.1	3.4	7.5	15.9	23.9	23.7	25.5	25.2	22.4	14.1	5.8	2.4	(30)
(31)		5%	WB	-1.1	-2.3	2.0	6.6	12.1	16.4	18.0	17.2	14.0	7.2	1.0	-2.7	(31)
(32)			MCDWB	0.7	-0.6	5.3	12.7	21.9	22.8	24.8	23.9	19.1	11.2	3.2	-1.2	(32)
(33)		10%	WB	-4.6	-5.7	0.3	5.3	11.0	15.5	17.1	16.3	12.6	5.7	-0.8	-6.1	(33)
(34)			MCDWB	-3.6	-4.5	3.0	11.0	19.9	21.7	23.8	22.4	17.3	9.2	0.8	-5.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	9.0	10.4	11.0	13.2	11.4	11.9	12.0	11.8	7.9	7.1	7.8	(35)
(36)			MCDBR	12.3	12.9	11.4	14.9	16.8	14.8	14.9	15.4	16.1	12.8	9.9	12.9	(36)
(37)			MCWBR	10.0	10.6	7.8	7.8	7.2	6.1	6.7	6.6	8.2	7.6	7.4	10.8	(37)
(38)		5% WB	MCDWB	12.4	12.8	10.9	14.1	15.2	12.5	14.3	14.2	14.9	12.2	9.5	12.4	(38)
(39)			MCWBR	10.5	10.6	7.5	7.8	6.8	5.9	6.9	6.8	7.9	7.6	7.4	10.7	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.222	0.246	0.270	0.330	0.342	0.360	0.366	0.349	0.310	0.283	0.235	0.205	(41)	
(42)		taud	2.250	2.318	2.320	2.354	2.423	2.401	2.397	2.437	2.547	2.561	2.352	2.137	(42)	
(43)		Ebn at Noon	668	819	892	881	892	877	861	853	844	776	650	553	(43)	
(44)		Edh at Noon	43	66	89	103	103	108	106	95	73	54	39	34	(44)	
(45)	All-Sky Solar Radiation	RadAvg	0.58	1.51	3.16	4.84	5.69	5.95	5.64	4.59	3.11	1.54	0.61	0.35	(45)	
		RadStd	0.04	0.11	0.20	0.23	0.43	0.47	0.27	0.32	0.22	0.19	0.06	0.03		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	+1.88	+2.45	N/A	N/A	N/A	N/A	N/A	+55	N/A

Nomenclature: See separate page