

TAWATINAW AGCM, AB, Canada

WMO: 715490

Lat: 54.300N

Lon: 113.520W

Elev: 2005

StdP: 13.66

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-23.8	-18.2	-30.2	1.1	-23.3	-24.8	1.5	-18.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	80.8	62.5	78.1	61.1	75.5	59.9	66.0	75.9	63.9	73.9	62.1	71.8	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.2	90.2	71.9	60.0	83.2	68.7	58.2	78.0	66.6	31.9	76.1	30.2	74.1	28.9	72.0	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-30.1	86.7	4.2	1.2	-33.1	87.6	-35.6	88.3	-38.0	89.0	-41.1	89.9		
(5)			-30.3	70.7	4.2	3.0	-33.3	72.9	-35.8	74.6	-38.1	76.3	-41.2	78.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.9	12.3	11.9	23.2	38.1	51.9	58.6	62.1	60.2	51.6	39.1	23.1	9.1		
	DBStd	22.02	15.62	14.56	13.49	9.11	8.37	5.63	4.68	5.73	8.08	8.60	12.24	13.50		
	HDD50	6026	1169	1068	830	369	79	7	0	3	75	351	806	1269		
	HDD65	10314	1634	1488	1295	808	410	201	114	168	403	803	1256	1734		
	CDD50	1246	0	0	0	11	138	265	377	318	124	13	0	0		
	CDD65	59	0	0	0	0	4	9	25	18	3	0	0	0		
	CDH74	868	0	0	0	3	108	140	307	220	88	2	0	0		
	CDH80	102	0	0	0	0	17	12	38	23	12	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	PrecAvg	17.0	0.9	0.4	0.7	1.0	1.9	3.2	3.2	2.2	1.4	0.7	0.8	0.7		
(15) Precipitation	PrecMax	21.2	3.7	0.9	1.5	1.9	3.1	5.3	6.3	4.6	3.1	1.3	2.8	1.3		
	PrecMin	12.6	0.0	0.0	0.1	0.0	0.3	1.3	1.5	0.9	0.2	0.1	0.1	0.0		
	PrecStd	2.8	0.9	0.3	0.4	0.5	0.7	1.1	1.2	0.9	0.7	0.4	0.7	0.4		
	PrecStd	2.8	0.9	0.3	0.4	0.5	0.7	1.1	1.2	0.9	0.7	0.4	0.7	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.2	43.2	52.4	72.5	82.4	81.6	83.6	82.8	81.7	70.4	52.5	40.2		
		MCWB	36.8	37.1	42.2	50.8	55.7	60.6	67.6	63.9	60.9	53.3	43.9	34.8		
	2%	DB	40.3	38.6	46.2	63.3	76.8	78.0	80.5	79.5	76.1	61.7	45.5	35.9		
		MCWB	35.2	33.9	38.4	46.1	53.7	59.2	65.0	63.9	58.8	48.6	39.8	31.3		
	5%	DB	37.5	35.4	42.2	57.8	72.1	74.7	77.4	76.3	71.7	56.5	41.5	32.1		
		MCWB	33.3	31.5	36.2	43.9	52.0	57.8	63.1	62.2	57.1	45.8	36.6	29.0		
	10%	DB	34.1	32.3	38.8	53.0	68.3	71.4	74.4	73.1	66.4	52.3	37.5	27.6		
		MCWB	30.9	29.4	33.8	41.4	50.2	56.8	61.7	61.0	54.3	43.6	34.2	25.2		
	0.4%	WB	37.3	37.4	43.1	51.6	57.7	64.6	70.1	68.6	62.9	54.1	44.7	35.5		
		MCDB	42.1	42.0	50.2	71.9	72.9	75.5	80.8	78.3	77.5	67.8	51.2	39.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.7	34.4	39.1	47.1	55.7	62.0	66.9	65.7	60.2	50.0	40.2	31.8		
		MCDB	39.7	37.9	45.1	61.6	71.5	72.5	77.0	75.3	72.8	59.1	45.2	35.4		
	5%	WB	33.5	31.9	36.4	44.3	53.8	60.1	64.8	63.6	57.6	46.9	37.1	28.6		
		MCDB	37.3	35.1	41.8	56.0	69.5	70.4	74.8	73.1	69.8	55.2	40.7	31.8		
	10%	WB	30.9	29.2	34.1	42.0	51.8	58.4	62.8	61.8	55.4	44.4	34.2	25.3		
		MCDB	34.3	32.4	38.5	51.5	65.0	68.3	72.1	71.1	65.1	50.9	37.1	27.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.9	16.4	16.0	18.4	22.3	20.0	20.5	21.1	21.3	16.8	12.8	13.5		
		MCDBR	15.2	18.1	18.2	26.6	28.8	25.1	25.4	25.6	30.1	23.9	16.4	17.2		
		MCWBR	11.4	14.5	11.9	13.9	12.1	10.5	12.6	11.9	14.4	13.4	11.6	14.7		
		MCDBR	15.6	17.6	17.6	25.0	26.2	21.8	23.4	23.2	28.0	22.9	15.3	16.6		
	5% WB	MCWBR	12.3	14.5	11.8	13.4	11.4	10.2	12.5	11.8	13.6	13.4	11.4	14.5		
		MCWBR	12.3	14.5	11.8	13.4	11.4	10.2	12.5	11.8	13.6	13.4	11.4	14.5		
(40) Clear-Sky Solar Irradiance	taub		0.255	0.275	0.307	0.326	0.341	0.353	0.355	0.361	0.307	0.282	0.252	0.236		
	taud		2.273	2.288	2.299	2.389	2.403	2.376	2.424	2.351	2.515	2.553	2.451	2.303		
	Ebn at Noon		226	261	277	287	287	283	281	271	277	261	234	212		
	Edh at Noon		18	25	31	33	35	36	34	34	25	19	15	14		
(44) All-Sky Solar Radiation	RadAvg		273	598	1077	1476	1800	1884	1906	1564	1079	607	283	198		
	RadStd		31	43	81	123	148	127	102	111	111	80	31	17		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page