

FANNY ISLAND, BC, Canada

WMO: 715680

Lat: 50.4536N

Lon: 125.9930W

Elev: 5

StdP: 101.26

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.9	-1.1	-11.5	1.4	-0.2	-7.5	2.0	0.2	16.5	5.6	14.2	5.9	5.2	50	0.769

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	19.7	13.9	17.8	13.8	16.6	13.4	15.2	18.0	14.5	16.8	13.8	15.9	4.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	9.9	16.0	13.2	9.5	15.4	12.7	9.1	14.9	42.4	18.3	40.5	16.9	38.8	16.0	19.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	13.2	12.2	DB	-5.4	25.7	2.6	2.4	-7.3	27.4	-8.8	28.8	-10.3	30.1	-12.2	31.8	(4)
(5)			WB	-6.7	17.1	2.6	0.8	-8.6	17.7	-10.2	18.2	-11.7	18.7	-13.6	19.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	4.5	5.0	6.1	8.2	10.7	12.4	13.8	14.0	12.6	9.7	6.5	4.3	(6)	
	DBStd	4.11	2.81	2.29	2.25	2.01	2.04	1.74	1.43	1.29	1.57	1.85	2.61	2.51	(7)	
	HDD10.0	822	169	140	123	60	14	1	0	0	1	28	108	178	(8)	
	HDD18.3	3404	427	373	380	303	236	177	141	133	173	268	356	436	(9)	
	CDD10.0	459	0	0	1	7	37	74	117	126	77	18	3	0	(10)	
	CDD18.3	2	0	0	0	0	0	1	1	1	0	0	0	0	(11)	
	CDH23.3	13	0	0	0	0	1	4	3	4	1	0	0	0	(12)	
	CDH26.7	3	0	0	0	0	0	1	1	1	0	0	0	0	(13)	
(14) Wind	WSAvg	5.7	4.8	4.7	5.0	5.4	6.4	6.9	7.9	7.1	5.3	4.7	4.8	4.9	(14)	
(15) Precipitation	PrecAvg	2091	274	166	170	147	101	92	64	74	106	254	320	300	(15)	
	PrecMax	2598	435	427	305	333	215	192	129	166	275	391	514	440	(16)	
	PrecMin	1578	141	2	17	41	42	38	8	5	20	53	141	150	(17)	
	PrecStd	264	85	93	65	80	41	41	35	48	58	102	106	71	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	11.0	12.8	18.4	21.2	22.9	21.6	21.5	21.0	16.3	13.1	11.1	(19)	
		MCWB	9.8	8.3	9.4	10.8	12.4	14.3	15.6	15.2	14.9	13.1	11.4	9.6	(20)	
	2%	DB	10.0	9.8	11.1	14.0	17.1	18.2	18.4	18.3	17.5	14.4	11.9	9.3	(21)	
		MCWB	8.6	7.6	8.3	9.5	11.6	13.5	14.6	14.4	13.9	12.2	10.5	7.9	(22)	
	5%	DB	9.0	8.8	10.0	12.2	14.6	16.1	16.9	17.1	15.9	13.1	10.9	8.1	(23)	
		MCWB	7.6	6.9	7.7	8.8	11.1	12.6	13.9	14.1	13.2	11.3	9.7	6.8	(24)	
	10%	DB	8.0	8.0	9.1	10.9	13.4	14.7	15.8	16.0	14.7	12.1	9.9	7.4	(25)	
		MCWB	6.8	6.4	7.2	8.2	10.6	12.1	13.3	13.6	12.6	10.5	8.6	6.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	9.2	10.5	11.7	13.5	15.0	16.0	16.2	15.7	13.9	11.3	9.8	(27)	
		MCDB	11.1	10.2	12.2	16.4	17.6	19.9	19.6	19.8	19.0	15.8	12.2	11.0	(28)	
	2%	WB	8.9	8.0	8.9	10.2	12.4	13.7	15.1	15.1	14.5	12.6	10.3	8.1	(29)	
		MCDB	9.9	9.4	10.4	12.9	15.8	16.5	17.8	17.4	17.0	14.0	11.3	9.2	(30)	
	5%	WB	7.8	7.2	8.0	9.3	11.6	13.0	14.3	14.3	13.7	11.6	9.5	7.0	(31)	
		MCDB	8.9	8.4	9.6	11.4	14.3	15.7	16.6	16.4	15.5	12.9	10.4	7.9	(32)	
	10%	WB	6.8	6.6	7.3	8.6	10.7	12.3	13.6	13.7	12.9	10.7	8.6	6.3	(33)	
		MCDB	7.9	7.8	9.0	10.5	13.0	14.6	15.5	15.6	14.3	12.0	9.6	7.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.8	3.5	4.0	4.6	4.7	4.4	4.5	4.5	4.4	3.3	3.0	2.6	(35)	
		MCDBR	3.1	4.6	5.2	7.4	7.8	7.4	6.6	6.5	7.0	4.8	3.0	2.8	(36)	
	5% WB	MCWBR	2.4	3.1	3.3	3.8	3.8	3.6	3.6	3.6	3.7	3.1	2.6	2.3	(37)	
		MCWBR	2.9	3.6	4.3	6.1	6.7	6.6	6.5	6.0	6.4	4.3	2.8	2.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.313	0.317	0.346	0.364	0.378	0.378	0.365	0.366	0.342	0.370	0.321	0.308	(40)	
		taud	2.408	2.483	2.414	2.375	2.379	2.417	2.492	2.501	2.560	2.357	2.457	2.380	(41)	
	Ebn at Noon		720	827	859	879	879	880	887	869	858	738	706	663	(42)	
		Edh at Noon	63	74	95	110	114	111	102	96	82	84	60	56	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.75	1.60	2.41	3.75	4.92	5.22	5.66	4.91	3.40	1.81	0.87	0.60	(44)	
	RadStd		0.12	0.29	0.35	0.37	0.55	0.59	0.68	0.42	0.31	0.32	0.17	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page