

BRATT'S LAKE, SK, Canada

WMO: 715690

Lat: 50.201N

Lon: 104.710W

Elev: 580

StdP: 94.55

Time Zone: -6.00 (W06)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-32.2	-29.5	-35.8	0.1	-32.2	-32.9	0.2	-29.4	14.4	-11.0	13.1	-10.8	4.4	270	0.760

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	30.7	17.4	28.7	16.8	26.9	16.2	20.1	26.1	18.9	25.2	17.9	24.2	5.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.1	14.0	22.9	16.7	12.8	21.6	15.6	11.9	20.5	60.7	26.2	56.2	25.1	52.9	24.5	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.6	10.4	DB	-36.4	34.9	3.0	2.0	-38.6	36.3	-40.4	37.5	-42.1	38.6	-44.3	40.1	(4)
(5)			WB	-36.6	22.7	2.9	1.5	-38.7	23.8	-40.4	24.7	-42.1	25.6	-44.2	26.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.8	-13.1	-13.9	-5.9	2.9	10.7	15.9	18.4	17.4	12.4	4.4	-4.2	-12.5	(6)
(7)		DBStd	13.26	8.26	8.35	8.13	5.74	4.80	3.26	2.89	3.27	4.57	4.77	6.80	7.95	(7)
(8)		HDD10.0	3481	714	668	494	217	51	2	0	0	25	184	427	698	(8)
(9)		HDD18.3	5754	973	902	752	462	238	84	36	58	184	433	677	956	(9)
(10)		CDD10.0	854	0	0	0	6	73	180	259	229	97	9	0	0	(10)
(11)		CDD18.3	86	0	0	0	0	3	12	37	28	6	0	0	0	(11)
(12)		CDH23.3	1512	0	0	0	6	126	221	478	490	188	3	0	0	(12)
(13)		CDH26.7	437	0	0	0	1	31	49	137	158	61	0	0	0	(13)
(14)	Wind	WSAvg	5.2	5.8	5.2	5.6	5.7	5.7	5.1	4.3	4.2	4.8	5.3	5.4	5.2	(14)
(15)	Precipitation	PrecAvg	383	13	9	15	26	52	75	59	54	28	25	13	13	(15)
(16)		PrecMax	553	37	19	47	72	130	165	148	115	65	80	35	38	(16)
(17)		PrecMin	233	0	1	0	5	8	23	19	3	1	1	1	0	(17)
(18)		PrecStd	81	8	5	11	17	30	36	29	28	17	18	9	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.3	5.4	15.1	23.2	30.3	31.3	32.9	33.6	31.5	23.3	16.1	5.8	(19)
(20)			MCWB	1.8	2.3	8.2	10.7	13.9	16.7	20.1	17.5	16.2	12.4	7.9	1.6	(20)
(21)		2%	DB	2.5	2.4	10.9	19.1	26.8	27.8	30.1	30.4	28.4	18.8	10.0	2.8	(21)
(22)			MCWB	0.7	0.6	6.2	8.6	13.4	16.2	19.2	17.4	14.8	10.1	5.0	0.6	(22)
(23)		5%	DB	1.1	0.1	6.4	16.1	24.0	25.7	27.9	28.2	25.1	15.1	6.8	0.5	(23)
(24)			MCWB	-0.2	-0.9	3.6	7.3	11.8	15.4	18.2	17.1	13.9	8.6	3.4	-0.9	(24)
(25)		10%	DB	-1.2	-2.0	3.3	12.8	21.3	24.0	26.0	26.1	22.0	12.4	4.2	-1.9	(25)
(26)			MCWB	-2.2	-2.9	1.4	5.7	10.8	14.5	17.8	16.4	12.9	7.2	1.9	-2.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.0	2.5	8.5	11.5	16.1	20.5	23.0	21.1	17.8	13.5	8.8	2.1	(27)
(28)			MCDWB	4.0	4.7	13.7	21.5	24.3	26.5	29.0	26.5	27.6	20.6	16.2	4.9	(28)
(29)		2%	WB	0.9	0.7	6.1	9.4	14.2	18.1	20.7	19.5	16.0	11.1	5.6	0.7	(29)
(30)			MCDWB	2.3	2.3	10.4	17.6	22.8	24.0	26.6	26.0	25.2	16.7	9.4	2.7	(30)
(31)		5%	WB	-0.3	-0.7	3.6	7.8	13.0	17.0	19.5	18.3	14.6	9.3	3.6	-0.9	(31)
(32)			MCDWB	1.1	0.4	6.3	14.5	21.7	22.3	25.5	25.3	23.4	14.5	6.2	0.4	(32)
(33)		10%	WB	-2.2	-2.9	1.5	6.4	11.8	15.8	18.4	17.3	13.1	7.7	2.0	-2.8	(33)
(34)			MCDWB	-1.2	-1.9	3.1	12.1	19.1	21.6	24.4	23.9	20.6	11.9	4.1	-1.9	(34)
(35)	Mean Daily Temperature Range		MDBR	10.3	10.6	10.1	12.6	14.9	12.8	13.5	14.8	14.5	12.0	10.2	9.2	(35)
(36)		5% DB	MCDBR	11.0	10.6	12.6	19.5	19.9	16.4	16.5	18.9	20.6	17.2	14.2	10.6	(36)
(37)			MCWBR	9.5	8.6	8.3	10.6	9.1	7.4	7.6	8.1	8.9	9.7	9.4	8.8	(37)
(38)		5% WB	MCDBR	11.3	10.2	12.6	17.0	16.5	12.9	14.0	15.6	18.1	15.8	13.4	10.5	(38)
(39)			MCWBR	9.9	8.4	8.4	9.8	8.1	6.8	7.3	7.8	8.2	9.2	9.0	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.240	0.309	0.272	0.328	0.347	0.351	0.359	0.369	0.327	0.280	0.250	0.237	(40)	
(41)		taud	2.393	2.185	2.515	2.393	2.391	2.423	2.415	2.366	2.458	2.564	2.519	2.423	(41)	
(42)		Ebn at Noon	833	815	951	918	910	906	891	864	871	869	822	786	(42)	
(43)		Edh at Noon	60	98	84	107	113	110	110	110	89	67	53	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.29	2.34	3.67	4.83	5.82	6.11	6.61	5.25	3.90	2.35	1.30	0.93	(44)	
(45)		RadStd	0.15	0.20	0.30	0.37	0.48	0.39	0.39	0.35	0.35	0.29	0.18	0.11	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page