

TALOYOAK, NU, Canada

WMO: 715800

Lat: 69.550N

Lon: 93.580W

Elev: 90

StdP: 14.65

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-44.8	-42.5	-49.3	0.3	-41.0	-46.3	0.4	-38.1	34.8	-20.9	30.7	-19.2	6.2	160	1.101

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	61.5	52.2	58.2	50.6	55.1	49.0	53.3	59.8	51.2	57.0	49.3	54.6	9.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.9	53.4	55.1	47.5	48.8	53.5	45.5	45.1	51.7	22.2	60.0	21.0	57.1	19.9	54.8	61.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.0	26.4	23.3	-48.3	67.8	3.7	3.0	-51.0	70.0	-53.1	71.7	-55.1	73.4	-57.8	75.6		
(5)			-42.2	58.4	5.0	2.3	-45.8	60.1	-48.7	61.5	-51.5	62.8	-55.2	64.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-25.8	-28.1	-21.5	-5.2	16.1	36.1	47.1	44.5	32.4	15.0	-5.8	-18.6		
	DBStd	28.55	10.06	10.41	11.35	10.63	9.64	6.92	5.19	5.67	5.89	10.30	11.66	11.24		
	HDD50	15601	2351	2187	2215	1657	1051	418	122	188	527	1086	1673	2126		
	HDD65	21023	2816	2607	2680	2107	1516	866	554	635	977	1551	2123	2591		
	CDD50	53	0	0	0	0	0	2	33	18	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	10.7	9.9	9.7	9.7	10.3	11.0	10.8	10.5	11.1	12.2	11.9	10.9	10.1		
	PrecAvg	6.8	0.3	0.3	0.3	0.3	0.5	0.7	0.9	1.1	0.9	0.9	0.4	0.3		
(15) Precipitation	PrecMax	9.6	0.6	0.8	0.5	0.9	1.3	1.9	2.4	2.2	1.9	1.8	1.1	1.2		
	PrecMin	5.3	0.0	0.0	0.0	0.0	0.1	0.2	0.1	0.1	0.1	0.3	0.0	0.0		
	PrecStd	1.1	0.1	0.2	0.2	0.2	0.3	0.4	0.6	0.5	0.5	0.4	0.2	0.3		
	PrecStd	1.1	0.1	0.2	0.2	0.2	0.3	0.4	0.6	0.5	0.5	0.4	0.2	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	4.5	16.1	24.3	36.4	59.6	67.2	63.8	48.5	33.6	25.2	13.2		
		MCWB	5.9	3.5	15.4	23.3	34.1	51.3	55.5	53.4	43.8	32.7	24.1	12.2		
	2%	DB	-0.7	0.5	8.2	19.9	34.0	54.0	63.2	59.8	45.2	32.1	20.8	9.8		
		MCWB	-1.6	-0.2	7.5	18.9	32.6	47.5	53.1	51.9	42.2	31.4	20.1	9.1		
	5%	DB	-5.1	-5.2	2.1	16.4	32.3	49.8	60.1	56.6	42.8	30.4	16.4	3.6		
		MCWB	-5.7	-5.8	1.4	15.4	31.1	44.8	51.3	50.2	40.4	29.4	15.5	2.8		
	10%	DB	-9.6	-11.3	-3.8	12.0	29.8	45.9	57.2	53.7	40.5	28.4	11.8	-1.3		
		MCWB	-10.1	-11.8	-4.5	11.0	28.3	42.0	49.8	48.7	38.6	27.5	11.0	-1.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	4.6	15.8	23.6	34.5	52.0	57.6	55.7	44.7	33.1	24.5	12.5		
		MCDB	6.7	5.2	16.8	24.3	35.8	58.7	64.6	60.7	47.4	33.5	25.4	13.1		
	2%	WB	-0.7	0.9	7.9	18.9	32.8	47.9	54.2	52.9	42.7	31.6	20.2	9.3		
		MCDB	-0.1	1.6	8.6	19.8	33.8	53.6	61.5	57.9	44.7	32.0	20.9	10.0		
	5%	WB	-4.8	-3.9	2.2	15.4	31.2	44.9	52.0	51.1	40.7	29.6	15.6	3.3		
		MCDB	-4.2	-3.2	2.9	16.4	32.4	49.5	58.8	55.6	42.4	30.2	16.4	4.0		
	10%	WB	-8.8	-9.2	-3.3	11.1	28.5	42.1	50.1	49.2	38.7	27.6	11.1	-1.5		
		MCDB	-8.3	-8.6	-2.7	12.0	29.8	45.6	56.5	53.2	40.3	28.5	12.0	-0.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	11.2	12.7	14.9	12.0	9.4	13.9	10.9	7.4	9.7	11.7	11.3		
		MCDBR	16.5	16.1	15.9	14.7	9.2	15.4	18.9	14.8	10.6	7.3	12.8	14.7		
		MCWBR	16.0	15.6	15.5	14.4	8.4	10.5	11.4	9.1	8.2	7.4	12.8	14.5		
		MCDBR	16.3	15.4	16.3	14.7	8.8	15.0	18.3	13.6	10.4	7.5	13.0	14.8		
	5% WB	MCWBR	16.0	14.9	15.8	14.3	8.1	10.5	12.0	9.4	8.5	7.7	13.0	14.6		
(40) Clear-Sky Solar Irradiance	taub		0.150	0.205	0.251	0.306	0.321	0.331	0.352	0.324	0.294	0.228	0.160	N/A		
	taud		1.885	2.033	2.175	2.069	2.151	2.365	2.402	2.496	2.458	2.077	1.889	N/A		
	Ebn at Noon		14	177	246	259	271	273	263	259	234	156	8	0		
	Edh at Noon		1	13	23	36	38	32	30	24	19	12	1	0		
(44) All-Sky Solar Radiation	RadAvg		4	124	610	1381	1999	1948	1649	1100	524	148	17	0		
	RadStd		0	10	24	49	95	142	135	83	41	19	2	0		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+1.28	+1.60	N/A	N/A	N/A	N/A	N/A	-542	-526	N/A	N/A

Nomenclature: See separate page