

BELLA BELLA, BC, CanadaWMO: **715820**Lat: **52.181N**Lon: **128.154W**Elev: **141**StdP: **14.62**Time Zone: **-8.00 (NAP)**Period: **07-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	17.8	21.7	-1.2	5.2	24.8	7.2	8.0	28.4	23.2	43.1	20.6	43.0	3.1	120	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.0	76.7	63.3	72.7	61.3	69.3	60.0	64.2	74.1	62.4	70.3	60.9	67.1	7.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.3	78.4	65.6	59.2	75.4	64.6	58.1	72.6	63.2	29.4	74.4	28.1	70.7	27.0	67.3	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 18.4	15.2	12.7	DB	11.6	85.3	3.7	3.5	8.9	87.8	6.7	89.8	4.7	91.8	2.0	94.3	
(5)			WB	10.4	67.1	3.7	1.1	7.7	67.9	5.5	68.5	3.5	69.1	0.8	69.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	38.5	37.6	39.8	44.3	51.0	54.7	59.0	59.6	55.6	48.0	41.6	35.9
	DBStd	9.63	6.16	5.99	4.99	3.96	4.66	3.93	3.92	3.47	4.19	4.23	5.62	6.28
	HDD50	2032	358	348	318	176	43	3	0	0	6	88	253	439
	HDD65	6514	823	768	781	620	433	311	193	172	283	526	701	903
	CDD50	1004	0	0	1	6	75	144	278	297	174	27	2	0
	CDD65	13	0	0	0	0	0	2	6	4	1	0	0	0
	CDH74	272	0	0	1	0	13	45	110	88	15	0	0	0
	CDH80	61	0	0	0	0	1	13	23	22	2	0	0	0
	WSAvg	4.9	5.7	5.1	5.6	5.1	4.4	4.2	4.0	3.8	4.2	5.0	6.0	5.8
	PrecAvg	104.7	10.8	7.4	9.7	7.9	6.0	5.5	4.7	6.4	8.5	13.8	13.9	11.5
(15) Precipitation	PrecMax	129.8	16.3	14.4	21.6	13.5	14.4	9.4	14.1	12.0	16.8	19.3	21.1	19.8
	PrecMin	76.0	3.6	2.2	4.7	3.0	2.4	2.7	0.8	1.0	0.9	6.2	8.0	2.6
	PrecStd	12.6	3.3	3.3	4.0	2.2	2.6	2.0	3.2	2.6	4.1	3.6	3.8	3.8
	PrecStd	12.6	3.3	3.3	4.0	2.2	2.6	2.0	3.2	2.6	4.1	3.6	3.8	3.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	53.1	54.3	59.7	66.2	75.8	81.0	82.9	82.8	75.8	64.2	55.4	50.8	
	0.4% MCWB	47.7	45.6	49.5	51.0	58.2	60.7	65.0	65.0	62.1	55.3	51.6	46.7	
	2% DB	49.9	50.6	53.0	59.1	69.9	71.0	76.6	75.4	70.3	60.1	52.6	48.2	
	2% MCWB	46.3	45.3	46.7	47.5	55.7	59.6	64.6	63.7	60.7	53.7	50.2	45.6	
	5% DB	47.8	48.1	50.1	55.5	64.4	66.2	72.0	71.5	66.7	57.6	50.9	46.2	
	5% MCWB	45.2	44.8	44.9	47.0	54.5	57.6	61.8	62.1	59.0	53.0	49.1	44.3	
	10% DB	45.9	46.0	47.6	52.3	60.6	62.6	67.9	68.1	62.9	55.5	49.4	44.3	
	10% MCWB	43.8	43.3	44.3	46.4	52.6	55.6	59.5	60.4	57.2	51.6	47.8	42.5	
	0.4% WB	49.3	49.3	51.3	54.4	59.3	63.1	66.9	66.0	64.7	58.4	53.2	48.1	
	0.4% MCDB	50.7	50.7	56.4	62.1	72.8	73.9	79.9	78.3	73.2	60.5	53.9	49.2	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	47.3	47.0	48.7	50.8	56.8	60.2	64.2	64.2	62.1	56.3	50.8	46.2	
	2% MCDB	48.9	48.5	51.1	53.9	66.6	69.2	74.7	74.1	68.2	58.5	51.7	47.8	
	5% WB	45.8	45.3	46.7	48.6	55.1	58.1	62.0	62.6	60.0	54.1	49.4	44.5	
	5% MCDB	47.2	47.4	48.4	52.5	63.0	64.6	70.6	70.0	64.3	56.2	50.6	46.0	
	10% WB	44.2	43.6	45.1	47.1	53.3	56.4	60.2	61.1	58.4	52.1	48.1	42.8	
	10% MCDB	45.5	45.7	47.0	50.9	59.1	61.5	66.5	66.6	61.7	54.4	49.4	44.1	
(35) Mean Daily Temperature Range	MDBR	9.4	11.9	12.0	13.9	15.5	13.1	14.6	15.0	13.6	12.2	9.6	9.7	
	5% DB MCDBR	11.3	15.6	17.2	22.3	24.5	22.4	25.0	23.4	21.1	16.9	8.7	10.0	
	5% DB MCWBR	7.9	10.7	10.7	12.6	13.4	12.5	13.5	13.0	12.6	10.9	7.2	7.9	
	5% WB MCDBR	8.7	12.0	13.4	16.5	20.7	18.5	21.8	20.3	17.7	12.2	8.1	9.2	
	5% WB MCWBR	6.9	9.3	9.4	10.6	11.7	10.6	11.8	11.7	11.1	9.2	7.1	7.9	
	5% WB MCWBR	6.9	9.3	9.4	10.6	11.7	10.6	11.8	11.7	11.1	9.2	7.1	7.9	
(40) Clear-Sky Solar Irradiance	taub	0.312	0.320	0.348	0.367	0.371	0.374	0.361	0.364	0.348	0.342	0.320	0.301	
	taud	2.411	2.491	2.414	2.384	2.417	2.443	2.519	2.523	2.556	2.494	2.415	2.396	
	Ebn at Noon	220	256	268	276	280	279	281	274	267	243	213	202	
	Edh at Noon	18	23	30	34	35	34	31	30	25	22	18	16	
(44) All-Sky Solar Radiation	RadAvg	200	471	753	1202	1548	1638	1608	1390	951	521	242	166	
	RadStd	28	82	117	93	172	156	212	138	102	86	39	28	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	N/A	+0.81	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page