

ROCKY HARBOUR, NL, Canada

WMO: 715880

Lat: 49.5716N

Lon: 57.8763W

Elev: 222

StdP: 14.58

Time Zone: -3.50 (NAF)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.3	3.8	-5.2	4.2	0.7	-1.2	5.2	5.0	28.6	21.8	25.1	20.5	6.4	50	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.9	78.1	66.3	75.2	64.7	72.4	63.7	68.7	74.9	66.9	72.5	65.1	70.7	7.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	97.8	72.1	64.7	92.1	70.4	62.8	86.2	68.3	33.0	75.1	31.6	72.5	30.2	70.9	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.7	18.8	16.0	DB	-10.3	85.1	5.6	3.0	-14.3	87.3	-17.6	89.1	-20.7	90.8	-24.8	93.0	(4)
(5)			WB	-10.4	72.4	6.8	1.7	-15.3	73.6	-19.3	74.6	-23.1	75.5	-28.0	76.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.6	21.0	20.6	25.3	35.4	44.2	53.4	62.0	62.2	54.4	44.7	36.1	27.0
	DBStd	16.26	8.47	9.03	8.81	7.18	6.15	6.80	5.13	4.82	6.56	6.57	7.28	8.08
	HDD50	4525	899	823	765	441	201	40	1	0	29	192	422	712
	HDD65	8951	1364	1243	1230	889	645	352	119	111	324	630	867	1177
	CDD50	1112	0	0	0	2	21	142	374	380	160	28	5	0
	CDD65	61	0	0	0	0	0	4	27	25	5	0	0	0
	CDH74	378	0	0	0	0	0	39	180	139	18	2	0	0
	CDH80	38	0	0	0	0	0	5	19	13	1	0	0	0
Wind	WSAvg	6.6	7.8	7.6	7.1	6.9	6.0	5.5	5.2	5.4	6.3	6.8	7.4	7.8
Precipitation	PrecAvg	54.6	6.3	4.1	3.6	2.6	3.1	3.7	4.4	4.8	5.0	5.2	5.0	5.8
	PrecMax	63.5	9.4	7.0	6.6	6.2	7.5	7.3	6.9	12.4	10.2	8.4	7.8	10.4
	PrecMin	43.9	3.2	1.6	1.5	0.4	0.9	1.2	2.6	1.6	1.9	1.7	1.0	3.4
	PrecStd	4.9	1.5	1.3	1.2	1.3	1.5	1.2	1.3	2.2	1.7	1.7	1.7	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	48.1	49.4	60.1	68.3	78.5	82.8	81.7	76.4	69.0	62.5	51.0
		MCWB	49.7	44.9	44.7	51.2	54.7	62.5	68.1	69.4	67.2	61.3	58.5	47.4
	2%	DB	41.3	41.7	44.4	54.8	63.8	73.4	78.7	77.6	72.2	62.7	56.4	46.2
		MCWB	39.2	38.7	40.0	47.5	53.0	59.9	66.6	66.8	64.0	57.1	53.6	43.7
	5%	DB	36.6	36.5	40.8	50.5	59.9	69.4	75.5	74.8	68.3	58.6	52.2	41.6
		MCWB	34.7	33.7	36.3	43.7	50.8	58.6	65.0	65.3	61.8	54.1	49.3	39.3
	10%	DB	32.8	33.2	37.6	46.5	56.4	65.7	72.5	71.8	65.4	55.3	47.1	38.1
		MCWB	31.1	31.1	33.6	40.7	49.2	56.7	64.0	64.3	60.4	51.4	44.7	36.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	46.0	45.6	54.0	59.3	65.6	71.3	71.4	68.8	62.4	58.7	48.6
		MCDB	51.2	47.9	48.5	58.9	65.0	72.3	79.9	78.2	74.3	66.3	62.5	50.3
	2%	WB	39.0	39.3	40.9	48.5	55.4	62.6	68.8	68.8	65.8	57.9	54.2	44.3
		MCDB	40.5	41.7	43.5	53.4	60.0	70.0	75.2	75.0	70.2	61.7	56.7	46.1
	5%	WB	34.6	34.2	36.9	44.4	52.7	60.4	67.0	67.0	63.4	54.7	50.0	39.9
		MCDB	36.2	36.0	40.1	49.4	58.1	67.9	72.9	72.4	67.5	57.9	52.3	41.7
	10%	WB	31.2	31.4	33.9	41.2	49.4	58.0	65.1	65.3	60.8	51.6	45.2	36.9
		MCDB	32.7	33.2	37.1	45.5	56.5	65.4	71.1	70.8	64.9	54.6	47.3	38.7
Mean Daily Temperature Range	5% DB	MDBR	12.3	14.9	17.0	16.2	18.2	18.8	18.8	17.9	16.8	13.8	11.3	10.4
		MCDBR	15.8	17.9	20.1	21.8	24.9	24.3	23.9	22.4	20.9	20.1	18.0	14.9
		MCWBR	14.2	15.4	16.1	14.7	15.5	13.9	13.7	13.6	14.0	14.8	16.3	13.6
	5% WB	MCDBR	15.2	17.0	18.0	19.2	21.6	21.4	19.3	18.9	17.8	17.8	18.3	14.9
		MCWBR	14.3	15.2	15.5	14.6	15.0	13.0	12.3	12.5	13.4	14.6	17.0	14.3
Clear-Sky Solar Irradiance	taub	0.296	0.341	0.322	0.366	0.375	0.374	0.417	0.388	0.366	0.336	0.312	0.289	
	taud	2.274	2.093	2.264	2.278	2.371	2.392	2.392	2.323	2.400	2.456	2.493	2.450	2.355
	Ebn at Noon	235	245	280	279	280	281	266	269	264	253	232	223	
	Edh at Noon	23	35	35	38	37	36	38	34	29	23	19	18	
All-Sky Solar Radiation	RadAvg	259	489	900	1284	1578	1663	1629	1392	1026	628	312	193	
	RadStd	27	58	81	148	113	165	141	89	86	49	32	19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	+2.23	N/A	+0.68	+0.90	N/A	N/A	N/A	N/A

Nomenclature: See separate page