

ROCKY HARBOUR, NL, Canada

WMO: 715880

Lat: 49.5716N

Lon: 57.8763W

Elev: 68

StdP: 100.51

Time Zone: -3.50 (NAF)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.9	-15.7	-20.7	0.6	-17.4	-18.4	0.7	-15.0	12.8	-5.6	11.2	-6.4	2.9	50	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.0	25.6	19.0	24.0	18.2	22.4	17.6	20.4	23.9	19.4	22.5	18.4	21.5	3.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.0	22.3	18.1	13.2	21.4	17.1	12.3	20.2	58.9	24.0	55.6	22.5	52.4	21.6	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 10.2	8.4	7.1	DB	-23.5	29.5	3.1	1.7	-25.7	30.7	-27.5	31.7	-29.3	32.7	-31.5	33.9	(4)
(5)			WB	-23.6	22.4	3.8	0.9	-26.3	23.1	-28.5	23.7	-30.6	24.2	-33.3	24.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-6.1	-6.3	-3.7	1.9	6.8	11.9	16.7	16.8	12.4	7.1	2.3	-2.8
	DBStd	9.03	4.71	5.02	4.89	3.99	3.41	3.78	2.85	2.68	3.65	3.65	4.04	4.49
	HDD10.0	2514	499	457	425	245	112	22	1	0	16	107	234	396
	HDD18.3	4973	758	691	683	494	358	196	66	62	180	350	482	654
	CDD10.0	618	0	0	0	1	12	79	208	211	89	16	3	0
	CDD18.3	34	0	0	0	0	0	2	15	14	3	0	0	0
	CDH23.3	210	0	0	0	0	0	22	100	77	10	1	0	0
	CDH26.7	21	0	0	0	0	0	3	11	7	1	0	0	0
Wind	WSAvg	3.0	3.5	3.4	3.2	3.1	2.7	2.5	2.3	2.4	2.8	3.0	3.3	3.5
Precipitation	PrecAvg	1386	159	105	91	66	78	93	111	123	126	131	128	148
	PrecMax	1614	238	178	168	157	190	185	174	316	258	214	197	264
	PrecMin	1115	82	41	37	11	24	31	66	41	47	42	25	86
	PrecStd	124	39	33	30	34	39	31	32	55	43	43	43	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	9.0	9.7	15.6	20.2	25.9	28.2	27.6	24.7	20.6	17.0	10.6
		MCWB	9.8	7.2	7.0	10.7	12.6	16.9	20.0	20.8	19.5	16.3	14.7	8.6
	2%	DB	5.2	5.4	6.9	12.7	17.7	23.0	26.0	25.4	22.3	17.1	13.6	7.9
		MCWB	4.0	3.7	4.4	8.6	11.7	15.5	19.2	19.4	17.8	13.9	12.0	6.5
	5%	DB	2.6	2.5	4.9	10.3	15.5	20.8	24.2	23.8	20.1	14.8	11.2	5.4
		MCWB	1.5	0.9	2.4	6.5	10.5	14.8	18.4	18.5	16.6	12.3	9.6	4.1
	10%	DB	0.5	0.7	3.1	8.0	13.6	18.7	22.5	22.1	18.5	12.9	8.4	3.4
		MCWB	-0.5	-0.5	0.9	4.8	9.5	13.7	17.8	18.0	15.8	10.8	7.0	2.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	7.8	7.5	12.2	15.2	18.6	21.8	21.9	20.4	16.9	14.9	9.2
		MCDB	10.6	8.8	9.2	14.9	18.3	22.4	26.6	25.7	23.5	19.1	16.9	10.1
	2%	WB	3.9	4.1	5.0	9.2	13.0	17.0	20.4	20.4	18.8	14.4	12.3	6.8
		MCDB	4.7	5.4	6.4	11.9	15.5	21.1	24.0	23.9	21.2	16.5	13.7	7.9
	5%	WB	1.4	1.2	2.7	6.9	11.5	15.8	19.4	19.4	17.5	12.6	10.0	4.4
		MCDB	2.4	2.2	4.5	9.6	14.5	20.0	22.7	22.4	19.7	14.4	11.3	5.4
	10%	WB	-0.4	-0.3	1.0	5.1	9.7	14.5	18.4	18.5	16.0	10.9	7.3	2.7
		MCDB	0.4	0.7	2.8	7.5	13.6	18.5	21.7	21.6	18.3	12.6	8.5	3.7
Mean Daily Temperature Range	5% DB	MDBR	6.8	8.3	9.4	9.0	10.1	10.4	10.4	10.0	9.3	7.7	6.3	5.8
		MCDBR	8.8	9.9	11.2	12.1	13.8	13.5	13.3	12.4	11.6	11.2	10.0	8.3
		MCWBR	7.9	8.6	8.9	8.2	8.6	7.7	7.6	7.5	7.8	8.2	9.1	7.6
	5% WB	MCDBR	8.5	9.4	10.0	10.6	12.0	11.9	10.7	10.5	9.9	9.9	10.1	8.3
		MCWBR	7.9	8.5	8.6	8.1	8.3	7.2	6.8	7.0	7.5	8.1	9.4	7.9
Clear-Sky Solar Irradiance	taub	0.296	0.341	0.322	0.366	0.375	0.374	0.417	0.388	0.366	0.336	0.312	0.289	
	taud	2.274	2.093	2.264	2.278	2.371	2.392	2.323	2.400	2.456	2.493	2.450	2.355	
	Ebn at Noon	741	773	883	878	884	885	838	848	832	799	732	703	
	Edh at Noon	71	110	110	121	116	114	121	107	91	74	61	58	
All-Sky Solar Radiation	RadAvg	0.82	1.54	2.84	4.05	4.97	5.24	5.13	4.39	3.23	1.98	0.98	0.61	
	RadStd	0.09	0.18	0.26	0.47	0.36	0.52	0.45	0.28	0.27	0.15	0.10	0.06	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	+1.24	N/A	+0.38	+0.50	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page