

EDMUNDSTON, NB, Canada

WMO: 715900

Lat: 47.4167N

Lon: 68.3244W

Elev: 506

StdP: 14.43

Time Zone: -4.00 (NAA)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.3	-17.5	-29.4	1.1	-23.0	-23.3	1.5	-16.4	16.4	18.0	14.6	16.4	1.6	330	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.3	84.5	67.8	81.0	66.3	78.2	64.9	70.7	79.4	69.0	77.2	67.2	75.0	6.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.8	104.1	74.9	66.1	98.0	73.1	64.4	92.1	71.2	34.9	79.4	33.5	77.4	32.0	75.1	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	12.8	11.4	-31.8	89.4	5.3	2.3	-35.6	91.1	-38.8	92.5	-41.7	93.8	-45.6	95.5
			-31.8	74.1	5.2	1.6	-35.5	75.3	-38.5	76.2	-41.4	77.1	-45.2	78.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.5	9.0	11.2	21.6	36.7	50.3	58.6	64.6	62.5	54.0	43.2	31.4	17.6
	DBStd	21.34	13.89	12.32	11.87	7.79	7.08	6.22	5.29	5.52	7.33	7.50	9.05	11.59
	HDD50	5570	1272	1086	882	400	83	4	0	1	41	237	560	1004
	HDD65	9784	1737	1506	1347	848	459	208	72	114	338	677	1009	1469
	CDD50	1386	0	0	0	3	92	263	453	389	160	25	1	0
	CDD65	125	0	0	0	0	3	17	60	38	7	0	0	0
	CDH74	1766	0	0	0	3	112	307	758	469	107	10	0	0
	CDH80	384	0	0	0	0	31	67	177	90	18	1	0	0
Wind	WSAvg	4.4	4.6	5.1	5.6	5.4	4.9	4.1	3.6	3.4	3.7	4.1	4.5	4.2
Precipitation	PrecAvg	48.2	4.2	3.6	3.8	3.2	3.5	3.1	4.2	4.6	4.1	4.2	4.3	5.9
	PrecMax	64.9	7.2	6.8	7.2	7.0	6.4	5.2	6.1	10.4	7.4	7.0	6.8	10.0
	PrecMin	37.8	1.0	1.5	0.6	0.7	1.6	1.3	2.2	1.4	1.3	1.7	2.4	1.7
	PrecStd	7.6	1.5	1.6	1.6	1.5	1.3	0.9	1.3	2.4	1.8	1.5	1.1	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.6	42.1	54.3	69.8	84.7	86.5	88.2	86.6	82.3	73.8	60.1	46.4
		MCWB	41.5	37.9	42.2	52.5	63.8	67.0	69.9	69.5	68.6	59.5	57.0	44.1
	2%	DB	38.4	37.5	46.1	62.1	76.2	81.1	84.8	82.3	76.6	65.4	53.1	40.0
		MCWB	36.5	33.3	37.6	47.7	58.9	64.9	68.5	67.1	64.1	56.5	49.1	38.1
	5%	DB	34.7	34.3	41.9	56.0	70.8	77.3	81.3	79.2	72.9	60.7	48.5	36.9
		MCWB	32.8	31.7	35.6	44.8	55.2	63.5	67.0	65.9	62.6	54.7	44.9	34.8
	10%	DB	30.8	31.5	38.1	50.7	66.0	73.6	78.2	76.0	68.9	56.9	44.6	34.1
		MCWB	29.0	29.1	33.3	42.0	53.3	60.9	65.5	64.3	60.9	51.7	41.9	32.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.0	39.2	45.6	55.8	67.2	71.7	74.3	71.8	70.2	63.2	56.6	44.4
		MCDB	43.0	40.8	51.2	65.0	77.8	81.7	82.9	82.3	79.4	69.1	58.7	45.9
	2%	WB	36.8	34.1	39.3	49.6	61.9	68.2	71.3	69.7	67.3	59.2	50.0	38.5
		MCDB	38.3	36.1	43.9	58.0	71.4	76.4	79.1	78.4	74.0	63.1	52.0	39.5
	5%	WB	33.1	32.1	36.1	46.3	58.1	65.6	69.4	68.0	64.8	55.6	45.2	35.2
		MCDB	34.4	34.4	41.1	54.2	66.2	73.4	77.3	76.1	70.1	60.1	47.3	36.5
	10%	WB	29.0	28.9	33.5	42.9	55.1	63.0	67.7	66.1	61.9	52.2	41.7	32.5
		MCDB	30.9	31.4	37.8	50.3	63.8	70.7	75.7	72.9	67.9	56.2	44.7	34.0
Mean Daily Temperature Range	5% DB	MDBR	23.2	24.8	24.1	21.6	24.0	23.8	24.3	24.5	24.4	20.0	15.7	17.6
		MCDBR	20.0	22.2	27.2	33.3	35.0	31.6	29.4	29.5	30.2	28.6	21.2	16.0
		MCWBR	19.1	19.0	19.8	20.4	18.8	17.4	15.6	16.2	18.8	20.0	17.4	14.7
	5% WB	MCDBR	19.8	18.1	22.8	28.8	27.4	25.4	24.5	24.3	24.9	24.2	18.1	15.4
		MCWBR	19.3	16.5	17.4	19.2	16.9	15.4	14.0	14.0	16.9	18.6	16.3	14.8
Clear-Sky Solar Irradiance	taub	0.256	0.269	0.304	0.350	0.353	0.374	0.404	0.381	0.357	0.323	0.291	0.268	
	taud	2.331	2.285	2.249	2.336	2.425	2.366	2.300	2.368	2.432	2.521	2.518	2.380	
	Ebn at Noon	266	286	291	286	289	282	271	273	270	265	253	247	
	Edh at Noon	23	30	36	37	35	37	40	36	30	24	19	19	
All-Sky Solar Radiation	RadAvg	428	713	1100	1415	1595	1728	1723	1505	1170	687	380	292	
	RadStd	54	85	81	117	164	115	163	98	86	62	45	29	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page