

MCNABS ISLAND, NS, Canada

WMO: 715910

Lat: 44.602N

Lon: 63.533W

Elev: 51

StdP: 14.67

Time Zone: -4.00 (NAA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.0	10.4	-2.9	4.7	8.5	0.8	5.7	12.7	42.7	29.6	39.9	29.5	17.9	290	0.706

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.4	77.3	65.8	74.6	64.8	72.1	63.8	69.2	73.9	67.6	71.5	66.2	69.6	12.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.7	102.0	71.0	66.1	96.5	69.6	64.7	91.8	67.9	33.4	74.1	32.1	71.5	30.9	69.7	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.6	30.6	27.3	DB	1.8	84.1	4.6	3.0	-1.4	86.2	-4.1	87.9	-6.7	89.6	-10.0	91.8	(4)
(5)			WB	0.6	71.5	4.1	1.3	-2.4	72.5	-4.8	73.3	-7.1	74.0	-10.1	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.0	27.1	26.6	32.3	40.2	48.3	56.4	64.0	65.8	61.1	52.5	42.7	33.6	(6)	
	DBStd	14.98	8.86	8.00	7.04	5.25	5.15	5.79	4.18	3.60	5.05	5.98	6.92	8.02	(7)	
	HDD50	3103	711	654	551	297	93	11	0	0	0	43	233	510	(8)	
	HDD65	7060	1176	1074	1014	745	518	263	69	34	134	390	669	974	(9)	
	CDD50	1638	0	0	2	2	41	203	433	489	335	119	14	0	(10)	
	CDD65	120	0	0	0	0	1	6	37	57	18	1	0	0	(11)	
	CDH74	317	0	0	2	0	7	45	100	116	45	2	0	0	(12)	
	CDH80	41	0	0	0	0	0	8	11	12	10	0	0	0	(13)	
(14) Wind	WSAvg	12.5	14.9	15.0	14.6	13.2	11.6	10.7	9.5	9.5	10.8	12.8	13.7	14.6	(14)	
(15) Precipitation	PrecAvg	55.7	5.2	4.5	4.8	4.3	4.4	4.1	4.0	3.8	3.8	5.0	5.5	5.9	(15)	
	PrecMax	70.7	10.7	9.0	9.6	8.2	8.4	13.7	9.0	12.6	8.9	10.1	10.2	10.0	(16)	
	PrecMin	38.7	1.7	1.3	1.8	0.7	1.0	1.3	0.5	1.0	1.1	1.3	1.5	2.6	(17)	
	PrecStd	7.8	1.9	1.9	1.8	1.7	1.8	2.2	1.9	2.4	1.8	2.0	2.2	2.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.4	47.5	56.0	59.4	73.0	79.5	81.6	81.5	78.8	70.2	60.4	54.2	(19)	
		MCWB	48.2	45.8	47.4	47.4	58.4	64.7	67.6	68.1	68.8	61.7	57.2	52.4	(20)	
	2%	DB	46.2	43.5	47.4	54.4	64.4	72.9	76.5	77.0	73.7	66.2	57.6	51.2	(21)	
		MCWB	44.7	41.8	42.6	45.4	53.5	60.4	65.8	65.9	65.7	61.4	55.1	49.7	(22)	
	5%	DB	42.7	40.2	44.0	50.7	59.3	69.1	73.8	74.4	70.6	63.5	55.4	48.1	(23)	
		MCWB	40.8	38.3	40.2	44.9	50.6	59.7	64.4	65.2	64.1	59.7	53.2	46.5	(24)	
	10%	DB	39.6	37.6	41.4	47.9	55.9	65.6	71.1	71.9	68.2	61.4	53.0	45.4	(25)	
		MCWB	37.6	35.4	38.1	43.7	49.5	58.0	63.8	64.6	63.0	58.1	50.9	43.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	46.3	50.3	52.0	62.1	67.1	70.9	71.4	70.7	65.6	58.5	53.2	(27)	
		MCDB	49.1	47.2	54.5	55.9	70.1	75.8	74.7	76.2	75.7	67.6	59.4	53.9	(28)	
	2%	WB	45.2	42.3	44.0	48.4	56.3	64.1	68.6	69.3	68.1	62.9	55.8	49.9	(29)	
		MCDB	46.1	43.2	45.6	51.2	60.6	70.0	74.1	73.3	71.4	64.8	56.9	50.8	(30)	
	5%	WB	41.2	38.8	41.2	46.5	53.1	61.7	66.6	67.9	66.1	60.9	53.7	46.9	(31)	
		MCDB	42.3	39.9	43.2	48.9	57.5	66.0	71.1	71.1	68.8	62.9	55.0	47.9	(32)	
	10%	WB	37.8	35.9	38.6	44.1	50.5	59.3	65.0	66.4	64.5	58.8	51.2	44.0	(33)	
		MCDB	39.6	37.4	41.1	47.2	54.5	63.5	68.6	69.5	67.0	61.0	52.8	45.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	11.8	11.1	10.7	11.8	12.2	11.6	11.4	11.3	10.4	10.0	10.9	(35)	
		MCDBR	15.1	14.3	14.2	16.0	19.0	19.2	16.5	15.5	14.5	12.2	11.9	13.7	(36)	
	5% WB	MCWBR	15.3	13.8	11.5	10.6	10.8	10.7	8.4	7.6	8.9	9.0	11.4	14.7	(37)	
		MCWBR	14.5	14.5	13.9	13.3	16.1	16.6	13.4	11.9	11.4	10.5	11.3	13.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.303	0.297	0.325	0.350	0.371	0.401	0.417	0.397	0.355	0.333	0.317	0.297	(40)	
		taud	2.472	2.520	2.473	2.446	2.434	2.379	2.355	2.407	2.498	2.553	2.550	2.535	(41)	
	Ebn at Noon	Ebn at Noon	260	286	290	290	285	276	270	272	276	268	254	252	(42)	
		Edh at Noon	22	25	30	34	35	37	38	35	30	24	21	19	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	456	741	1121	1369	1571	1708	1696	1585	1293	839	482	361	(44)	
	RadStd	RadStd	34	54	76	112	203	159	124	110	85	87	52	28	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	+0.67	+0.90	N/A	N/A	+101	+31	(47)

Nomenclature: See separate page