

MCNABS ISLAND, NS, Canada

WMO: 715910

Lat: 44.602N

Lon: 63.533W

Elev: 15

StdP: 101.14

Time Zone: -4.00 (NAA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.4	-12.0	-19.4	0.7	-13.1	-17.3	0.8	-10.7	19.1	-1.3	17.8	-1.4	8.0	290	0.706

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	25.2	18.8	23.7	18.2	22.3	17.7	20.7	23.3	19.8	21.9	19.0	20.9	5.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.6	21.6	19.0	13.8	20.9	18.2	13.1	20.0	59.8	23.4	56.7	22.0	54.0	21.0	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.7	12.2	-16.8	28.9	2.5	1.7	-18.6	30.1	-20.1	31.1	-21.5	32.0	-23.3	33.2		
(5)			-17.4	22.0	2.3	0.7	-19.1	22.5	-20.4	22.9	-21.7	23.4	-23.4	23.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-2.7	-3.0	0.2	4.5	9.1	13.6	17.8	18.8	16.2	11.4	5.9	0.9	(6)
(7)		DBStd	8.32	4.92	4.44	3.91	2.91	2.86	3.22	2.32	2.00	2.80	3.32	3.84	4.46	(7)
(8)		HDD10.0	1724	395	363	306	165	52	6	0	0	0	24	129	283	(8)
(9)		HDD18.3	3922	653	597	563	414	288	146	38	19	74	217	372	541	(9)
(10)		CDD10.0	910	0	0	1	1	23	113	241	272	186	66	8	0	(10)
(11)		CDD18.3	67	0	0	0	0	1	3	21	32	10	1	0	0	(11)
(12)		CDH23.3	176	0	0	1	0	4	25	56	64	25	1	0	0	(12)
(13)		CDH26.7	23	0	0	0	0	0	4	6	7	6	0	0	0	(13)
(14)	Wind	WSAvg	5.6	6.7	6.7	6.5	5.9	5.2	4.8	4.3	4.2	4.8	5.7	6.1	6.5	(14)
(15)	Precipitation	PrecAvg	1414	132	114	123	110	111	103	101	96	97	128	139	151	(15)
(16)		PrecMax	1795	271	229	243	208	214	349	229	320	225	256	258	253	(16)
(17)		PrecMin	983	42	34	45	19	26	32	13	25	27	32	38	67	(17)
(18)		PrecStd	198	47	47	46	42	45	55	48	61	46	52	55	51	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	8.6	13.3	15.2	22.8	26.4	27.5	26.0	21.2	15.8	12.3	(19)	
(20)			MCWB	9.0	7.7	8.6	8.6	14.7	18.2	19.8	20.1	20.5	16.5	14.0	11.3	(20)
(21)		2%	DB	7.9	6.4	8.6	12.4	18.0	22.7	24.7	25.0	23.2	19.0	14.2	10.7	(21)
(22)			MCWB	7.1	5.5	5.9	7.5	12.0	15.8	18.8	18.8	18.7	16.3	12.8	9.8	(22)
(23)		5%	DB	5.9	4.6	6.6	10.4	15.2	20.6	23.2	23.5	21.4	17.5	13.0	8.9	(23)
(24)			MCWB	4.9	3.5	4.6	7.2	10.3	15.4	18.0	18.4	17.8	15.4	11.8	8.0	(24)
(25)		10%	DB	4.2	3.1	5.2	8.8	13.3	18.7	21.7	22.2	20.1	16.3	11.7	7.4	(25)
(26)			MCWB	3.1	1.9	3.4	6.5	9.7	14.5	17.7	18.1	17.2	14.5	10.5	6.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	7.9	10.2	11.1	16.7	19.5	21.6	21.9	21.5	18.7	14.7	11.8	(27)
(28)			MADB	9.5	8.4	12.5	13.3	21.2	24.3	23.7	24.6	24.3	19.8	15.2	12.2	(28)
(29)		2%	WB	7.4	5.7	6.7	9.1	13.5	17.8	20.3	20.7	20.1	17.2	13.2	10.0	(29)
(30)			MADB	7.8	6.2	7.6	10.7	15.9	21.1	23.4	22.9	21.9	18.2	13.8	10.5	(30)
(31)		5%	WB	5.1	3.8	5.1	8.0	11.7	16.5	19.2	19.9	19.0	16.1	12.0	8.3	(31)
(32)			MADB	5.7	4.4	6.2	9.4	14.2	18.9	21.7	21.7	20.4	17.2	12.8	8.8	(32)
(33)		10%	WB	3.2	2.1	3.7	6.7	10.3	15.2	18.4	19.1	18.1	14.9	10.7	6.7	(33)
(34)			MADB	4.2	3.0	5.0	8.4	12.5	17.5	20.3	20.8	19.5	16.1	11.5	7.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.6	6.6	6.2	5.9	6.5	6.8	6.4	6.3	6.3	5.8	5.6	6.0	(35)
(36)			MCDBR	8.4	7.9	7.9	8.9	10.6	10.6	9.1	8.6	8.0	6.8	6.6	7.6	(36)
(37)			MCWBR	8.5	7.6	6.4	5.9	6.0	5.9	4.7	4.2	4.9	5.0	6.3	8.1	(37)
(38)		5% WB	MCDBR	8.0	8.1	7.7	7.4	9.0	9.2	7.5	6.6	6.3	5.8	6.3	7.4	(38)
(39)			MCWBR	8.5	8.3	7.2	6.1	6.3	5.9	4.7	4.2	4.8	5.5	6.7	8.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.303	0.297	0.325	0.350	0.371	0.401	0.417	0.397	0.355	0.333	0.317	0.297	(40)	
(41)		taud	2.472	2.520	2.473	2.446	2.434	2.379	2.355	2.407	2.498	2.553	2.550	2.535	(41)	
(42)		Ebn at Noon	820	901	914	913	899	870	850	856	870	846	801	796	(42)	
(43)		Edh at Noon	70	80	95	107	111	118	120	110	93	77	65	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.44	2.34	3.53	4.32	4.95	5.38	5.35	5.00	4.08	2.65	1.52	1.14	(44)	
(45)		RadStd	0.11	0.17	0.24	0.35	0.64	0.50	0.39	0.35	0.27	0.27	0.16	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	+0.37	+0.50	N/A	N/A	+56	+17

Nomenclature: See separate page