

KEJIMKUJIK, NS, Canada

WMO: 715990

Lat: 44.403N

Lon: 65.203W

Elev: 125

StdP: 99.83

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.5	-15.3	-20.2	0.6	-16.3	-18.2	0.8	-13.6	7.7	5.8	6.5	0.4	1.3	330	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	29.0	20.5	27.3	19.8	25.8	19.1	22.6	26.3	21.7	24.9	20.7	23.6	2.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.5	16.4	24.0	20.6	15.5	23.2	19.7	14.7	22.3	67.4	26.4	64.0	24.9	60.6	23.6	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.2	5.3	4.4	-20.3	32.0	2.4	1.3	-22.0	33.0	-23.4	33.7	-24.7	34.5	-26.5	35.4		
			-20.6	24.3	2.4	1.3	-22.3	25.3	-23.7	26.1	-25.0	26.8	-26.7	27.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-4.7	-4.0	-0.5	5.2	11.0	15.8	19.7	19.0	15.0	9.0	3.8	-1.3
	DBStd	9.50	5.64	5.38	4.78	3.98	3.68	3.56	2.64	2.79	3.77	4.06	4.62	5.07
	HDD10.0	1976	457	393	326	153	30	2	0	0	4	68	192	352
	HDD18.3	4124	716	627	583	394	227	91	16	26	112	288	436	609
	CDD10.0	1031	1	0	1	8	62	177	301	280	155	38	7	1
	CDD18.3	135	0	0	0	0	1	16	58	47	12	1	0	0
	CDH23.3	1014	0	0	2	3	33	158	430	318	71	1	0	0
	CDH26.7	211	0	0	0	1	6	37	93	62	12	0	0	0
Wind	WSAvg	1.8	1.9	2.0	2.1	2.1	1.9	1.7	1.6	1.5	1.5	1.7	1.8	1.9
Precipitation	PrecAvg	1421	149	113	121	116	103	100	96	94	115	127	154	163
	PrecMax	1963	396	238	273	203	294	284	227	278	323	263	272	420
	PrecMin	984	26	39	41	28	35	18	18	36	47	16	40	40
	PrecStd	217	80	52	52	41	53	63	50	54	65	60	56	86
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.5	12.0	15.9	21.0	27.1	30.5	31.3	30.6	28.2	22.5	17.7	14.3
		MCWB	12.2	9.2	10.0	13.6	16.8	20.6	21.8	21.4	20.8	17.4	15.7	13.7
	2%	DB	9.9	8.7	11.7	17.2	23.3	27.2	29.0	28.3	25.3	19.9	15.6	11.9
		MCWB	9.1	7.3	8.5	11.5	15.1	19.3	21.0	20.2	19.6	16.3	14.2	11.2
	5%	DB	6.1	5.9	9.1	14.7	20.8	24.9	27.4	26.7	23.2	17.8	13.6	9.1
		MCWB	5.3	4.5	6.5	10.3	13.7	17.6	20.1	19.7	18.6	15.3	12.4	8.5
	10%	DB	3.1	3.4	6.8	12.5	18.3	23.0	25.8	25.0	21.5	16.1	11.3	5.9
		MCWB	2.2	2.1	4.3	8.8	12.4	16.6	19.4	19.0	18.0	13.8	10.0	5.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.9	10.7	11.7	15.7	19.2	22.6	23.8	23.6	23.0	19.2	16.6	13.8
		MCDB	13.5	11.5	13.5	18.2	23.6	27.2	28.1	27.1	25.3	20.7	17.3	14.2
	2%	WB	9.1	7.5	9.2	13.7	17.0	21.1	22.7	22.5	21.3	17.5	14.6	11.4
		MCDB	9.7	8.1	10.6	15.8	20.7	24.9	26.6	25.8	23.6	18.8	15.3	11.9
	5%	WB	5.4	4.6	7.0	11.5	15.4	19.6	21.7	21.4	20.1	16.0	12.6	8.6
		MCDB	6.0	5.5	8.6	13.5	18.4	22.7	25.2	24.4	22.2	17.2	13.4	9.0
	10%	WB	2.3	2.3	4.5	9.2	13.7	18.1	20.7	20.4	18.9	14.1	10.1	5.4
		MCDB	3.0	3.3	6.5	11.8	16.9	21.3	23.7	23.1	20.6	15.7	11.2	5.9
Mean Daily Temperature Range	5% DB	MDBR	8.7	9.1	9.4	10.1	11.2	11.2	10.9	10.9	10.9	9.8	8.0	7.7
		MCDBR	12.5	11.3	13.0	14.6	16.0	14.9	13.6	13.1	12.7	11.8	10.6	10.9
		MCWBR	12.2	9.8	9.8	9.3	8.9	8.0	7.0	6.6	7.7	8.4	9.4	10.8
	5% WB	MCDBR	12.6	10.5	12.0	11.8	12.3	11.7	10.7	9.9	9.6	9.6	10.0	10.7
		MCWBR	12.4	9.9	10.5	9.4	8.0	7.2	6.4	6.0	6.7	8.2	9.5	10.8
Clear-Sky Solar Irradiance	taub	0.288	0.290	0.317	0.341	0.362	0.389	0.403	0.386	0.354	0.326	0.310	0.295	
	taud	2.492	2.517	2.487	2.458	2.434	2.372	2.350	2.393	2.457	2.548	2.550	2.519	
	Ebn at Noon	845	913	924	923	908	880	863	867	871	856	812	800	
	Edh at Noon	69	80	94	105	111	119	120	111	96	77	65	62	
All-Sky Solar Radiation	RadAvg	1.35	2.21	3.40	4.35	4.99	5.49	5.52	5.04	4.08	2.62	1.48	1.06	
	RadStd	0.11	0.19	0.26	0.41	0.61	0.54	0.42	0.33	0.27	0.29	0.17	0.10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	Station Only	N/A	N/A	+1.13	N/A	N/A	N/A	N/A	N/A	+110	+33
	Regional (34 neighbors)	N/A	N/A	N/A	N/A	+0.38	+0.50	N/A	N/A	+57	N/A

Nomenclature: See separate page