

SHEARWATER JETTY, NS, Canada

WMO: 716015

Lat: 44.628N

Lon: 63.522W

Elev: 6

StdP: 101.26

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-13.7	-11.5	-19.4	0.7	-11.8	-16.9	0.9	-10.3	14.4	-3.3	13.4	-3.0	5.5	330	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	25.8	19.6	24.3	18.7	22.9	18.2	21.1	23.8	20.3	22.6	19.6	21.6	4.3	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.0	22.0	19.6	14.3	21.4	18.8	13.6	20.8	61.3	24.0	58.5	22.5	56.1	21.8	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.8	9.5	DB	-16.8	30.3	3.0	3.1	-18.9	32.5	-20.7	34.3	-22.4	36.0	-24.6	38.2	(4)
(5)			WB	-17.1	22.5	3.0	0.8	-19.3	23.0	-21.1	23.5	-22.8	24.0	-25.0	24.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-2.4	-2.4	0.5	4.9	9.5	14.3	18.4	19.1	16.3	11.1	5.8	1.1		
	DBStd	8.33	5.04	4.35	3.87	2.90	2.72	3.03	2.31	2.05	2.85	3.42	3.98	4.46		
	HDD10.0	1663	383	348	296	154	43	2	0	0	0	28	134	275		
	HDD18.3	3826	641	582	553	403	276	123	28	16	72	226	374	533		
	CDD10.0	965	0	0	1	2	26	133	259	282	191	62	9	1		
	CDD18.3	84	0	0	0	0	0	4	29	38	12	1	0	0		
	CDH23.3	247	0	0	3	0	2	27	98	96	22	1	0	0		
	CDH26.7	29	0	0	2	0	0	4	12	9	2	0	0	0		
(14) Wind	WSAvg	4.4	5.4	5.3	5.0	4.6	3.9	3.5	3.1	3.1	3.7	4.5	5.0	5.2		
(15) Precipitation	PrecAvg	1414	132	114	123	110	111	103	101	96	97	128	139	151		
	PrecMax	1795	271	229	243	208	214	349	229	320	225	256	258	253		
	PrecMin	983	42	34	45	19	26	32	13	25	27	32	38	67		
	PrecStd	198	47	47	46	42	45	55	48	61	46	52	55	51		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	9.7	12.6	16.3	21.5	26.5	28.3	27.7	25.5	21.2	16.2	12.8		
		MCWB	10.2	8.4	8.1	10.1	14.6	19.2	20.7	20.5	19.9	17.2	15.0	12.2		
	2%	DB	8.9	7.2	9.1	13.0	18.1	23.2	25.8	25.7	23.4	18.9	14.5	11.0		
		MCWB	8.5	6.3	6.4	7.9	12.8	16.8	19.6	19.6	19.1	16.5	13.3	10.4		
	5%	DB	6.9	5.3	7.2	11.1	15.7	21.3	24.1	24.2	21.7	17.5	13.3	9.4		
		MCWB	6.0	4.3	4.9	7.6	11.3	15.9	18.7	18.9	18.1	15.6	12.2	8.7		
	10%	DB	4.8	3.7	5.7	9.4	13.8	19.4	22.6	22.8	20.5	16.2	12.1	7.8		
		MCWB	3.7	2.6	3.8	7.0	10.2	15.2	18.3	18.3	17.7	14.4	10.9	6.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	8.5	10.1	12.2	16.5	19.8	22.1	22.1	21.5	19.2	15.6	12.3		
		MCDB	10.7	9.2	11.7	14.3	19.3	24.0	26.2	24.9	23.3	20.0	16.2	12.6		
	2%	WB	8.4	6.2	7.0	10.0	14.1	18.1	21.1	21.1	20.2	17.5	14.0	10.6		
		MCDB	8.8	6.8	7.9	11.3	16.3	20.9	24.4	23.5	21.6	18.5	14.5	10.9		
	5%	WB	6.4	4.2	5.4	8.7	12.4	17.0	20.2	20.5	19.3	16.2	12.7	8.9		
		MCDB	6.9	4.9	6.6	10.1	14.2	19.2	23.1	22.5	20.6	17.1	13.3	9.4		
	10%	WB	4.1	2.6	3.9	7.4	10.9	15.9	19.3	19.7	18.4	15.0	11.3	7.3		
		MCDB	4.9	3.4	5.1	8.9	12.9	17.8	21.7	21.6	19.8	16.2	12.1	7.9		
(35) Mean Daily Temperature Range	MDBR		7.2	6.8	6.4	6.4	6.8	7.1	6.9	6.9	6.6	6.0	5.7	6.2		
	5% DB	MCDBR	9.0	8.1	8.7	9.3	10.3	10.6	9.5	9.1	7.7	6.9	6.6	7.8		
		MCWBR	8.8	8.1	6.9	6.2	6.1	5.8	4.5	4.0	4.8	5.1	6.7	8.4		
	5% WB	MCDBR	8.7	8.2	8.0	7.6	8.7	8.5	8.0	6.7	6.1	5.8	6.6	7.8		
		MCWBR	9.1	8.4	7.5	6.3	6.3	5.6	4.7	4.0	4.6	5.5	7.1	8.5		
(40) Clear-Sky Solar Irradiance	taub		0.304	0.298	0.325	0.351	0.371	0.401	0.417	0.397	0.355	0.334	0.317	0.298		
	taud		2.469	2.517	2.472	2.444	2.432	2.376	2.353	2.404	2.496	2.551	2.549	2.533		
	Ebn at Noon		819	901	913	912	899	869	849	855	870	845	801	795		
	Edh at Noon		70	80	95	107	111	119	120	110	93	77	65	61		
(44) All-Sky Solar Radiation	RadAvg		1.43	2.33	3.53	4.31	4.95	5.38	5.35	5.00	4.07	2.64	1.52	1.13		
	RadStd		0.11	0.17	0.24	0.35	0.64	0.50	0.39	0.35	0.27	0.27	0.16	0.09		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	+0.37	+0.50	N/A	N/A	+56	+17

Nomenclature: See separate page