

PORT MELLON, BC, Canada

WMO: 716050

Lat: 49.526N

Lon: 123.496W

Elev: 123

StdP: 99.86

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.8	-3.1	-11.7	1.4	-1.3	-8.7	1.8	-1.0	4.9	4.2	4.3	4.2	1.5	350	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	27.4	18.3	25.7	17.8	24.1	17.0	19.1	25.8	18.4	24.3	17.6	22.8	1.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	12.1	21.1	16.0	11.5	20.6	15.3	11.1	19.8	54.9	25.9	52.4	24.5	49.9	22.9	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.1	3.3	2.8	-7.4	31.4	2.0	1.4	-8.9	32.4	-10.1	33.3	-11.2	34.0	-12.7	35.1		
			-8.1	20.6	2.4	0.5	-9.8	21.0	-11.2	21.3	-12.6	21.6	-14.3	21.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	3.7	4.2	6.2	8.6	13.1	15.4	18.8	18.7	15.3	10.3	6.0	3.1	(6)
(7)		DBStd	6.26	2.83	3.19	2.65	2.51	3.16	3.04	2.64	2.64	3.01	2.49	3.16	2.93	(7)
(8)		HDD10.0	904	196	163	121	56	7	1	0	0	1	26	123	213	(8)
(9)		HDD18.3	3023	454	396	376	292	165	98	26	27	101	249	369	471	(9)
(10)		CDD10.0	1022	0	0	3	14	103	163	271	270	159	35	3	0	(10)
(11)		CDD18.3	98	0	0	0	0	2	11	38	38	9	0	0	0	(11)
(12)		CDH23.3	514	0	0	0	0	12	68	218	179	38	0	0	0	(12)
(13)		CDH26.7	86	0	0	0	0	1	11	42	29	3	0	0	0	(13)
(14)	Wind	WSAvg	1.0	1.1	1.1	1.3	1.3	1.1	1.0	0.9	0.9	0.9	1.0	1.1	(14)	
(15)	Precipitation	PrecAvg	2306	321	223	237	144	94	79	56	78	114	266	365	329	(15)
(16)		PrecMax	3065	608	511	442	310	173	165	113	318	276	577	726	503	(16)
(17)		PrecMin	1813	142	15	54	35	29	27	14	11	18	25	153	156	(17)
(18)		PrecStd	303	98	106	87	63	36	37	31	70	66	121	160	91	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	12.0	16.3	19.4	24.9	28.3	30.4	30.0	26.8	19.2	13.8	10.8	(19)
(20)			MCWB	10.0	7.9	11.0	11.3	15.1	18.0	19.4	19.4	17.8	13.7	12.5	10.4	(20)
(21)		2%	DB	9.2	10.5	13.3	16.4	22.4	25.4	27.6	27.0	24.1	16.6	12.3	8.9	(21)
(22)			MCWB	8.2	8.4	8.8	9.8	14.4	16.9	18.4	18.6	16.6	12.7	11.2	8.1	(22)
(23)		5%	DB	8.3	9.3	11.4	14.5	20.5	22.7	25.7	25.3	21.9	15.1	11.1	7.9	(23)
(24)			MCWB	7.5	7.7	8.1	9.3	13.9	15.8	18.0	18.0	15.6	12.4	10.2	7.3	(24)
(25)		10%	DB	7.3	8.2	10.0	12.8	18.5	20.7	24.0	23.6	19.9	13.7	10.0	6.9	(25)
(26)			MCWB	6.5	6.8	7.7	8.6	12.9	14.9	17.2	17.3	15.0	11.5	9.0	6.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	10.6	11.7	12.6	16.2	19.1	20.3	20.2	18.8	15.5	13.0	10.5	(27)
(28)			MCD B	10.7	10.7	14.6	17.0	22.0	26.4	28.0	26.7	24.4	17.2	13.3	10.8	(28)
(29)		2%	WB	8.7	9.2	10.1	11.3	15.2	17.5	19.2	19.1	17.6	14.2	11.5	8.5	(29)
(30)			MCD B	8.9	9.6	12.0	14.6	20.7	23.9	26.2	25.5	21.9	15.4	12.0	8.7	(30)
(31)		5%	WB	7.7	8.0	8.7	10.2	14.3	16.2	18.3	18.5	16.6	12.9	10.4	7.3	(31)
(32)			MCD B	8.1	9.0	10.3	12.8	19.1	21.5	24.4	24.3	20.2	14.1	11.0	7.6	(32)
(33)		10%	WB	6.6	7.0	7.9	9.2	13.4	15.3	17.5	17.7	15.6	11.9	9.2	6.3	(33)
(34)			MCD B	7.1	7.9	9.4	11.7	17.7	19.9	22.9	22.7	18.8	13.3	9.8	6.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.8	4.7	5.6	6.9	7.8	7.4	8.6	8.1	6.8	5.3	4.3	3.5	(35)
(36)			MCDBR	4.5	5.6	8.0	9.8	11.0	10.9	11.3	10.7	9.6	7.4	4.9	4.0	(36)
(37)			MCWBR	3.6	3.9	4.8	5.4	5.6	5.3	5.1	5.1	5.0	4.6	3.9	3.5	(37)
(38)		5% WB	MCDBR	3.7	4.3	6.2	7.6	9.6	9.9	10.4	10.0	8.2	5.7	4.3	3.6	(38)
(39)			MCWBR	3.4	3.4	4.4	4.8	5.2	5.1	5.0	5.0	4.6	4.0	3.8	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.304	0.328	0.358	0.374	0.367	0.358	0.360	0.340	0.331	0.313	0.298	(40)	
(41)		taud	2.396	2.470	2.422	2.376	2.383	2.425	2.478	2.487	2.543	2.546	2.500	2.428	(41)	
(42)		Ebn at Noon	736	852	884	888	885	892	895	878	864	810	737	702	(42)	
(43)		Edh at Noon	65	76	95	110	114	111	103	98	84	71	59	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.83	1.68	2.47	3.89	5.14	5.46	6.17	5.25	3.59	1.97	0.97	0.66	(44)	
(45)		RadStd	0.15	0.27	0.37	0.45	0.47	0.71	0.60	0.44	0.34	0.30	0.20	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page