

MOUNT FOREST, ON, Canada

WMO: 716310

Lat: 43.9895N

Lon: 80.7447W

Elev: 415

StdP: 96.44

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.2	-18.3	-25.0	0.4	-20.6	-21.6	0.6	-17.8	9.4	-6.2	8.6	-6.3	2.4	340	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	28.9	21.2	27.3	20.4	25.9	19.6	22.7	26.8	21.7	25.6	20.9	24.4	3.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	16.9	24.6	20.5	16.0	23.8	19.6	15.1	23.0	69.0	26.7	65.5	25.6	62.3	24.4	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.4	6.5	DB	-26.1	31.1	3.4	1.3	-28.6	32.0	-30.5	32.7	-32.4	33.5	-34.9	34.4	(4)
(5)			WB	-26.1	24.8	3.6	1.2	-28.6	25.6	-30.8	26.3	-32.8	27.0	-35.4	27.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-7.5	-6.8	-2.0	5.1	11.9	17.1	19.3	18.5	15.0	8.6	2.0	-3.7	(6)	
	DBStd	10.76	6.48	6.04	6.33	5.27	4.94	3.94	3.24	3.04	4.21	4.78	5.04	5.18	(7)	
	HDD10.0	2348	541	469	377	165	36	2	0	0	7	86	242	424	(8)	
	HDD18.3	4463	799	702	632	398	209	68	28	36	117	303	489	682	(9)	
	CDD10.0	1081	0	0	3	17	94	214	287	264	156	42	3	0	(10)	
	CDD18.3	156	0	0	0	1	9	31	57	41	16	2	0	0	(11)	
	CDH23.3	1093	0	0	1	4	73	242	407	252	106	7	0	0	(12)	
	CDH26.7	197	0	0	0	0	10	49	81	41	16	0	0	0	(13)	
(14) Wind	WSAvg	3.0	3.6	3.5	3.4	3.5	2.9	2.4	2.3	2.2	2.4	3.0	3.4	3.5	(14)	
(15) Precipitation	PrecAvg	977	85	67	62	75	87	86	92	78	86	81	88	78	(15)	
	PrecMax	1232	128	118	151	125	177	195	151	147	150	154	164	135	(16)	
	PrecMin	686	50	24	25	28	33	41	31	34	28	24	30	34	(17)	
	PrecStd	133	23	24	30	32	33	39	37	30	31	37	31	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	9.7	18.9	23.6	28.0	30.1	30.7	30.0	28.7	24.3	16.5	11.3	(19)	
		MCWB	9.8	8.4	14.9	15.6	19.0	22.3	22.3	21.5	21.1	17.9	12.6	10.3	(20)	
	2%	DB	6.1	6.0	13.5	19.5	25.6	28.1	28.9	27.6	26.2	21.1	13.8	7.3	(21)	
		MCWB	5.8	4.8	9.9	13.2	18.2	20.7	21.5	20.7	19.8	16.5	11.4	6.5	(22)	
	5%	DB	3.3	3.3	9.8	16.5	22.9	26.3	27.2	26.0	24.1	18.6	11.6	4.9	(23)	
		MCWB	2.7	2.0	7.2	11.4	16.2	19.6	20.4	20.0	18.7	15.2	9.6	4.1	(24)	
	10%	DB	1.1	1.2	6.7	13.8	20.4	24.2	25.6	24.5	22.1	16.1	9.5	2.5	(25)	
		MCWB	0.6	0.2	4.4	9.3	14.6	18.4	19.5	19.0	17.6	13.3	7.9	1.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	8.7	15.4	17.0	21.0	23.2	24.4	23.8	22.5	19.9	14.1	10.4	(27)	
		MCDB	9.8	9.3	18.9	21.2	26.1	28.2	28.7	26.6	26.8	22.7	15.2	11.0	(28)	
	2%	WB	5.9	5.0	10.7	14.4	19.3	22.0	22.9	22.1	21.1	17.5	11.9	6.7	(29)	
		MCDB	6.2	6.2	12.4	18.2	23.9	26.7	26.9	25.8	24.3	19.8	13.5	7.3	(30)	
	5%	WB	2.8	2.1	7.3	12.3	17.7	20.8	21.8	21.1	19.7	15.4	9.8	4.1	(31)	
		MCDB	3.2	3.2	9.5	15.4	21.7	24.7	25.4	24.5	22.6	18.2	11.1	4.9	(32)	
	10%	WB	0.6	0.3	4.5	9.8	15.9	19.5	20.8	20.2	18.5	13.6	7.9	1.9	(33)	
		MCDB	1.0	1.1	6.4	13.5	19.3	23.0	24.2	23.2	21.4	15.8	9.5	2.4	(34)	
(35) Mean Daily Temperature Range	MDBR		7.1	7.7	8.2	9.6	10.4	10.1	10.3	10.0	9.9	8.2	6.5	5.8	(35)	
	5% DB	MCDBR	7.5	8.7	11.2	13.8	12.4	12.0	11.5	11.3	11.7	11.2	9.9	7.4	(36)	
		MCWBR	7.4	7.9	8.5	9.2	7.0	6.6	5.9	5.9	6.5	7.2	8.0	7.0	(37)	
	5% WB	MCDBR	7.6	8.2	10.4	12.2	11.0	10.2	9.6	9.4	9.6	9.9	8.9	7.3	(38)	
		MCWBR	7.6	7.9	8.6	9.4	7.0	6.4	5.8	5.8	6.2	7.2	7.9	7.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.278	0.311	0.312	0.349	0.375	0.400	0.396	0.388	0.358	0.343	0.303	0.276	(40)	
	taud		2.336	2.201	2.392	2.356	2.328	2.267	2.302	2.313	2.399	2.426	2.489	2.401	(41)	
	Ebn at Noon		848	870	928	915	896	870	869	865	866	832	820	818	(42)	
	Edh at Noon		79	109	103	117	124	132	126	121	102	87	69	68	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.28	2.19	3.49	4.50	5.42	5.97	5.97	5.15	4.07	2.40	1.40	0.91	(44)	
	RadStd		0.17	0.28	0.38	0.45	0.50	0.40	0.36	0.26	0.38	0.25	0.21	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page