

PEKISKO, AB, Canada

WMO: 716690

Lat: 50.370N

Lon: 114.420W

Elev: 4642

StdP: 12.39

Time Zone: -7.00 (NAM)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.8	-15.4	-28.0	1.4	-22.2	-21.0	2.1	-15.6	14.3	37.9	12.0	37.1	1.2	240	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.6	80.9	57.8	77.6	57.1	74.3	56.0	61.6	73.0	59.8	72.1	58.0	70.6	2.9	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	83.7	66.0	55.0	76.6	64.7	53.0	71.0	62.0	29.7	72.3	28.4	72.3	27.1	70.7	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	8.6	6.9	DB	-30.0	87.6	6.1	3.9	-34.4	90.3	-38.0	92.6	-41.4	94.8	-45.9	97.6	(4)
(5)			WB	-30.7	64.9	6.1	1.7	-35.1	66.2	-38.7	67.1	-42.1	68.1	-46.6	69.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.6	22.1	18.6	27.7	36.1	45.2	51.8	58.2	56.2	48.8	38.3	27.4	19.4
	DBStd	17.46	14.37	15.13	13.25	9.03	7.70	5.77	5.14	5.72	8.07	9.09	13.16	14.65
	HDD50	5223	864	878	691	422	189	44	5	15	117	370	678	950
	HDD65	10006	1329	1298	1156	868	612	395	218	275	485	827	1128	1415
	CDD50	701	0	0	0	4	41	99	258	207	82	9	1	0
	CDD65	9	0	0	0	0	0	1	6	2	0	0	0	0
	CDH74	772	0	0	0	2	33	71	331	264	70	1	0	0
	CDH80	134	0	0	0	0	2	9	67	49	7	0	0	0
Wind	WSAvg	2.4	2.9	2.6	3.0	2.4	2.1	2.0	1.9	1.7	1.9	2.4	2.9	2.8
Precipitation	PrecAvg	22.9	0.9	0.9	1.4	1.9	3.1	4.5	2.4	2.4	2.0	1.3	1.2	1.0
	PrecMax	38.1	1.7	1.6	3.9	3.5	6.1	15.7	6.5	5.0	6.0	2.6	3.0	2.3
	PrecMin	14.4	0.2	0.1	0.6	0.8	0.5	0.7	0.2	0.2	0.0	0.1	0.1	0.2
	PrecStd	5.2	0.4	0.4	0.7	0.7	1.7	3.1	1.6	1.2	1.3	0.7	0.7	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	50.3	55.5	69.6	78.1	80.9	86.1	85.1	80.4	66.8	57.8	49.9
		MCWB	38.1	38.3	39.5	48.1	52.2	59.1	58.8	57.2	55.6	49.6	42.9	38.0
	2%	DB	46.1	46.0	51.2	62.8	72.6	75.5	81.3	80.5	75.6	61.3	52.1	45.4
		MCWB	36.1	36.6	38.1	44.4	50.5	55.7	58.4	57.7	53.7	46.7	40.6	35.6
	5%	DB	42.9	42.7	48.0	56.6	67.7	71.0	77.6	76.5	70.9	56.7	47.8	41.6
		MCWB	34.0	34.1	37.0	40.9	49.2	54.1	58.5	57.4	52.8	44.4	38.7	33.2
	10%	DB	40.5	39.0	44.7	51.4	63.2	67.0	73.9	72.6	65.6	52.4	43.9	38.3
		MCWB	32.7	31.3	34.8	38.5	46.9	52.2	57.7	56.3	50.7	42.0	35.4	31.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.6	38.7	41.4	48.9	54.2	62.3	64.7	63.1	59.2	50.7	44.2	39.2
		MCDB	49.9	47.1	51.1	69.6	70.9	73.7	74.4	74.9	70.1	63.8	55.3	48.1
	2%	WB	36.9	36.5	39.4	45.4	51.5	58.1	62.2	60.7	55.9	48.1	41.2	35.5
		MCDB	45.3	45.2	50.1	62.7	68.3	71.0	72.5	73.5	70.3	59.1	50.5	42.7
	5%	WB	34.7	34.1	37.3	42.1	49.7	55.4	60.5	59.1	53.7	45.0	38.2	33.2
		MCDB	41.8	41.7	47.0	54.8	64.9	68.2	72.4	72.2	68.9	54.9	45.8	40.7
	10%	WB	32.8	31.3	35.4	39.4	47.6	53.1	58.8	57.3	51.3	42.1	35.2	31.1
		MCDB	39.8	38.0	44.8	49.0	60.6	64.4	70.9	70.2	63.6	50.8	41.9	38.0
Mean Daily Temperature Range	5% DB	MDBR	19.4	21.3	21.2	21.8	24.1	23.9	27.6	27.9	25.6	20.2	17.3	17.6
		MCDBR	19.1	21.5	23.4	31.4	35.1	32.6	35.7	37.0	35.9	26.7	21.1	18.2
		MCWBR	12.0	12.6	13.3	16.4	16.5	16.0	17.7	17.1	17.0	14.0	12.7	11.8
	5% WB	MCDBR	18.7	20.3	23.4	31.4	32.6	29.4	30.8	31.8	33.7	25.7	20.2	17.3
		MCWBR	13.1	13.5	13.7	16.4	15.7	15.8	17.2	17.0	16.7	14.4	12.8	11.9
Clear-Sky Solar Irradiance	taub	0.240	0.263	0.274	0.326	0.331	0.330	0.328	0.340	0.302	0.272	0.249	0.229	
	taud	2.444	2.400	2.448	2.331	2.405	2.447	2.465	2.434	2.527	2.589	2.536	2.452	
	Ebn at Noon	265	284	300	291	293	294	293	284	286	279	261	254	
	Edh at Noon	18	25	29	36	35	34	33	32	26	21	16	16	
All-Sky Solar Radiation	RadAvg	356	659	1009	1448	1680	1789	2054	1699	1188	733	381	282	
	RadStd	27	46	77	97	142	147	156	122	128	73	30	19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page