

PEKISKO, AB, Canada

WMO: 716690

Lat: 50.370N

Lon: 114.420W

Elev: 1415

StdP: 85.44

Time Zone: -7.00 (NAM)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-29.9	-26.3	-33.3	0.2	-30.1	-29.4	0.3	-26.5	6.4	3.3	5.3	2.8	0.5	240	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	27.2	14.3	25.3	13.9	23.5	13.3	16.4	22.8	15.4	22.3	14.4	21.4	1.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	12.0	18.9	12.8	10.9	18.2	11.6	10.1	16.7	51.2	22.4	48.2	22.4	45.1	21.5	20.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	3.8	3.1	DB	-34.5	30.9	3.4	2.1	-36.9	32.4	-38.9	33.7	-40.8	34.9	-43.3	36.4	(4)
(5)			WB	-34.8	18.3	3.4	0.9	-37.3	19.0	-39.3	19.5	-41.2	20.0	-43.6	20.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.1	-5.5	-7.4	-2.4	2.3	7.4	11.0	14.5	13.4	9.4	3.5	-2.6	-7.0	(6)	
	DBStd	9.70	7.98	8.40	7.36	5.02	4.28	3.21	2.86	3.18	4.48	5.05	7.31	8.14	(7)	
	HDD10.0	2902	480	488	384	234	105	24	3	8	65	206	377	528	(8)	
	HDD18.3	5559	738	721	642	482	340	219	121	153	269	459	627	786	(9)	
	CDD10.0	389	0	0	0	2	23	55	143	115	46	5	1	0	(10)	
	CDD18.3	5	0	0	0	0	0	1	3	1	0	0	0	0	(11)	
	CDH23.3	429	0	0	0	1	18	39	184	147	39	1	0	0	(12)	
	CDH26.7	74	0	0	0	0	1	5	37	27	4	0	0	0	(13)	
(14) Wind	WSAvg	1.1	1.3	1.2	1.3	1.1	0.9	0.9	0.8	0.8	0.8	1.1	1.3	1.3	(14)	
(15) Precipitation	PrecAvg	582	22	24	35	47	80	114	60	61	52	33	30	25	(15)	
	PrecMax	967	42	41	98	90	155	400	164	126	153	65	77	58	(16)	
	PrecMin	366	6	3	16	20	13	19	6	5	1	3	2	5	(17)	
	PrecStd	132	9	10	17	19	42	78	41	30	33	17	18	13	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	10.2	13.0	20.9	25.6	27.1	30.1	29.5	26.9	19.3	14.3	10.0	(19)	
		MCWB	3.4	3.5	4.1	9.0	11.2	15.0	14.9	14.0	13.1	9.8	6.1	3.4	(20)	
	2%	DB	7.9	7.8	10.7	17.1	22.5	24.1	27.4	26.9	24.2	16.3	11.2	7.4	(21)	
		MCWB	2.3	2.5	3.4	6.9	10.3	13.2	14.7	14.3	12.0	8.2	4.8	2.0	(22)	
	5%	DB	6.1	6.0	8.9	13.7	19.8	21.7	25.3	24.7	21.6	13.7	8.8	5.4	(23)	
		MCWB	1.1	1.2	2.8	5.0	9.6	12.3	14.7	14.1	11.6	6.9	3.7	0.7	(24)	
	10%	DB	4.7	3.9	7.1	10.8	17.3	19.4	23.3	22.6	18.7	11.3	6.6	3.5	(25)	
		MCWB	0.4	-0.4	1.6	3.6	8.3	11.2	14.3	13.5	10.4	5.6	1.9	-0.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	3.7	5.2	9.4	12.3	16.8	18.2	17.3	15.1	10.4	6.8	4.0	(27)	
		MCDB	9.9	8.4	10.6	20.9	21.6	23.2	23.6	23.8	21.2	17.7	13.0	9.0	(28)	
	2%	WB	2.7	2.5	4.1	7.4	10.8	14.5	16.8	16.0	13.3	8.9	5.1	1.9	(29)	
		MCDB	7.4	7.3	10.1	17.0	20.2	21.6	22.5	23.0	21.3	15.1	10.3	6.0	(30)	
	5%	WB	1.5	1.2	3.0	5.6	9.9	13.0	15.9	15.1	12.1	7.2	3.4	0.7	(31)	
		MCDB	5.5	5.4	8.3	12.7	18.3	20.1	22.5	22.3	20.5	12.7	7.7	4.8	(32)	
	10%	WB	0.4	-0.4	1.9	4.1	8.7	11.7	14.9	14.1	10.7	5.6	1.8	-0.5	(33)	
		MCDB	4.3	3.3	7.1	9.4	15.9	18.0	21.6	21.2	17.6	10.5	5.5	3.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	11.9	11.8	12.1	13.4	13.3	15.3	15.5	14.2	11.2	9.6	9.8	(35)	
		MCDBR	10.6	11.9	13.0	17.4	19.5	18.1	19.8	20.5	20.0	14.8	11.7	10.1	(36)	
	5% WB	MCWBR	6.7	7.0	7.4	9.1	9.2	8.9	9.8	9.5	9.4	7.8	7.1	6.6	(37)	
		MCWBR	10.4	11.3	13.0	17.5	18.1	16.3	17.1	17.7	18.7	14.3	11.2	9.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.240	0.263	0.274	0.326	0.331	0.330	0.328	0.340	0.302	0.272	0.249	0.229	(40)	
		taud	2.444	2.400	2.448	2.331	2.405	2.447	2.465	2.434	2.527	2.589	2.536	2.452	(41)	
	Ebn at Noon	Ebn at Noon	836	894	945	917	925	926	923	894	902	881	823	801	(42)	
		Edh at Noon	57	78	90	114	111	107	104	102	83	65	52	49	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.12	2.08	3.18	4.57	5.30	5.64	6.47	5.36	3.74	2.31	1.20	0.89	(44)	
	RadStd	RadStd	0.09	0.14	0.24	0.30	0.45	0.46	0.49	0.39	0.41	0.23	0.09	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page