

KENTVILLE, NS, CanadaWMO: **716710**Lat: **45.070N**Lon: **64.480W**Elev: **160**StdP: **14.61**Time Zone: **-4.00 (NAA)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.5	5.6	-5.4	4.1	4.1	-2.0	5.0	8.8	21.9	24.4	20.2	25.1	8.1	280	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	84.3	70.1	81.6	68.5	79.0	67.3	72.9	80.4	71.3	78.2	69.7	76.1	8.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.3	112.1	77.2	68.8	106.5	75.6	67.3	100.9	73.8	36.6	80.5	35.2	78.3	33.9	76.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.8	16.4	14.2	-3.9	89.4	4.7	2.8	-7.3	91.4	-10.0	93.0	-12.7	94.6	-16.1	96.6		
(5)			-4.5	75.5	4.5	1.4	-7.7	76.5	-10.4	77.3	-12.9	78.1	-16.2	79.1	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.0	23.6	24.4	31.1	41.8	52.3	61.0	68.3	67.5	60.6	49.7	40.2	30.4	(6)	
	DBStd	17.39	10.27	9.42	8.51	7.11	6.55	6.47	4.76	4.87	6.80	7.34	8.42	9.28	(7)	
	HDD50	3458	819	717	586	263	48	3	0	0	4	97	311	610	(8)	
	HDD65	7233	1284	1137	1050	697	397	154	22	30	167	478	743	1074	(9)	
	CDD50	2004	0	0	2	16	119	332	567	541	321	86	18	2	(10)	
	CDD65	302	0	0	0	0	3	33	124	106	34	2	0	0	(11)	
	CDH74	2109	0	0	1	5	52	281	875	702	185	8	0	0	(12)	
	CDH80	407	0	0	0	1	6	51	179	137	33	0	0	0	(13)	
(14) Wind	WSAvg	6.1	7.2	7.5	7.4	6.9	5.9	5.1	4.7	4.6	5.0	5.8	6.6	7.0	(14)	
(15) Precipitation	PrecAvg	46.0	4.2	3.7	3.8	3.5	3.6	3.1	3.1	3.0	3.9	4.4	4.8	5.0	(15)	
	PrecMax	60.0	7.1	6.5	8.4	5.7	7.9	8.4	6.3	6.7	10.4	9.3	9.0	9.0	(16)	
	PrecMin	35.6	1.6	1.3	1.0	1.1	1.3	0.4	0.8	0.8	1.3	1.0	2.0	2.1	(17)	
	PrecStd	5.5	1.3	1.4	1.7	1.1	1.9	1.9	1.6	1.6	2.2	2.0	1.8	1.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.9	54.2	60.8	70.5	80.1	85.5	87.9	87.6	84.2	74.5	66.5	59.4	(19)	
		MCWB	55.2	51.3	52.3	57.4	63.1	69.1	71.0	72.0	69.8	64.0	62.0	57.1	(20)	
	2%	DB	50.2	47.5	52.4	63.0	73.9	80.7	84.3	83.7	78.9	69.3	62.0	53.9	(21)	
		MCWB	47.7	44.8	47.0	54.2	59.8	66.6	70.6	69.9	67.9	62.0	58.6	51.8	(22)	
	5%	DB	43.2	41.8	48.1	58.6	69.3	77.0	81.8	80.7	75.3	65.7	58.4	48.8	(23)	
		MCWB	40.7	38.7	43.4	50.5	57.9	65.1	69.1	68.2	66.3	60.7	55.3	46.6	(24)	
	10%	DB	37.6	37.6	43.6	54.5	65.2	73.6	79.1	77.9	72.3	62.2	54.0	43.6	(25)	
		MCWB	35.3	35.3	39.0	47.9	55.4	63.0	67.6	67.0	64.9	57.3	50.8	41.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	51.3	53.4	61.1	66.4	72.3	75.0	74.5	73.1	67.5	63.2	57.3	(27)	
		MCDB	57.9	52.8	57.6	66.5	76.3	81.1	83.7	83.6	79.4	71.4	65.8	59.0	(28)	
	2%	WB	48.1	45.5	48.8	56.9	63.2	70.0	73.1	72.6	70.4	63.9	59.4	52.0	(29)	
		MCDB	49.7	47.4	51.7	61.2	70.1	77.4	80.9	79.9	76.2	67.4	61.6	53.7	(30)	
	5%	WB	41.0	39.3	43.9	52.8	60.2	67.7	71.5	70.8	68.4	61.4	55.7	47.1	(31)	
		MCDB	42.9	41.2	47.2	56.9	66.5	74.2	78.7	77.4	73.2	64.9	57.8	48.6	(32)	
	10%	WB	35.6	35.3	39.4	48.5	56.9	65.0	69.8	69.1	66.3	58.0	50.9	41.6	(33)	
		MCDB	37.2	37.2	42.9	53.1	63.3	71.8	76.3	75.3	70.8	61.6	53.5	43.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	15.0	15.2	16.5	18.9	18.7	18.6	18.7	18.6	16.1	13.6	12.9	(35)	
		MCDBR	22.4	19.8	21.2	25.1	26.0	24.4	23.0	22.6	21.3	20.9	18.9	19.7	(36)	
	5% WB	MCWBR	21.8	17.7	17.0	16.9	15.0	13.4	12.1	11.7	12.7	14.9	16.6	19.4	(37)	
		MCWBR	21.9	19.6	20.2	21.1	21.5	20.7	19.2	18.2	17.1	17.6	18.1	19.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.295	0.290	0.323	0.349	0.371	0.394	0.417	0.396	0.361	0.329	0.309	0.293	(40)	
		taud	2.451	2.490	2.448	2.419	2.399	2.352	2.308	2.368	2.443	2.534	2.542	2.504	(41)	
	Ebn at Noon	Ebn at Noon	261	287	290	290	285	278	269	271	273	268	256	251	(42)	
		Edh at Noon	22	26	31	35	36	38	40	36	31	24	21	19	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	460	732	1100	1364	1578	1719	1750	1587	1269	815	460	351	(44)	
		RadStd	38	54	75	127	180	154	121	108	89	87	50	26	(45)	

Historical Trends