

KENTVILLE, NS, CanadaWMO: **716710**Lat: **45.070N**Lon: **64.480W**Elev: **49**StdP: **100.74**Time Zone: **-4.00 (NAA)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-14.6	-20.8	0.6	-15.5	-18.9	0.7	-12.9	9.8	-4.2	9.1	-3.8	3.6	280	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	29.0	21.2	27.5	20.3	26.1	19.6	22.7	26.9	21.8	25.7	21.0	24.5	3.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.3	16.0	25.1	20.5	15.2	24.2	19.6	14.4	23.2	67.3	27.0	64.0	25.7	60.9	24.5	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.3	6.4	-19.9	31.9	2.6	1.5	-21.8	33.0	-23.3	33.9	-24.8	34.8	-26.7	35.9		
(5)			-20.3	24.2	2.5	0.8	-22.1	24.7	-23.5	25.2	-24.9	25.6	-26.8	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-4.7	-4.2	-0.5	5.4	11.3	16.1	20.2	19.7	15.9	9.8	4.6	-0.9
	DBStd	9.66	5.70	5.23	4.73	3.95	3.64	3.59	2.64	2.71	3.78	4.08	4.68	5.15
	HDD10.0	1921	455	398	326	146	27	2	0	0	2	54	173	339
	HDD18.3	4018	713	632	583	387	221	86	12	17	93	266	413	597
	CDD10.0	1113	0	0	1	9	66	184	315	301	178	48	10	1
	CDD18.3	168	0	0	0	0	2	18	69	59	19	1	0	0
	CDH23.3	1172	0	0	1	3	29	156	486	390	103	4	0	0
	CDH26.7	226	0	0	0	1	3	28	99	76	18	0	0	0
Wind	WSAvg	2.7	3.2	3.4	3.3	3.1	2.7	2.3	2.1	2.1	2.2	2.6	2.9	3.1
Precipitation	PrecAvg	1169	107	93	97	88	91	78	78	77	100	111	121	128
	PrecMax	1525	180	165	213	145	201	214	160	171	263	237	228	228
	PrecMin	904	40	33	25	28	32	10	20	21	32	25	51	54
	PrecStd	140	34	36	42	28	48	47	40	41	57	51	46	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	12.3	16.0	21.4	26.7	29.7	31.1	30.9	29.0	23.6	19.2	15.2
		MCWB	12.9	10.7	11.3	14.1	17.3	20.6	21.7	22.2	21.0	17.8	16.6	14.0
	2%	DB	10.1	8.6	11.3	17.2	23.3	27.1	29.0	28.7	26.0	20.7	16.7	12.2
		MCWB	8.7	7.1	8.4	12.4	15.5	19.2	21.5	21.1	19.9	16.7	14.8	11.0
	5%	DB	6.2	5.4	8.9	14.8	20.7	25.0	27.7	27.0	24.0	18.7	14.7	9.4
		MCWB	4.9	3.7	6.3	10.3	14.4	18.4	20.6	20.1	19.1	15.9	12.9	8.1
	10%	DB	3.1	3.1	6.5	12.5	18.4	23.1	26.2	25.5	22.4	16.8	12.2	6.4
		MCWB	1.8	1.8	3.9	8.8	13.0	17.2	19.8	19.4	18.3	14.0	10.4	5.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	10.7	11.9	16.1	19.1	22.4	23.9	23.6	22.9	19.7	17.3	14.1
		MCDB	14.4	11.5	14.2	19.2	24.6	27.3	28.7	28.6	26.4	21.9	18.8	15.0
	2%	WB	9.0	7.5	9.3	13.9	17.3	21.1	22.9	22.6	21.4	17.7	15.2	11.1
		MCDB	9.8	8.6	10.9	16.2	21.2	25.2	27.2	26.6	24.6	19.7	16.5	12.1
	5%	WB	5.0	4.0	6.6	11.5	15.7	19.9	22.0	21.6	20.2	16.3	13.2	8.4
		MCDB	6.0	5.1	8.4	13.8	19.2	23.4	26.0	25.2	22.9	18.3	14.3	9.2
	10%	WB	2.0	1.9	4.1	9.2	13.8	18.3	21.0	20.6	19.1	14.5	10.5	5.4
		MCDB	2.9	2.9	6.1	11.7	17.4	22.1	24.6	24.1	21.5	16.4	12.0	6.3
Mean Daily Temperature Range	5% DB	MDBR	8.1	8.3	8.4	9.2	10.5	10.4	10.3	10.4	10.3	8.9	7.5	7.2
		MCDBR	12.4	11.0	11.8	13.9	14.5	13.5	12.8	12.6	11.8	11.6	10.5	10.9
		MCWBR	12.1	9.8	9.4	9.4	8.3	7.4	6.7	6.5	7.0	8.3	9.2	10.8
	5% WB	MCDBR	12.2	10.9	11.2	11.7	11.9	11.5	10.6	10.1	9.5	9.8	10.1	10.8
		MCWBR	12.0	10.3	10.2	9.6	8.0	7.1	6.3	6.0	6.6	8.2	9.6	10.8
Clear-Sky Solar Irradiance	taub	0.295	0.290	0.323	0.349	0.371	0.394	0.417	0.396	0.361	0.329	0.309	0.293	
	taud	2.451	2.490	2.448	2.419	2.399	2.352	2.308	2.368	2.443	2.534	2.542	2.504	
	Ebn at Noon	824	906	913	913	898	875	848	855	860	846	806	792	
	Edh at Noon	70	81	97	109	115	121	125	114	97	77	65	61	
All-Sky Solar Radiation	RadAvg	1.45	2.31	3.47	4.30	4.97	5.42	5.52	5.00	4.00	2.57	1.45	1.11	
	RadStd	0.12	0.17	0.24	0.40	0.57	0.48	0.38	0.34	0.28	0.28	0.16	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	+0.35	+0.48	N/A	N/A	+51	N/A

Nomenclature: See separate page