

FERINTOSH AGCM, AB, Canada

WMO: 716730

Lat: 52.7439N

Lon: 112.8580W

Elev: 795

StdP: 92.13

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-30.3	-27.5	-33.7	0.2	-30.1	-30.7	0.2	-27.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	27.6	16.7	26.1	16.4	24.5	15.5	19.4	24.7	18.1	23.6	17.0	22.3	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.4	13.7	22.6	15.9	12.5	20.9	14.8	11.6	19.7	58.8	24.5	54.5	23.7	50.8	22.3	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-34.1	30.8	3.1	2.1	-36.3	32.4	-38.2	33.6	-39.9	34.8	-42.2	36.4		
(5)			-34.2	21.8	3.1	1.6	-36.5	22.9	-38.3	23.9	-40.0	24.7	-42.2	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-9.4	-11.2	-4.9	2.8	10.4	14.2	16.0	15.2	10.6	3.7	-4.7	-10.6	(6)
(7)		DBStd	11.62	7.72	8.12	7.76	5.37	4.51	2.92	2.64	3.03	4.43	4.80	7.12	7.40	(7)
(8)		HDD10.0	3265	602	594	462	222	51	4	0	2	45	202	441	640	(8)
(9)		HDD18.3	5711	860	828	721	467	246	127	82	104	233	454	691	898	(9)
(10)		CDD10.0	615	0	0	0	5	64	130	185	162	63	6	1	0	(10)
(11)		CDD18.3	20	0	0	0	0	1	3	8	6	2	0	0	0	(11)
(12)		CDH23.3	582	0	0	0	2	67	73	163	177	98	3	0	0	(12)
(13)		CDH26.7	86	0	0	0	0	8	4	21	30	22	0	0	0	(13)
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15)	Precipitation	PrecAvg	423	21	12	18	31	47	79	77	57	34	19	15	14	(15)
(16)		PrecMax	529	63	26	38	60	85	114	166	107	77	45	56	30	(16)
(17)		PrecMin	289	1	3	2	4	16	25	24	6	3	5	3	5	(17)
(18)		PrecStd	71	15	7	9	16	21	26	34	24	20	9	12	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	6.2	13.1	22.4	27.9	27.1	29.0	28.8	29.5	22.4	14.7	6.1	(19)
(20)			MCWB	2.7	2.6	7.2	10.1	12.7	16.1	20.2	16.8	15.3	12.1	7.3	2.9	(20)
(21)		2%	DB	5.0	3.8	9.4	18.4	25.3	25.5	26.9	27.3	26.2	17.6	9.6	3.9	(21)
(22)			MCWB	2.1	1.0	4.5	8.5	11.9	15.4	18.7	17.5	14.2	9.7	4.7	1.1	(22)
(23)		5%	DB	3.4	2.1	6.5	14.9	22.8	23.7	25.3	25.4	23.4	14.7	6.4	1.6	(23)
(24)			MCWB	1.1	0.0	3.0	6.7	11.3	14.5	17.8	17.3	13.4	7.9	2.8	-0.7	(24)
(25)		10%	DB	1.5	0.3	4.2	12.0	20.1	21.7	23.4	23.4	20.1	11.9	4.2	-0.8	(25)
(26)			MCWB	-0.4	-1.3	1.4	5.4	10.1	13.5	16.9	16.5	12.2	6.5	1.5	-2.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	2.8	7.3	10.7	13.9	18.7	21.9	20.8	16.6	12.5	7.6	3.3	(27)
(28)			MCDWB	6.2	5.8	12.1	21.5	23.5	24.6	27.1	25.6	25.6	21.3	14.3	5.5	(28)
(29)		2%	WB	2.2	1.4	4.8	8.7	12.8	17.0	19.8	19.2	15.3	10.3	5.1	1.2	(29)
(30)			MCDWB	4.7	3.5	8.8	17.7	22.5	22.8	25.0	24.7	24.0	15.8	8.9	3.6	(30)
(31)		5%	WB	1.1	0.0	3.1	7.1	11.9	15.7	18.5	18.0	13.9	8.6	3.2	-0.5	(31)
(32)			MCDWB	3.2	1.7	6.2	13.6	20.8	20.9	23.8	23.7	21.5	13.6	5.8	1.5	(32)
(33)		10%	WB	-0.4	-1.4	1.6	5.7	10.9	14.5	17.4	16.8	12.7	7.0	1.8	-2.5	(33)
(34)			MCDWB	1.4	0.3	3.9	11.3	18.8	19.8	22.5	22.1	19.8	11.4	3.7	-1.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.1	10.6	10.5	11.9	13.7	12.3	12.8	13.9	14.2	12.1	9.9	9.2	(35)
(36)			MCDBR	10.7	11.6	12.8	17.9	17.8	15.7	16.0	17.8	20.6	17.0	12.5	10.5	(36)
(37)			MCWBR	8.5	9.4	8.5	9.2	7.6	7.3	9.2	9.5	9.9	9.5	8.4	8.2	(37)
(38)		5% WB	MCDBR	11.0	11.1	12.3	16.4	15.5	13.5	14.5	15.6	18.2	15.8	11.6	10.4	(38)
(39)			MCWBR	8.9	9.1	8.6	8.8	7.0	7.3	8.8	9.2	9.3	9.1	8.1	8.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.263	0.264	0.294	0.325	0.343	0.352	0.351	0.362	0.310	0.281	0.253	0.246	(40)	
(41)		taud	2.290	2.386	2.401	2.377	2.382	2.377	2.413	2.354	2.478	2.535	2.461	2.306	(41)	
(42)		Ebn at Noon	736	868	904	911	907	898	893	860	877	841	767	694	(42)	
(43)		Edh at Noon	60	75	91	107	112	114	108	108	84	64	51	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.06	2.11	3.55	4.71	5.75	6.07	6.32	5.17	3.58	2.12	1.06	0.77	(44)	
(45)		RadStd	0.10	0.17	0.26	0.45	0.37	0.39	0.32	0.35	0.38	0.25	0.11	0.07	(45)	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB		1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (88 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page