

LOWER CARP LAKE, NT, Canada

WMO: 716800

Lat: 63.600N

Lon: 113.850W

Elev: 373

StdP: 96.92

Time Zone: -7.00 (NAM)

Period: 98-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.0	-38.3	-44.6	0.0	-40.0	-42.7	0.1	-38.2	9.6	-16.1	8.7	-19.5	1.5	60	0.828

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	25.7	15.4	23.8	14.5	22.0	13.8	16.5	23.0	15.6	21.9	14.7	20.5	4.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.0	10.5	18.1	13.0	9.8	17.3	12.0	9.1	16.7	47.5	23.2	44.9	21.8	42.4	20.7	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.7	7.8	-41.9	27.9	1.5	1.0	-43.0	28.6	-43.9	29.2	-44.8	29.8	-45.9	30.5		
(5)			-42.0	17.6	1.6	0.9	-43.1	18.2	-44.0	18.7	-44.9	19.2	-46.0	19.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.5	-25.5	-23.9	-18.5	-8.3	2.5	11.9	16.3	12.9	6.4	-3.0	-14.3	-23.3	(6)
(7)		DBStd	16.13	7.94	6.90	8.73	7.62	6.30	4.70	3.64	3.89	4.58	4.88	6.42	7.92	(7)
(8)		HDD10.0	6066	1101	948	884	550	242	33	2	16	124	403	729	1034	(8)
(9)		HDD18.3	8716	1359	1181	1142	800	490	197	82	174	358	661	979	1292	(9)
(10)		CDD10.0	421	0	0	0	0	10	91	198	105	16	0	0	0	(10)
(11)		CDD18.3	29	0	0	0	0	0	5	19	4	0	0	0	0	(11)
(12)		CDH23.3	204	0	0	0	0	2	44	129	29	0	0	0	0	(12)
(13)		CDH26.7	26	0	0	0	0	0	7	16	3	0	0	0	0	(13)
(14)	Wind	WSAvg	3.6	2.5	3.0	3.6	3.9	4.2	4.1	3.9	4.1	4.4	4.0	3.0	2.5	(14)
(15)	Precipitation	PrecAvg	309	13	10	14	11	18	35	47	54	42	29	20	16	(15)
(16)		PrecMax	405	23	22	34	24	35	96	100	106	95	42	36	28	(16)
(17)		PrecMin	218	5	3	3	3	3	6	17	19	14	10	11	7	(17)
(18)		PrecStd	41	5	4	7	5	9	19	19	19	17	9	6	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.2	-6.0	3.7	11.3	22.8	27.7	28.6	26.3	20.1	12.3	-0.2	-4.4	(19)
(20)			MCWB	-3.3	-6.4	1.0	5.3	11.2	15.5	16.3	16.0	13.1	8.5	-0.5	-4.6	(20)
(21)		2%	DB	-6.1	-8.7	0.3	7.6	17.8	24.2	26.4	23.8	17.0	7.1	-1.6	-6.8	(21)
(22)			MCWB	-6.3	-9.1	-1.8	3.2	9.5	13.6	16.0	15.0	11.2	4.9	-1.9	-7.2	(22)
(23)		5%	DB	-10.0	-10.6	-2.6	5.4	14.7	22.1	24.6	21.6	14.8	4.6	-3.2	-9.4	(23)
(24)			MCWB	-10.4	-11.0	-4.1	1.8	7.5	13.0	15.3	14.4	10.3	3.3	-3.5	-9.7	(24)
(25)		10%	DB	-14.0	-13.4	-5.4	2.8	12.0	19.9	22.9	19.4	12.7	2.7	-5.4	-11.8	(25)
(26)			MCWB	-14.4	-13.8	-6.5	0.1	6.1	12.0	14.4	13.3	9.3	1.8	-5.7	-12.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.5	-6.4	1.2	5.6	11.7	16.0	17.9	17.1	13.7	9.2	-0.5	-4.6	(27)
(28)			MCDWB	-3.4	-6.1	3.4	10.3	20.2	23.6	24.9	23.7	18.3	11.9	0.0	-4.5	(28)
(29)		2%	WB	-6.5	-9.0	-1.8	3.4	9.9	14.8	16.9	15.9	12.0	5.2	-1.9	-7.1	(29)
(30)			MCDWB	-6.2	-8.7	0.2	7.3	17.9	22.5	23.5	22.0	15.8	6.7	-1.7	-6.9	(30)
(31)		5%	WB	-10.3	-11.0	-4.1	2.0	7.9	13.7	16.1	14.9	10.7	3.3	-3.5	-9.7	(31)
(32)			MCDWB	-10.1	-10.7	-2.6	5.2	14.1	20.3	22.5	20.2	14.2	4.5	-3.3	-9.5	(32)
(33)		10%	WB	-14.4	-13.7	-6.4	0.3	6.3	12.6	15.3	13.9	9.7	1.9	-5.7	-12.2	(33)
(34)			MCDWB	-14.1	-13.4	-5.3	2.6	11.4	19.0	21.5	18.3	12.2	2.7	-5.4	-11.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.3	8.6	10.8	11.9	10.3	9.5	8.8	7.7	6.1	4.7	6.1	6.6	(35)
(36)			MCDBR	7.3	8.8	11.6	12.4	13.8	12.1	11.1	11.0	9.7	7.0	5.7	7.5	(36)
(37)			MCWBR	7.5	8.7	9.6	8.6	7.3	4.7	4.1	4.5	5.1	4.9	5.6	7.5	(37)
(38)		5% WB	MCDBR	7.6	8.6	11.1	11.9	13.0	10.8	9.8	9.1	6.7	5.7	7.5	(38)	
(39)			MCWBR	7.6	8.6	9.2	8.2	7.0	4.7	4.2	4.6	5.1	4.9	5.6	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.174	0.227	0.257	0.288	0.322	0.325	0.353	0.326	0.296	0.262	0.171	0.147	(40)
(41)		taud		1.982	2.235	2.249	2.235	2.398	2.493	2.433	2.512	2.584	2.392	1.988	1.938	(41)
(42)		Ebn at Noon		471	741	853	895	893	897	855	853	819	687	457	276	(42)
(43)		Edh at Noon		28	55	83	107	101	94	98	82	62	48	26	12	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.23	1.05	2.84	5.06	5.96	6.02	5.30	3.93	2.29	0.80	0.22	0.09	(44)
(45)		RadStd		0.01	0.06	0.17	0.24	0.45	0.52	0.27	0.25	0.21	0.10	0.04	0.01	(45)

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)
		N/A	N/A	+1.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page