

ASHCROFT, BC, Canada

WMO: 716810

Lat: 50.708N

Lon: 121.281W

Elev: 1073

StdP: 14.14

Time Zone: -8.00 (NAP)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.4	(c) 5.9	(d) -9.9	(e) 3.4	(f) 4.7	(g) -4.5	(h) 4.5	(i) 7.9	(j) 14.1	(k) 41.7	(l) 12.1	(m) 32.9	(n) 3.4	(o) 0	(p) 0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 26.3	(c) 96.7	(d) 62.7	(e) 92.9	(f) 61.9	(g) 89.3	(h) 60.9	(i) 64.3	(j) 89.8	(k) 63.0	(l) 87.7	(m) 61.9	(n) 85.1	(o) 5.9	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.5	73.5	66.3	55.4	67.9	66.1	53.4	63.1	65.6	29.9	89.4	29.0	88.1	28.1	85.3	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.5	12.9	11.2		-4.1	102.2	5.7	2.8	-8.1	104.2	-11.5	105.8	-14.6	107.4	-18.8	109.4	
				DB	-4.6	67.5	5.9	2.0	-8.9	68.9	-12.4	70.1	-15.7	71.2	-20.0	72.7
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	27.6	29.3	42.0	50.5	61.5	67.3	73.6	72.8	62.5	49.1	35.8	27.9
	DBStd	18.36	9.22	10.54	7.60	5.68	6.53	6.26	6.11	5.62	6.83	6.25	9.87	8.86
	HDD50	2803	694	579	259	59	1	0	0	0	1	92	432	686
	HDD65	6165	1159	999	713	434	149	43	8	9	130	494	876	1151
	CDD50	2848	0	0	11	75	359	518	733	708	375	63	6	0
	CDD65	735	0	0	0	0	42	111	276	252	54	0	0	0
	CDH74	8909	0	0	1	44	701	1337	3369	2833	620	4	0	0
	CDH80	4091	0	0	0	10	248	548	1705	1351	229	0	0	0
Wind	WSAvg	3.7	2.2	3.1	3.9	4.8	4.7	5.2	4.8	4.1	3.7	3.0	2.8	2.3
Precipitation	PrecAvg	16.6	1.9	1.0	1.1	0.8	1.2	1.5	1.1	1.1	1.1	1.5	2.3	2.1
	PrecMax	20.8	3.2	2.2	2.4	1.6	2.7	2.6	2.7	4.3	2.1	3.4	5.6	4.0
	PrecMin	13.2	0.6	0.2	0.3	0.3	0.2	0.7	0.1	0.2	0.3	0.6	0.6	0.8
	PrecStd	2.0	0.6	0.5	0.6	0.3	0.7	0.5	0.7	0.9	0.5	0.6	1.2	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	53.2	67.8	79.8	91.6	97.1	102.3	100.1	92.2	72.9	62.5	50.6
		MCWB	41.8	43.0	49.7	55.4	59.0	62.3	64.7	63.8	62.2	55.9	50.0	41.8
	2%	DB	43.4	48.9	62.8	72.0	86.4	91.7	97.8	95.8	86.5	67.3	55.7	44.7
		MCWB	37.3	40.5	46.8	51.9	57.5	61.8	63.0	62.7	60.2	52.8	47.0	39.4
	5%	DB	39.2	45.3	58.5	66.8	82.1	86.3	94.0	91.6	81.3	63.5	51.4	40.2
		MCWB	35.5	38.8	44.9	48.8	56.4	59.2	62.4	61.9	58.8	50.2	44.1	36.7
	10%	DB	36.3	41.8	54.6	62.7	76.9	81.4	89.9	87.7	76.1	59.9	47.5	37.2
		MCWB	34.0	37.2	43.1	46.7	55.0	57.8	61.2	60.9	56.9	48.7	42.3	34.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	45.2	50.2	55.9	60.5	65.4	65.7	66.0	63.6	57.5	51.7	42.8
		MCDB	49.6	50.5	66.0	74.8	82.4	89.1	95.0	88.1	84.5	70.9	61.3	47.9
	2%	WB	38.0	41.7	47.5	53.1	58.7	62.5	64.4	64.1	61.7	54.4	47.7	39.7
		MCDB	42.1	46.3	60.6	70.2	83.0	87.9	92.2	88.1	81.6	64.6	54.5	44.4
	5%	WB	35.7	39.4	45.6	50.1	57.2	60.7	63.0	62.9	60.2	52.0	45.0	37.4
		MCDB	38.1	44.7	57.0	65.3	77.9	83.2	88.7	87.2	78.2	61.6	50.7	40.3
	10%	WB	34.3	37.3	43.7	47.7	55.9	58.8	61.9	61.8	58.3	49.5	42.8	35.2
		MCDB	36.2	42.0	53.6	60.4	74.6	77.3	85.8	84.4	74.4	59.1	47.5	37.3
Mean Daily Temperature Range	5% DB	MDBR	9.6	14.6	19.8	22.7	24.8	23.3	26.3	26.7	23.5	18.1	11.9	9.6
		MCDBR	13.4	17.7	25.9	30.4	34.3	31.8	34.2	33.9	33.0	23.5	16.9	13.1
		MCWBR	9.0	10.2	12.6	13.8	12.3	10.2	10.4	10.2	11.9	11.2	8.8	8.4
	5% WB	MCDBR	11.6	17.0	24.7	28.1	29.9	29.8	30.8	30.6	29.1	21.4	15.1	12.6
		MCWBR	8.1	10.2	12.6	12.9	11.0	9.7	9.6	9.4	10.7	10.5	8.3	7.9
Clear-Sky Solar Irradiance	taub	0.298	0.304	0.337	0.382	0.396	0.391	0.372	0.378	0.354	0.340	0.313	0.295	
	taud	2.326	2.390	2.384	2.262	2.278	2.335	2.417	2.403	2.455	2.450	2.413	2.327	
	Ebn at Noon	230	265	275	272	273	275	279	271	266	247	224	211	
	Edh at Noon	21	25	31	39	40	38	35	33	29	24	19	18	
All-Sky Solar Radiation	RadAvg	311	615	1012	1443	1729	1875	2040	1736	1213	705	336	236	
	RadStd	28	47	66	119	137	161	158	100	101	70	36	24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page