

LINDBURG LANDING, NT, Canada

WMO: 716820

Lat: 61.125N

Lon: 122.852W

Elev: 600

StdP: 14.38

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.1	-34.9	-47.4	0.4	-39.8	-41.8	0.5	-34.7	11.0	15.1	9.3	18.4	0.3	260	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	83.0	63.5	79.5	62.0	76.4	60.6	66.3	77.6	64.5	74.9	62.8	72.6	3.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	87.4	69.0	60.8	81.3	67.3	59.1	76.4	65.7	31.3	78.0	29.9	75.2	28.7	72.7	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.2	7.2	-44.8	89.0	4.5	3.0	-48.1	91.2	-50.7	92.9	-53.3	94.6	-56.6	96.8	(4)	(4)
(5)			-44.7	70.7	4.1	2.3	-47.7	72.3	-50.1	73.6	-52.4	74.9	-55.4	76.5	(5)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	-9.0	-1.5	8.3	31.4	47.5	58.4	62.4	58.0	46.8	30.9	5.3	-6.8		
	DBStd	28.29	16.00	13.24	14.64	10.87	8.55	6.10	5.06	6.50	7.23	8.73	13.37	15.16		
	HDD50	9130	1829	1441	1293	559	148	8	1	12	143	593	1342	1761		
	HDD65	13635	2294	1861	1758	1009	544	210	110	228	546	1057	1792	2226		
	CDD50	1025	0	0	0	0	70	261	385	260	47	2	0	0		
	CDD65	54	0	0	0	0	1	12	29	12	0	0	0	0		
	CDH74	1221	0	0	0	0	73	319	541	276	12	0	0	0		
	CDH80	259	0	0	0	0	7	73	116	61	2	0	0	0		
(14) Wind	WSAvg	2.4	1.5	1.8	2.5	3.1	3.5	2.8	2.5	2.4	2.6	2.5	1.8	1.4		
(15) Precipitation	PrecAvg	16.3	0.9	0.7	0.7	0.6	1.3	2.5	2.8	2.2	1.7	1.2	1.0	0.9		
	PrecMax	22.9	1.7	1.8	1.7	1.2	2.4	5.1	7.3	4.3	4.0	2.1	2.2	2.0		
	PrecMin	10.1	0.1	0.1	0.0	0.1	0.3	0.7	0.4	0.4	0.5	0.6	0.2	0.2		
	PrecStd	2.8	0.4	0.4	0.4	0.3	0.6	1.3	1.3	0.8	0.8	0.5	0.4	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	44.5	50.4	64.8	80.5	86.3	87.4	86.3	74.9	60.9	46.7	48.8		
		MCWB	35.2	36.6	38.5	48.0	56.8	63.5	66.0	65.7	59.5	48.4	38.1	40.2		
	2%	DB	34.5	35.0	44.7	59.1	75.7	81.9	83.2	80.6	69.7	54.2	36.9	34.6		
		MCWB	30.1	30.3	35.3	44.2	55.5	61.4	64.5	63.8	55.5	44.4	32.5	30.5		
	5%	DB	23.6	23.0	38.6	55.0	70.8	77.4	79.8	76.5	65.5	48.7	28.5	23.5		
		MCWB	22.1	21.6	31.5	41.9	53.2	59.4	63.2	62.1	53.7	41.8	27.5	22.6		
	10%	DB	11.5	16.6	31.6	50.4	65.8	73.7	76.6	72.7	61.3	43.4	22.3	14.7		
		MCWB	10.8	15.5	27.2	39.5	50.5	58.0	62.0	60.5	51.8	39.1	21.5	14.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.7	36.8	39.1	48.4	59.3	66.6	68.9	69.4	61.2	49.7	38.6	40.0		
		MCDB	41.3	44.3	49.3	63.4	76.0	78.1	80.0	80.9	71.8	58.4	46.7	48.8		
	2%	WB	30.0	30.4	35.5	44.7	56.7	64.1	66.6	66.0	57.4	45.1	32.5	30.7		
		MCDB	34.5	34.7	44.0	57.4	71.6	75.1	78.0	76.5	65.4	52.3	36.8	35.0		
	5%	WB	22.0	21.7	31.7	42.2	54.2	62.0	65.0	63.7	54.9	42.4	27.3	22.4		
		MCDB	23.5	23.1	38.2	53.9	69.1	72.6	75.8	73.1	62.7	48.4	28.7	23.4		
	10%	WB	10.7	15.4	27.2	39.9	51.4	60.0	63.5	61.5	52.7	39.2	21.7	14.3		
		MCDB	11.3	16.5	31.2	49.9	64.3	70.2	73.5	70.5	60.1	42.9	22.4	14.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.9	21.1	27.1	25.6	25.9	24.4	23.6	23.3	21.5	14.5	14.7	15.4		
		MCDBR	26.2	29.1	34.4	32.9	35.3	32.6	31.6	32.4	30.3	24.4	20.1	27.0		
	5% WB	MCWBR	22.3	25.2	25.1	18.9	16.3	14.2	14.8	17.0	17.2	15.5	16.7	23.0		
		MCDWR	26.3	29.1	33.4	31.3	33.0	27.2	28.4	29.6	27.5	23.7	19.9	26.8		
(40) Clear-Sky Solar Irradiance	taub		0.204	0.251	0.267	0.329	0.349	0.365	0.380	0.356	0.307	0.282	0.209	0.166		
		taud	2.134	2.269	2.284	2.259	2.417	2.411	2.400	2.469	2.593	2.508	2.179	1.988		
	Ebn at Noon		180	239	275	273	278	274	266	264	263	230	175	139		
		Edh at Noon	11	20	27	35	32	33	33	28	21	16	10	7		
(44) All-Sky Solar Radiation	RadAvg		111	377	929	1493	1748	1799	1690	1352	856	392	139	56		
	RadStd		8	30	58	74	110	145	135	100	92	33	15	3		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	+227	+36
(47) Regional (5 neighbors)			N/A	+3.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page