

WHISTLER NESTERS, BC, Canada

WMO: 716870

Lat: 50.1289N

Lon: 122.9547W

Elev: 2162

StdP: 13.58

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 5.9	(c) 10.1	(d) -4.0	(e) 4.8	(f) 10.5	(g) 1.7	(h) 6.5	(i) 12.6	(j) 11.9	(k) 26.5	(l) 10.1	(m) 26.7	(n) 2.2	(o) 0	(p) 0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 25.0	(c) 87.6	(d) 62.0	(e) 83.9	(f) 60.8	(g) 79.9	(h) 59.7	(i) 63.9	(j) 82.3	(k) 62.2	(l) 79.4	(m) 60.7	(n) 76.2	(o) 3.6	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.7	77.0	66.9	56.2	72.8	65.1	54.8	69.1	63.4	30.2	83.0	28.9	79.6	27.8	76.4	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.6	8.1	7.4	DB	1.7	93.0	4.3	3.5	-1.4	95.5	-3.9	97.6	-6.3	99.5	-9.4	102.1	
			WB	0.8	67.3	4.4	3.7	-2.3	70.0	-4.9	72.1	-7.4	74.2	-10.6	76.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.3	28.6	30.5	35.6	42.0	51.6	56.4	63.0	62.8	54.8	43.7	34.0	27.2
	DBStd	14.09	7.34	7.06	5.30	5.26	6.09	5.80	5.87	5.36	6.14	4.94	6.81	7.41
	HDD50	3379	664	545	446	250	54	7	0	0	21	204	480	708
	HDD65	7666	1129	965	910	691	414	268	109	107	310	660	930	1173
	CDD50	1287	0	0	0	9	105	198	404	398	165	8	0	0
	CDD65	101	0	0	0	0	0	9	48	40	4	0	0	0
	CDH74	2420	0	0	0	7	113	279	985	849	187	0	0	0
	CDH80	815	0	0	0	0	18	94	361	293	49	0	0	0
Wind	WSAvg	2.2	1.5	1.9	2.1	2.5	2.5	2.9	2.8	2.5	2.1	1.8	1.8	1.6
Precipitation	PrecAvg	49.9	7.0	4.6	4.7	2.7	2.0	2.1	1.5	2.2	2.9	6.3	7.6	7.1
	PrecMax	66.3	14.1	10.5	8.9	5.7	4.2	4.2	3.1	9.2	6.4	14.5	17.3	10.6
	PrecMin	37.7	3.5	0.4	1.2	0.4	0.5	0.7	0.3	0.4	0.6	0.2	2.2	2.6
	PrecStd	7.1	2.3	2.4	2.0	1.3	0.9	0.9	0.8	1.9	1.5	3.4	3.9	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	48.4	58.6	73.8	82.5	89.1	93.8	91.1	86.0	65.8	51.2	42.8
		MCWB	40.2	38.9	45.0	54.8	57.4	62.4	64.7	63.1	59.9	53.5	49.0	42.1
	2%	DB	39.3	44.0	52.5	63.6	77.1	81.8	88.0	87.0	79.6	59.3	47.3	39.1
		MCWB	38.1	39.1	43.0	47.9	56.2	59.5	62.7	61.7	58.4	50.2	45.5	38.5
	5%	DB	37.3	41.2	47.8	57.3	72.0	75.7	84.0	83.3	73.9	55.6	45.0	37.0
		MCWB	36.3	37.9	40.6	45.2	53.8	57.6	61.0	61.0	57.1	48.9	43.7	36.4
	10%	DB	35.7	38.9	44.1	52.6	66.8	70.2	79.6	78.8	67.8	52.2	42.7	35.0
		MCWB	34.8	36.7	39.4	43.3	52.1	55.4	60.0	59.7	55.2	47.5	41.6	34.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.2	43.0	48.7	54.9	59.9	63.7	67.8	65.6	62.8	56.1	50.3	42.2
		MCDB	42.1	44.5	56.2	70.8	76.5	83.2	87.5	84.1	78.7	61.5	51.2	42.7
	2%	WB	38.4	40.7	44.4	50.1	57.2	60.9	64.5	63.6	60.4	52.8	45.9	38.7
		MCDB	39.0	42.9	49.5	59.6	73.5	78.1	84.0	81.4	73.3	56.7	46.8	39.1
	5%	WB	36.5	38.6	41.9	46.8	55.1	58.6	62.5	62.0	58.5	50.1	43.9	36.5
		MCDB	37.2	40.3	46.6	54.4	69.1	73.1	79.8	79.2	69.9	53.5	44.8	36.9
	10%	WB	35.0	36.7	39.7	44.4	53.0	56.3	60.6	60.6	56.3	48.0	41.6	34.6
		MCDB	35.6	38.4	43.4	50.3	64.3	67.8	76.4	76.0	66.4	51.4	42.7	35.0
Mean Daily Temperature Range	5% DB	MDBR	8.8	12.3	14.6	18.0	22.8	20.2	25.0	25.3	21.1	14.2	8.3	7.6
		MCDBR	8.8	15.5	22.8	30.2	35.6	34.1	36.0	36.5	35.2	22.3	10.9	7.1
	5% WB	MCWBR	7.5	10.7	13.6	16.2	16.4	14.1	13.2	13.8	15.9	13.6	8.9	6.7
		MCWBR	8.0	12.6	19.3	25.2	30.6	30.3	32.0	31.7	29.3	18.4	9.9	6.8
Clear-Sky Solar Irradiance	taub	taub	0.277	0.280	0.300	0.345	0.356	0.356	0.350	0.347	0.324	0.321	0.285	0.270
		taud	2.248	2.278	2.232	2.118	2.228	2.351	2.397	2.431	2.499	2.462	2.366	2.249
	Ebn at Noon	Ebn at Noon	240	273	287	283	285	285	285	281	278	257	238	224
		Edh at Noon	23	28	36	45	42	37	35	33	27	24	20	19
All-Sky Solar Radiation	RadAvg	RadAvg	272	546	799	1281	1682	1680	1879	1634	1122	626	306	219
	RadStd	RadStd	48	83	127	159	161	208	187	125	99	101	61	37

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page