

WHISTLER NESTERS, BC, Canada

WMO: 716870

Lat: 50.1289N

Lon: 122.9547W

Elev: 659

StdP: 93.65

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-14.5	-12.2	-20.0	0.7	-11.9	-16.8	0.9	-10.8	5.3	-3.0	4.5	-3.0	1.0	0	0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	30.9	16.7	28.8	16.0	26.6	15.4	17.7	28.0	16.8	26.3	15.9	24.6	1.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	11.0	19.4	13.4	10.4	18.4	12.6	9.9	17.5	52.4	28.3	49.3	26.5	46.7	24.7	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.8	3.6	3.3	-16.8	33.9	2.4	2.0	-18.5	35.3	-19.9	36.4	-21.3	37.5	-23.0	38.9		
			-17.3	19.6	2.4	2.0	-19.1	21.1	-20.5	22.3	-21.9	23.4	-23.7	24.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.8	-1.9	-0.8	2.0	5.5	10.9	13.5	17.2	17.1	12.7	6.5	1.1	-2.7
	DBStd	7.83	4.08	3.92	2.95	2.92	3.38	3.22	3.26	2.98	3.41	2.74	3.78	4.12
	HDD10.0	1877	369	303	248	139	30	4	0	0	12	113	267	393
	HDD18.3	4259	627	536	506	384	230	149	61	59	172	367	517	652
	CDD10.0	715	0	0	0	5	58	110	224	221	92	4	0	0
	CDD18.3	56	0	0	0	0	5	27	22	2	0	0	0	0
	CDH23.3	1344	0	0	0	4	63	155	547	472	104	0	0	0
	CDH26.7	453	0	0	0	0	10	52	201	163	27	0	0	0
(14) Wind	WSAvg	1.0	0.7	0.9	0.9	1.1	1.1	1.3	1.2	1.1	0.9	0.8	0.8	0.7
(15) Precipitation	PrecAvg	1268	178	117	119	68	50	53	37	55	73	161	193	181
	PrecMax	1684	358	266	225	146	106	106	78	233	162	368	439	268
	PrecMin	958	90	11	31	10	12	18	7	9	14	5	56	66
	PrecStd	181	58	60	50	32	23	23	21	48	38	87	98	52
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	9.1	14.8	23.2	28.0	31.7	34.3	32.8	30.0	18.8	10.7	6.0
		MCWB	4.5	3.8	7.2	12.7	14.1	16.9	18.1	17.3	15.5	12.0	9.4	5.6
	2%	DB	4.1	6.7	11.4	17.6	25.1	27.7	31.1	30.5	26.4	15.2	8.5	3.9
		MCWB	3.4	3.9	6.1	8.8	13.5	15.3	17.0	16.5	14.7	10.1	7.5	3.6
	5%	DB	3.0	5.1	8.8	14.1	22.2	24.3	28.9	28.5	23.3	13.1	7.2	2.8
		MCWB	2.4	3.3	4.8	7.3	12.1	14.2	16.1	16.1	14.0	9.4	6.5	2.4
	10%	DB	2.1	3.8	6.7	11.5	19.3	21.2	26.4	26.0	19.9	11.2	6.0	1.7
		MCWB	1.6	2.6	4.1	6.3	11.2	13.0	15.6	15.4	12.9	8.6	5.4	1.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.1	6.1	9.3	12.7	15.5	17.6	19.9	18.6	17.1	13.4	10.2	5.7
		MCDB	5.6	6.9	13.4	21.6	24.7	28.4	30.8	28.9	25.9	16.4	10.7	5.9
	2%	WB	3.6	4.8	6.9	10.0	14.0	16.0	18.1	17.6	15.8	11.5	7.7	3.7
		MCDB	3.9	6.1	9.7	15.3	23.1	25.6	28.9	27.5	22.9	13.7	8.2	3.9
	5%	WB	2.5	3.7	5.5	8.2	12.8	14.8	16.9	16.7	14.7	10.1	6.6	2.5
		MCDB	2.9	4.6	8.1	12.5	20.6	22.8	26.5	26.2	21.1	11.9	7.1	2.7
	10%	WB	1.7	2.6	4.3	6.9	11.7	13.5	15.9	15.9	13.5	8.9	5.4	1.5
		MCDB	2.0	3.6	6.3	10.2	17.9	19.9	24.6	24.5	19.1	10.8	5.9	1.7
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	6.8	8.1	10.0	12.7	11.2	13.9	14.0	11.7	7.9	4.6	4.2
		MCDBR	4.9	8.6	12.7	16.8	19.8	18.9	20.0	20.3	19.5	12.4	6.1	3.9
	5% WB	MCWBR	4.2	5.9	7.6	9.0	9.1	7.9	7.4	7.7	8.8	7.6	4.9	3.7
		MCDWR	4.4	7.0	10.7	14.0	17.0	16.8	17.8	17.6	16.3	10.2	5.5	3.8
(40) Clear-Sky Solar Irradiance	taub	taub	0.277	0.280	0.300	0.345	0.356	0.356	0.350	0.347	0.324	0.321	0.285	0.270
		taud	2.248	2.278	2.232	2.118	2.228	2.351	2.397	2.431	2.499	2.462	2.366	2.249
	Ebn at Noon	Ebn at Noon	756	862	905	893	899	900	900	887	877	809	750	705
		Edh at Noon	71	89	112	141	132	118	111	103	86	75	63	61
(44) All-Sky Solar Radiation	RadAvg	0.86	1.72	2.52	4.04	5.30	5.30	5.92	5.15	3.54	1.97	0.96	0.69	
	RadStd	0.15	0.26	0.40	0.50	0.51	0.66	0.59	0.40	0.31	0.32	0.19	0.12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page