

TEEPEE CREEK AGCM, AB, Canada

WMO: 716900

Lat: 55.3524N

Lon: 118.4076W

Elev: 2198

StdP: 13.57

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-31.3	-24.4	-37.7	0.7	-31.2	-30.4	1.1	-24.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	81.8	61.0	78.5	59.9	75.5	58.6	64.2	75.4	62.4	74.2	60.7	72.0	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.0	83.8	69.0	58.1	78.2	66.6	56.2	73.1	64.4	30.5	75.2	29.1	74.3	27.9	72.4	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	DB	-37.9	87.1	7.4	2.7	-43.2	89.0	-47.6	90.6	-51.7	92.1	-57.1	94.1	
			WB	-38.1	67.4	7.3	3.2	-43.4	69.7	-47.7	71.5	-51.8	73.3	-57.1	75.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	35.7	12.3	11.6	21.0	37.3	50.6	57.4	60.8	59.0	49.7	37.7	20.0	9.0	(6)
	DBStd	21.92	16.04	16.00	13.85	8.81	7.56	5.34	4.46	5.79	7.60	8.51	12.71	14.00	(7)
	HDD50	6283	1170	1074	900	386	86	6	0	5	98	387	900	1271	(8)
	HDD65	10738	1635	1494	1365	830	447	233	144	198	460	846	1350	1736	(9)
	CDD50	1051	0	0	0	6	104	229	334	283	88	7	0	0	(10)
	CDD65	29	0	0	0	0	0	5	13	11	0	0	0	0	(11)
	CDH74	982	0	0	0	7	71	168	356	304	76	0	0	0	(12)
	CDH80	179	0	0	0	1	9	23	67	69	10	0	0	0	(13)
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15) Precipitation	PrecAvg	18.5	1.3	0.8	0.9	1.0	1.8	3.0	2.9	2.1	1.5	1.2	1.2	0.9	(15)
	PrecMax	25.3	4.0	2.0	1.8	1.9	3.5	5.4	5.2	5.5	4.3	3.5	3.6	3.8	(16)
	PrecMin	12.1	0.4	0.2	0.4	0.2	0.7	0.7	1.1	0.7	0.3	0.2	0.2	0.0	(17)
	PrecStd	3.6	0.7	0.4	0.4	0.5	0.8	1.4	1.1	1.1	0.8	0.7	0.7	0.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.8	41.0	49.0	71.2	80.8	82.9	86.3	86.2	81.1	69.5	49.6	40.9	(19)
		MCWB	36.5	35.4	40.5	50.2	54.2	61.3	63.9	62.9	58.5	53.4	42.1	35.3	(20)
	2%	DB	39.7	38.8	45.2	62.6	75.2	78.8	81.2	81.6	75.7	61.0	42.9	37.2	(21)
		MCWB	35.6	34.6	37.6	46.4	53.6	59.3	61.8	62.7	57.7	48.3	38.4	33.2	(22)
	5%	DB	37.6	36.7	41.7	56.0	71.0	75.0	77.9	77.1	70.7	55.7	39.2	34.0	(23)
		MCWB	34.5	33.3	35.5	42.8	51.8	57.0	60.7	60.7	55.2	45.1	34.8	30.6	(24)
	10%	DB	34.9	33.5	38.9	51.4	67.1	71.3	74.7	73.5	65.2	51.6	36.2	30.0	(25)
		MCWB	32.2	30.4	33.9	40.9	49.9	55.7	59.4	59.1	53.0	43.2	33.3	27.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.9	36.5	41.3	51.5	57.9	64.2	67.4	66.7	61.7	54.6	43.1	36.1	(27)
		MCDB	40.5	39.8	47.5	70.0	73.9	77.3	79.6	79.5	77.0	66.6	47.3	39.6	(28)
	2%	WB	35.9	35.0	38.1	47.4	55.1	61.2	64.6	64.2	58.7	49.8	38.5	33.4	(29)
		MCDB	39.0	38.2	44.0	60.9	70.1	74.5	75.3	75.3	71.6	59.2	42.6	36.9	(30)
	5%	WB	34.6	33.4	36.0	43.8	53.0	59.4	62.6	62.4	56.1	46.4	35.6	30.7	(31)
		MCDB	37.5	36.6	41.1	54.1	67.6	71.5	73.8	73.7	68.9	53.5	38.5	33.9	(32)
	10%	WB	32.2	30.4	34.2	41.4	51.2	57.5	60.9	60.5	53.9	43.8	33.4	27.3	(33)
		MCDB	35.0	33.3	38.7	50.6	64.9	68.1	71.5	71.5	64.0	50.4	36.0	29.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	17.8	20.7	21.7	20.3	24.6	21.8	23.6	24.2	24.8	19.4	17.2	17.5	(35)
		MCDBR	16.6	18.7	23.6	30.3	32.5	29.9	31.5	31.5	35.1	27.5	19.6	20.9	(36)
	5% WB	MCWBR	13.6	14.9	16.7	16.0	14.5	13.2	14.6	14.8	17.6	16.4	14.8	17.6	(37)
		MCWBR	15.6	17.7	22.2	27.5	29.0	25.5	27.2	27.9	32.4	26.3	18.0	21.0	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.239	0.250	0.303	0.326	0.343	0.350	0.350	0.350	0.310	0.284	0.246	0.234	(40)
		taud	2.332	2.390	2.305	2.386	2.400	2.398	2.419	2.409	2.530	2.563	2.437	2.250	(41)
	Ebn at Noon	Ebn at Noon	231	272	276	285	285	284	281	274	274	258	229	200	(42)
		Edh at Noon	16	22	30	33	34	35	34	32	24	19	14	13	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	236	533	996	1479	1760	1922	1878	1530	1049	566	258	169	(44)
	RadStd	RadStd	23	41	79	86	122	151	123	132	96	62	22	15	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page