

MARTICOT ISLAND, NL, CanadaWMO: **716920**Lat: **47.328N**Lon: **54.585W**Elev: **72**StdP: **14.66**Time Zone: **-3.50 (NAF)**Period: **94-17**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.2	12.5	0.3	5.6	10.7	3.3	6.5	13.3	51.1	26.4	45.3	27.5	13.8	340	0.794

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	67.5	62.3	65.3	61.7	63.8	61.1	64.2	65.5	63.0	64.2	62.0	63.2	10.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	88.6	64.6	62.6	85.2	63.6	61.5	81.8	62.6	29.5	65.6	28.6	64.2	27.9	63.4	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.8	35.1	29.7	DB	4.6	73.4	4.0	1.7	1.6	74.7	-0.7	75.7	-3.0	76.7	-5.9	78.0	(4)
(5)			WB	3.0	66.7	3.9	1.9	0.2	68.1	-2.1	69.2	-4.3	70.3	-7.1	71.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.9	27.1	26.0	29.0	35.5	41.7	48.9	56.2	60.8	56.0	48.0	40.3	31.7
	DBStd	12.75	6.73	6.67	6.38	3.88	3.70	4.25	3.66	3.07	4.29	5.12	5.70	6.67
	HDD50	3763	711	672	651	436	257	69	1	0	6	100	292	568
	HDD65	8452	1176	1092	1116	886	721	483	273	132	271	528	741	1033
	CDD50	791	0	0	0	0	1	36	194	336	185	38	1	0
	CDD65	4	0	0	0	0	0	0	0	3	1	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.1	16.4	15.6	14.6	13.1	11.1	10.0	9.5	10.6	12.1	13.9	14.9	15.9
Precipitation	PrecAvg	58.9	5.3	4.6	4.4	4.5	4.3	4.0	4.2	4.1	5.5	6.4	6.0	5.9
	PrecMax	70.3	8.6	6.5	7.8	10.2	6.7	7.6	6.9	6.6	8.8	11.5	7.6	9.1
	PrecMin	49.9	2.6	2.2	2.0	1.8	1.5	2.2	2.2	2.6	2.5	3.6	2.9	3.9
	PrecStd	5.0	1.5	1.2	1.6	2.4	1.4	1.5	1.4	1.0	1.8	2.1	1.3	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	41.3	43.3	48.5	56.5	64.9	69.1	70.9	69.2	61.2	54.3	49.2
		MCWB	43.0	41.1	39.9	43.1	48.1	56.6	61.5	63.0	63.4	58.5	53.4	48.6
	2%	DB	40.5	39.1	39.9	44.7	52.6	60.0	65.1	68.1	65.5	58.8	52.0	46.1
		MCWB	40.1	38.8	38.2	41.3	47.1	54.7	60.2	62.9	62.0	56.7	51.3	45.5
	5%	DB	38.3	37.2	38.1	42.4	49.4	57.1	63.0	66.1	63.4	56.8	50.4	43.6
		MCWB	37.5	36.7	36.7	40.0	45.3	53.1	60.0	62.3	60.7	55.0	49.6	42.9
	10%	DB	36.0	34.9	36.4	40.6	47.1	54.7	61.2	64.6	61.8	55.2	48.5	40.5
		MCWB	35.2	34.3	35.1	38.6	44.3	52.0	59.0	62.0	59.6	53.6	47.6	39.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.1	41.2	41.2	45.0	51.0	58.8	64.3	66.2	65.3	60.3	53.7	48.8
		MCDB	43.3	41.3	42.3	46.2	53.3	61.5	65.9	67.9	66.9	60.7	54.1	49.0
	2%	WB	40.2	39.0	38.7	42.3	48.3	56.2	62.1	64.7	63.4	57.7	51.2	45.7
		MCDB	40.4	39.0	39.5	43.8	50.5	58.6	63.4	66.0	64.7	58.1	51.5	46.1
	5%	WB	37.8	36.8	36.9	40.5	46.3	54.2	60.8	63.7	61.8	55.7	49.6	43.1
		MCDB	38.1	37.0	37.6	42.0	48.5	56.2	62.2	64.9	62.9	56.4	50.0	43.6
	10%	WB	35.4	34.4	35.4	39.0	44.7	52.5	59.4	62.8	60.3	54.0	47.5	39.7
		MCDB	35.9	34.8	36.1	40.5	46.7	54.3	60.8	63.9	61.4	54.9	48.1	40.4
Mean Daily Temperature Range	5% DB	MDBR	9.6	9.3	8.8	7.8	8.9	8.7	6.9	6.9	8.1	7.5	7.9	8.9
		MCDBR	11.7	10.0	9.3	10.8	13.2	13.1	10.4	9.4	9.9	8.5	8.7	11.4
		MCWBR	12.6	10.4	8.3	8.4	8.8	8.3	6.6	6.2	7.5	8.0	9.8	12.4
	5% WB	MCDBR	11.8	10.1	9.4	10.0	11.4	11.6	8.4	7.3	8.2	8.1	8.4	11.2
		MCWBR	12.8	10.7	8.9	8.3	8.6	8.3	6.4	5.6	7.5	8.5	9.5	12.5
Clear-Sky Solar Irradiance	taub		0.319	0.319	0.334	0.368	0.383	0.407	0.436	0.408	0.371	0.350	0.324	0.313
	taud		2.347	2.422	2.428	2.359	2.371	2.339	2.301	2.387	2.469	2.477	2.479	2.380
	Ebn at Noon		239	269	282	281	280	272	262	266	266	254	239	226
	Edh at Noon		23	27	31	36	37	39	40	35	30	25	21	20
All-Sky Solar Radiation	RadAvg		330	542	896	1327	1588	1631	1559	1375	1111	691	384	271
	RadStd		24	59	57	118	117	163	117	82	70	52	47	24

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page